

STN	Klimatizačné jednotky, jednotky na chladenie kvapalín a tepelné čerpadlá s elektricky poháňanými kompresormi na vykurovanie a chladenie. Skúšanie a hodnotenie pri podmienkach čiastočnej záťaže a výpočet sezónnej účinnosti.	STN EN 14825 14 3003
------------	---	--

Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 12/13

Obsahuje: EN 14825:2013

Oznámením tejto normy sa ruší
STN EN 14825 (14 3003) z augusta 2012

EUROPEAN STANDARD

EN 14825

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2013

ICS 27.080; 91.140.30

Supersedes EN 14825:2012

English Version

**Air conditioners, liquid chilling packages and heat pumps, with
electrically driven compressors, for space heating and cooling -
Testing and rating at part load conditions and calculation of
seasonal performance**

Climatiseurs, groupes refroidisseurs de liquide et pompes à
chaleur avec compresseur entraîné par moteur électrique
pour le chauffage et la réfrigération des locaux - Essais et
détermination des caractéristiques à charge partielle et
calcul de performance saisonnière

Luftkonditionierer, Flüssigkeitskühlsätze und
Wärmepumpen mit elektrisch angetriebenen Verdichtern
zur Raumbeheizung und -kühlung - Prüfung und
Leistungsbemessung unter Teillastbedingungen und
Berechnung der saisonalen Arbeitszahl

This European Standard was approved by CEN on 18 July 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	5
Introduction	7
1 Scope	8
2 Normative references	8
3 Terms, definitions, symbols, abbreviated terms and units	8
3.1 Terms and definitions	8
3.2 Symbols, abbreviated terms and units.....	17
4 Part load conditions in cooling mode	19
4.1 General.....	19
4.2 Air-to-air units	19
4.3 Water-to-air units and brine-to-air units	20
4.4 Air-to-water units	20
4.5 Water-to-water and brine-to-water units.....	21
5 Part load conditions in heating mode	22
5.1 General.....	22
5.2 Air-to-air units	23
5.3 Water-to-air and brine-to-air units.....	24
5.4 Air-to-water units	25
5.4.1 General.....	25
5.4.2 Low temperature application	26
5.4.3 Medium temperature application	29
5.4.4 High temperature application	32
5.4.5 Very high temperature application.....	35
5.5 Water-to-water and brine-to-water units.....	37
5.5.1 General.....	37
5.5.2 Low temperature application	38
5.5.3 Medium temperature application	41
5.5.4 High temperature application	44
5.5.5 Very high temperature application.....	47
6 Calculation methods for reference SEER and reference SEERon	49
6.1 General formula for calculation of reference SEER	49
6.2 Calculation of the reference annual cooling demand (Q_C)	49
6.3 Calculation of the reference annual electricity consumption (Q_{CE}).....	50
6.4 Calculation of reference SEERon.....	50
6.5 Calculation procedure for determination of EERbin(T_j) values at part load conditions B, C, D.....	51
6.5.1 General.....	51
6.5.2 For air-to-air & water-to-air units.....	51
6.5.3 Air-to-water, water-to-water & brine-to-water units.....	52
7 Calculation methods for reference SCOP, reference SCOPon and reference SCOPnet.....	52
7.1 General formula for calculation of reference SCOP.....	52
7.2 Calculation of the reference annual heating demand (Q_H)	53
7.3 Calculation of the annual electricity consumption (Q_{HE})	53
7.4 Calculation of reference SCOPon and reference SCOPnet.....	53
7.5 Calculation procedure for determination of COPbin(T_j) values at part load conditions A, B, C, D	54
7.5.1 General.....	54
7.5.2 For air-to-air, brine-to-air and water-to-air units.....	55

7.5.3	For air-to-water, water-to-water and brine-to-water units	55
8	Test methods for testing capacities, EER _{bin} (T _j) and COP _{bin} (T _j) values during active mode at part load conditions	56
8.1	General	56
8.2	Basic principles	56
8.3	Uncertainties of measurement	57
8.4	Test procedures for units with fixed capacity	58
8.4.1	General	58
8.4.2	Air-to-air and water-to-air units – Determination of the degradation coefficient Cd	58
8.4.3	Air-to-water units and water-to-water units – Determination of the degradation factor Cc	59
8.5	Test procedure for staged and variable capacity units (air-to-air, air-to-water, water-to-air, water/brine-to-water)	60
8.5.1	Air-to-air & water-to-air units	60
8.5.2	Air-to-water and water/brine-to-water units	60
9	Test methods for electric power consumption during thermostat-off mode, standby mode and crankcase heater mode	60
9.1	Measurement of electric power consumption during thermostat-off mode	60
9.2	Measurement of the electric power consumption during standby mode	61
9.3	Measurement of the electric power consumption during crankcase heater mode	61
9.4	Measurement of the electric power consumption during off mode	61
10	Test report	61
11	Technical data sheet	62
Annex A	(normative) Applicable climate bin hours and hours for active mode, thermostat-off, standby, off mode for air conditioners below and equal to 12 kW	63
A.1	Climate bins	63
A.1.1	Bin limit temperature	63
A.1.2	Cooling	63
A.1.3	Heating	63
A.2	Hours for active mode, thermostat-off, standby, off mode	65
A.2.1	Cooling	65
A.2.2	Heating	65
A.3	Hours used for crankcase heater mode	65
A.3.1	Cooling	65
A.3.2	Heating	66
Annex B	(informative) Calculation example for reference SEER _{on} and reference SEER – Application to a reverse cycle air-to-air unit with variable capacity	67
B.1	Calculation of SEER _{on}	67
B.2	Calculation of SEER	68
B.2.1	Calculation of reference annual cooling demand (QC) according to Formula (2)	68
B.2.2	Calculation of reference SEER according to Formula (1)	69
Annex C	(informative) Calculation example for reference SCOP _{on} and reference SCOP _{net} of a fixed capacity air-to-water heat pump used for floor heating	70
Annex D	(informative) Adaption of water temperature for fixed capacity units	74
Annex E	(informative) Determination of reference annual cooling/heating demands and determination of hours for active mode, thermostat-off, standby, off mode and crankcase heater mode	77
E.1	General	77
E.2	Determination of reference annual cooling/heating demands and hours for active mode, thermostat-off, standby, off mode	77
E.3	Hours used for crankcase heater mode	79
Annex F	(informative) Compensation method for air-to-water and water/brine-to-water units	80
F.1	General	80
F.2	Compensation system for reduced capacity test in cooling mode	80
F.3	Compensation system for reduced capacity test in heating mode	80

Annex G (normative) Template for technical data sheet.....	82
Annex ZA (informative) Relationship between this European Standard and the requirements of Commission Regulation (EC) No 206/2012	85
Bibliography	86

Foreword

This document (EN 14825:2013) has been prepared by Technical Committee CEN/TC 113 “Heat pumps and air conditioning units”, the secretariat of which is held by AENOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2014, and conflicting national standards shall be withdrawn at the latest by March 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14825:2012.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

The main changes with respect to the previous edition are:

- a) Clause 3 “Terms, definitions, symbols, abbreviated terms and units” has been modified in order to be harmonised with Commission Regulation (EC) No 206/2012;
- b) modifications so that the text is aligned to the modified terms and definitions;
- c) a new normative Annex A, Applicable climate bin hours and hours for active mode, thermostat-off, standby, off mode for air conditioners below and equal to 12 kW, which includes Tables 26 and 37 of the previous standard;
- d) a new normative Annex G, Template for technical data sheet;
- e) a new informative Annex ZA, Relationship between this European Standard and the requirements of Commission Regulation (EC) No 206/2012;
- f) see the following cross references regarding structural changes:

EN 14825:2013	EN 14825:2012
6.1	-
6.2	6.2
6.3	6.1
6.4	6.3
6.5	6.4
7.1	7.1
7.2	7.2
7.3	7.1
7.4	7.3
7.5	7.4
Annex A	-
Annex B	Annex A
Annex C	Annex B
Annex D	Annex C
Annex E	Annex D
Annex F	Annex E
Annex G	-

Although this document be prepared in the frame of the Commission Regulation (EU) No 206/2012 implementing Directive 2009/125/EC with regard to ecodesign requirements for air conditioners and comfort fans, it may also be used to show compliance with the requirements of the European Directive 2010/30/EU and Commission Delegated Regulation (EU) No 626/2011.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Heat pumps, air conditioners and liquid chilling packages are, at present, selected and compared at a rated condition. This condition does not represent the usual operating conditions of the equipment over a season. This operating condition can be better assessed by comparing equipment at representative reduced capacities and determining the Seasonal Energy Efficiency Ratio and Seasonal Coefficient of Performance.

Fixed capacity heat pumps, air conditioners and liquid chilling packages deal with varying loads by varying the operation time. The efficiency of the system is dependent on the effectiveness of the controlling thermostats. Variable capacity air conditioners, liquid chilling packages and heat pumps, by continuous or step control of the compressor, can more closely match the varying load improving system efficiency.

This European Standard provides part load conditions and calculation methods for calculating the Seasonal Energy Efficiency Ratio (SEERon) and Seasonal Coefficient of Performance (SCOPon and SCOPnet) of such units when they are used to fulfil the cooling and heating demands.

Other energy consumptions can occur when the unit is not used to fulfil the cooling and heating demands such as those from a crankcase heater or when the unit is on standby. These consumptions are considered in the calculation methods for reference SEER and reference SCOP.

Reference SEER/SEERon and reference SCOP/SCOPon/SCOPnet calculations may be based on calculated or tested values. In case of tested values, this European Standard gives the methods for testing heat pumps, air conditioners and liquid chilling packages at part load conditions.

The rating conditions and test methods of units operating at rated and application capacities are given in EN 14511-2 and EN 14511-3.

The methods for calculation of system energy efficiencies for specific heat pump systems in buildings are given in EN 15316-4-2.

1 Scope

This European Standard covers air conditioners, heat pumps and liquid chilling packages. It applies to factory made units defined in EN 14511-1, except single duct, control cabinet and close control units.

This European Standard gives the calculation methods for the determination of reference seasonal energy efficiency SEER and SEER_{on} and reference seasonal coefficient of performance SCOP, SCOP_{on} and SCOP_{net}.

Such calculation methods may be based on calculated or measured values.

In case of measured values, this European Standard covers the test methods for determination of capacities, EER and COP values during active mode at part load conditions. It also covers test methods for electric power consumption during thermostat-off mode, standby mode, off-mode and crankcase heater mode.

This European Standard serves as an input for the calculation of the system energy efficiency in heating mode of specific heat pump systems in buildings, as stipulated in the standard EN 15316-4-2.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14511-1, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 1: Terms and definitions*

EN 14511-2, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 2: Test conditions*

EN 14511-3:2011, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 3: Test methods*

EN 14511-4, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 4: Operating requirements, marking and instructions*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN