

STN	Nízkonapäťové prepäťové ochranné prístroje. Prepäťové ochranné prístroje pre špecifické aplikácie vrátane jednosmerného prúdu. Časť 12: Princípy výberu a použitia. SPD pripojené k fotovoltickým inštaláciám.	STN P CLC/TS 50539-12 34 1392
------------	---	---

Low-voltage surge protective devices - Surge protective devices for specific application including d.c. -- Part 12: Selection and application principles - SPDs connected to photovoltaic installations

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Obsahuje: CLC/TS 50539-12:2013

Oznámením tejto normy sa ruší
STN P CLC/TS 50539-12 (34 1392) z júla 2010

118966

Úrad pre normalizáciu, metrológiu a skúšobníctvo SR, odbor SÚTN, 2014
Podľa zákona č. 264/1999 Z. z. v znení neskorších predpisov sa môžu slovenské technické normy
rozmnžovať a rozširovať iba so súhlasom Úradu pre normalizáciu, metrológiu a skúšobníctvo SR.

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 50539-12

December 2013

ICS 29.120.50

Supersedes CLC/TS 50539-12:2010

English version

**Low-voltage surge protective devices -
Surge protective devices for specific application including d.c. -
Part 12: Selection and application principles -
SPDs connected to photovoltaic installations**

Parafoudres basse tension -
Parafoudres pour applications spécifiques
incluant le courant continu -
Partie 12: Principes de choix et
d'application -
Parafoudres connectés aux installations
photovoltaïques

Überspannungsschutzgeräte für
Niederspannung -
Überspannungsschutzgeräte für
besondere Anwendungen einschließlich
Gleichspannung -
Teil 12: Auswahl und
Anwendungsgrundsätze -
Überspannungsschutzgeräte für den
Einsatz in Photovoltaik-Installationen

This Technical Specification was approved by CENELEC on 2013-10-21.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Contents

Page

Foreword	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Systems and equipment to be protected	9
5 Overvoltages in a PV installation	9
6 Installation and location of SPDs	9
6.1 General	9
6.2 PV installation without external LPS	10
6.3 PV installation with external LPS when separation distance s is kept	11
6.4 PV installation with external LPS when separation distance is not kept	13
7 Equipotential bonding	13
8 Surge protective devices (SPD) in PV installations	15
9 Requirements for the implementation of SPDs	15
9.1 Decision for using SPDs	15
9.2 Selection and installation of SPDs for application in PV installation	16
9.2.1 Selection of SPDs installed at the a.c. side of PV installations	16
9.2.2 Selection of SPDs installed at the d.c. side of PV-installation	18
10 Maintenance	23
Annex A (informative) Determination of the value of I_{imp} or I_n for SPDs for different structures protected by a LPS according to a simplified approach	24
A.1 Introduction	24
A.2 PV installation on a building according to 6.4	24
A.2.1 General	24
A.2.2 Case of voltage limiting and combination type SPDs (having voltage switching and limiting components in series)	26
A.2.3 Case of voltage switching and combination type SPDs (having voltage switching and limiting components in parallel)	27
A.3 Outside free field power plant PV installation according to 6.4	27
A.3.1 General	27
A.3.2 Assumption	27
A.3.3 Result	28
Annex B (informative) Characteristic of a PV source	30
B.1 General	30
B.2 Calculation of U_{OCMAX}	31
B.3 Calculation of I_{SCMAX}	31
Annex C (normative) Simplified risk assessment based on EN 62305-2	32
Bibliography	34

Figures

Figure 1 – Current branches vs. modes of protection of an SPD.....	9
Figure 2 – Installation of SPDs in case of PV installation without external LPS	10
Figure 3 – Installation of SPDs in case of a building with external LPS when separation distance s is kept	11
Figure 4 – Installation of SPDs in case of a building with external LPS when separation distance s is kept – Installation with data acquisition and control system.....	12
Figure 5 – Installation of SPDs in case of PV installation with external LPS when separation distance s is not kept.....	13
Figure 6 – Building with external LPS: Dimensions of all equipotential bonding conductors are 6 mm^2 except the one indicated in the figure (earthing of the SPD Type 1 located at the origin of installation).....	14
Figure 7 – Building with external LPS: Dimensions of equipotential bonding conductors in case of a non-isolated LPS	15
Figure 8 – Installation of SPDs on the a.c.-side and short distance between origin of installation and PV-inverter ($E < 10 \text{ m}$).....	17
Figure 9 – Installation of SPDs on the a.c.-side and long distance between origin of installation and PV-inverter ($E > 10 \text{ m}$).....	17
Figure 10 – Example of an overvoltage protection on d.c. side of a PV installation	19
Figure 11 – I-configuration.....	21
Figure 12 – U-configuration	21
Figure 13 – L-configuration.....	21
Figure 14 – Δ -configuration	21
Figure 15 – Y-configuration	22
Figure 16 – Single mode SPDs to be connected in Y-configuration	22
Figure A.1 – Example of a structure with two external down conductors to determine the value of the discharge current for the selection of SPDs	25
Figure A.2 – Example of a structure of an extended PV installation – Free field PV power plant with multiple earthing and a meshed earthing system.....	28
Figure B.1 – Principle of a PV current source	30
Figure B.2 – V/I characteristic of a non-linear PV current source	30
Figure C.1 – L calculation.....	33

Tables

Table 1 – Impulse withstand voltage U_w for equipment between PV generator and inverter	19
Table A.1 – Values of $I_{10/350}$ and $I_{8/20}$ for voltage limiting and combination type SPDs (having voltage switching and limiting components in series)	26
Table A.2 – Values of I_{imp} for voltage switching and combination type SPDs (having voltage switching and limiting components in parallel)	27
Table A.3 – Values of $I_{10/350}$ and $I_{8/20}$ for SPDs intended to be used in free field PV power plant with multiple earthing and a meshed earthing system.....	29
Table C.1 – Calculation of the critical length L_{crit}	32

Foreword

This document (CLC/TS 50539-12:2013) has been prepared by CLC/TC 37A "Low voltage surge protective devices".

This document supersedes CLC/TS 50539-12:2010.

CLC/TS 50539-12:2013 includes the following significant technical changes with respect to CLC/TS 50539-12:2010:

- a) scope and definitions have been revised to align CLC/TS 50539-12 with EN 50539-11;
- b) structure of the document has been revised for better clarification;
- c) only Type 1 d.c. SPDs can be used for cases described in 6.4;
- d) multi-earthed solar systems have been introduced for SPD selection and for current sharing calculation;
- e) Table 1 (impulse withstand) has been introduced;
- f) current sharing in Annex A has been revised;
- g) Annex B has been created;
- h) risk assessment has been introduced in Annex C.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

1 Scope

This Technical Specification describes the principles for selection, location, coordination and operation of SPDs to be connected to PV installations. The d.c. side is rated up to 1 500 V d.c. and the a.c. side, if any, is rated up to 1 000 V rms 50 Hz.

The electrical installation starts from a PV generator or a set of interconnected PV modules with their cables, provided by the PV generator manufacturer, up to the user installation or the utility supply point.

For PV installations including batteries, additional requirements will be necessary.

NOTE 1 HD 60364-7-712, CLC/TS 61643-12 and EN 62305-4 are also applicable.

NOTE 2 This Technical Specification deals only with SPDs, and not with SPDs components integrated inside equipment.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CLC/TS 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles (IEC 61643-12)*

EN 50539-11, *Low-voltage surge protective devices – Surge protective devices for specific application including d.c. – Part 11: Requirements and tests for SPDs in photovoltaic applications*

EN 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests (IEC 60664-1:2007)*

EN 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test (IEC 61000-4-5)*

EN 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – Requirements and tests methods (IEC 61643-1)*

EN 61643-21, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods (IEC 61643-21)*

EN 62305-2:2012, *Protection against lightning – Part 2: Risk management (IEC 62305-2:2010, mod.)*

EN 62305-4, *Protection against lightning – Part 4: Electrical and electronic systems within structures (IEC 62305-4)*

HD 60364-4-443, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances – Clause 443: Protection against overvoltages of atmospheric origin or due to switching (IEC 60364-4-44)*

HD 60364-5-534, *Low-voltage electrical installations – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control – Clause 534: Devices for protection against overvoltages (IEC 60364-5-53)*

ITU-T Recommendation K.20, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*

ITU-T Recommendation K.21, *Resistibility of telecommunication equipment installed in customer premises to overvoltages and overcurrents*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN