

STN	Poplachové systémy. Poplachové prenosové systémy a zariadenia. Časť 2: Požiadavky na prijímač/vysielač chránených priestorov.	STN EN 50136-2 33 4596
------------	--	--

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Obsahuje: EN 50136-2:2013

Oznámením tejto normy sa od 12.08.2016 ruší
STN EN 50136-2-1 (33 4596) zo septembra 2001

STN EN 50136-2-2 (33 4596) zo septembra 2001

STN EN 50136-2-3 (33 4596) zo septembra 2001

STN EN 50136-2-4 (33 4596) zo septembra 2001

119206

EUROPEAN STANDARD
 NORME EUROPÉENNE
 EUROPÄISCHE NORM

EN 50136-2

August 2013

ICS 13.320; 33.040.40

Supersedes EN 50136-2-1:1998 + corr. Apr.1998 + A1:2001, EN 50136-2-2:1998, EN 50136-2-3:1998, EN 50136-2-4:1998

English version

**Alarm systems -
 Alarm transmission systems and equipment -
 Part 2: Requirements for Supervised Premises Transceiver (SPT)**

Systemes d'alarme -
 Systemes et equipements de transmission
 d'alarme -
 Partie 2: Exigences pour les transmetteurs
 des locaux surveilles (SPT)

Alarmanlagen -
 Alarmübertragungsanlagen und -
 einrichtungen -
 Teil 2: Anforderungen an
 Übertragungseinrichtungen (ÜE)

This European Standard was approved by CENELEC on 2013-08-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
 Comité Européen de Normalisation Electrotechnique
 Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Contents

Foreword	4
1 Scope	6
2 Normative references	6
3 Terms, definitions and abbreviations	6
3.1 Terms and definitions	6
3.2 Abbreviations	7
4 General requirements	7
4.1 General	7
4.2 SPT classification	8
5 Functional requirements	8
5.1 General	8
5.2 Access levels	8
5.3 Remote access	9
5.4 Uploading and downloading of software and firmware	9
5.5 Storage of parameters	9
5.6 ATS and ATP fault reporting to the AS	9
5.7 Interface to the AS	9
5.8 Monitoring of the transmission network interface(s) – Fault reporting	10
5.9 Power supply for the SPT	10
5.10 Event logging	10
6 Operation	12
6.1 Modes of acknowledgement operation	12
6.2 SPT alarms	12
6.3 Substitution security	13
6.4 Information security	13
7 Documentation	13
7.1 SPT documentation	13
7.2 Marking and identification	14
8 Housing and tamper protection – Tamper protection requirements	14
9 Tests	14
9.1 General	14
9.2 General requirements	14
9.3 Reduced functional test	15
9.4 Functional tests	15
Annex A (normative) Requirements of the interface between AS and SPT	28
A.1 Parallel interface between AS and SPT	28
A.2 Serial interface between AS and SPT	28
Bibliography	30

Tables

Table 1 — Event recording classification – Events to be recorded	11
Table 2 — Event recording classification – Memory capacity & endurance	11
Table 3 — Alarms originated by the SPT and transmitted to the RCT	13
Table 4 — Summary of functional tests	16
Table 5 — Test of access levels	17
Table 6 — Test of upload and download of software and firmware	18
Table 7 — Test of parameter storage	18
Table 8 — Reporting ATS failure from the SPT to the AS in a Dual path ATS.....	19
Table 9 – Reporting the ATS path failure from the SPT to the AS in a Single path ATS.....	19
Table 10 — Test of standardized serial interface to the AS.....	20
Table 11 — Test of standardized parallel interface to the AS.....	21
Table 12 — Test of proprietary interface to the AS.....	22
Table 13 — Test of the transmission network interface monitoring	22
Table 14 — Test of event logging	23
Table 15 — Test of event log capacity	23
Table 16 — Test of clock resolution	24
Table 17 — Test of store-and-forward operation	25
Table 18 — Test of pass-through operation.....	26

Foreword

This document (EN 50136-2:2013) has been prepared by CLC/TC 79 "Alarm systems".

The following dates are proposed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-08-12
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2016-08-12

This document supersedes EN 50136-2-1:1998+corr.Apr.1998+A1:2001, EN 50136-2-2:1998, EN 50136-2-3:1998 and EN 50136-2-4:1998.

EN 50136-2:2013 includes the following significant technical changes with respect to EN 50136-2-1:1998+corr.Apr.1998+A1:2001, EN 50136-2-2:1998, EN 50136-2-3:1998 and EN 50136-2-4:1998:

- 1) referenced based standards were updated to the latest versions;
- 2) definitions were updated;
- 3) requirements were aligned with new ATS categories of the revised system standard EN 50136-1;
- 4) test methods were added;
- 5) the scope was changed to reflect the amalgamation of EN 50136-2-2:1998, EN 50136-2-3:1998 and EN 50136-2-4:1998 and to achieve compatibility with application specific standards such as fire alarm transmission systems and social alarm transmission systems;
- 6) significant changes were made to the structure of the document to achieve general alarm transmission requirements for SPT. Application specific requirements were removed;
- 7) the title was corrected to match the scope of the document.

This revision was prepared to bring the procedures up-to-date with current technical developments, taking account of changes in the basic standards and the experience gained in the use of the standard.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This European Standard is part of a series. This series is intended to give the requirements applicable to alarm transmission systems in general.

EN 50136 consists of the following parts, under the general title *Alarm systems — Alarm transmission systems and equipment*:

- *Part 1: General requirements for alarm transmission systems*;
- *Part 2: Requirements for Supervised Premises Transceiver (SPT)*;
- *Part 3: Requirements for Receiving Centre Transceiver (RCT)*;
- *Part 4: Annunciation equipment used in alarm receiving centres* (Technical Specification);
- *Part 7: Application guidelines* (Technical Specification);

- *Part 9: Requirements for common protocol for alarm transmission using the Internet protocol (Technical Specification).*

1 Scope

This European Standard specifies the general equipment requirements for the performance, reliability, resilience, security and safety characteristics of supervised premises transceiver (SPT) installed in supervised premises and used in alarm transmission systems (ATS). A supervised premises transceiver can be a stand-alone device or an integrated part of an alarm system.

These requirements also apply to SPT's sharing means of interconnection, control, communication and power supplies with other applications.

The alarm transmission system requirements and classifications are defined within EN 50136-1. Different types of alarm systems may in addition to alarm messages also send other types of messages, e.g. fault messages and status messages. The term alarm is used in this broad sense throughout the document. Additional requirements for the connection of specific types of alarm systems are given in the relevant European Standards.

Because the SPT can be applied in different applications (e.g. I&HAS, fire and social alarm systems), requirements for the SPT, additional to those of this European Standard, may be specified in separate application specific documents.

This European Standard specifies the requirements specific to alarm transmission. Application specific requirements for the connection of the SPT to specific types of alarm systems are given in the EN 50131 (all parts) for I&HAS, and EN 54 (all parts) for fire. For other SPT applications, see the relevant National or European standards.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50130-4, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 50130-5, *Alarm systems — Part 5: Environmental test methods*

EN 50136-1:2012, *Alarm systems — Alarm transmission systems and equipment — Part 1: General requirements for alarm transmission systems*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN