

<b>STN</b>	<b>Skúšky reakcie stavebných výrobkov na oheň. Stavebné výrobky okrem podlahových krytín, vystavené tepelnému pôsobeniu osamelo horiaceho predmetu.</b>	<b>STN EN 13823+A1</b>  92 0213
------------	---	---

Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 05/15

Obsahuje: EN 13823:2010+A1:2014

Oznámením tejto normy sa od 01.09.2016 ruší  
STN EN 13823 (92 0213) zo septembra 2011

**120803**

---

Úrad pre normalizáciu, metrológiu a skúšobníctvo SR, odbor SÚTN, 2015  
Podľa zákona č. 264/1999 Z. z. v znení neskorších predpisov sa môžu slovenské technické normy  
rozmnžovať a rozširovať iba so súhlasom Úradu pre normalizáciu, metrológiu a skúšobníctvo SR.

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 13823:2010+A1**

November 2014

ICS 91.060.01; 13.220.50; 91.100.01

Supersedes EN 13823:2010

English Version

**Reaction to fire tests for building products - Building products  
excluding floorings exposed to the thermal attack by a single  
burning item**

Essais de réaction au feu des produits de construction -  
Produits de construction à l'exclusion des revêtements de  
sol exposés à une sollicitation thermique provoquée par un  
objet isolé en feu

Prüfungen zum Brandverhalten von Bauprodukten -  
Thermische Beanspruchung durch einen einzelnen  
brennenden Gegenstand für Bauprodukte mit Ausnahme  
von Bodenbelägen

This European Standard was approved by CEN on 25 June 2010 and includes Amendment 1 approved by CEN on 9 September 2014.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Contents

Page

Foreword .....	4
Introduction .....	5
1 Scope .....	6
2 Normative references .....	6
3 Terms and definitions .....	6
4 Test facility .....	7
4.1 General .....	7
4.2 Test room .....	7
4.3 Materials .....	10
4.4 Test apparatus .....	10
4.5 Smoke exhaust system .....	12
4.6 General measurement section equipment .....	12
4.7 Other general equipment .....	13
5 Test specimen .....	14
5.1 Dimensions of specimen .....	14
5.2 Mounting of specimen .....	14
5.2.1 Mounting as in end use application .....	14
5.2.2 Standard mounting .....	15
5.3 Installation of the specimen wings in the trolley .....	17
5.4 Number of specimens .....	17
6 Conditioning .....	17
7 Principle .....	18
8 Test procedure .....	18
8.1 General .....	18
8.2 Testing operations .....	18
8.3 Visual observation and manual recording of data .....	19
8.3.1 General .....	19
8.3.2 Pre-test conditions .....	19
8.3.3 Lateral flame spread on the long wing .....	19
8.3.4 Flaming particles or droplets .....	20
8.3.5 End of test conditions .....	21
8.3.6 Recorded events .....	21
8.4 Automated recording of data .....	22
8.5 Early termination of test .....	22
9 Expression of results .....	23
10 Test report .....	23
Annex A (normative) Calculation procedures .....	25
A.1 General .....	25
A.1.1 General remarks .....	25
A.1.2 Calculations to be performed on the test data .....	26
A.1.3 Calculations to be performed on calibration data .....	26
A.1.4 Standard data set .....	26
A.2 Synchronization of data .....	26

<b>A.3</b>	<b>Checking equipment response.....</b>	<b>28</b>
<b>A.3.1</b>	<b>Temperature readings .....</b>	<b>28</b>
<b>A.3.2</b>	<b>Drift in gas concentration measurement .....</b>	<b>28</b>
<b>A.3.3</b>	<b>Drift in light attenuation measurement .....</b>	<b>28</b>
<b>A.4</b>	<b>Exposure period .....</b>	<b>29</b>
<b>A.5</b>	<b>Heat output .....</b>	<b>29</b>
<b>A.5.1</b>	<b>Calculation of heat release rate (<i>HRR</i>).....</b>	<b>29</b>
<b>A.5.2</b>	<b>Calculation of <i>THR</i>(<i>t</i>) and <i>THR</i><sub>600s</sub> .....</b>	<b>32</b>
<b>A.5.3</b>	<b>Calculation of <i>FIGRA</i><sub>0,2MJ</sub> and <i>FIGRA</i><sub>0,4MJ</sub> (fire growth rate indices) .....</b>	<b>32</b>
<b>A.6</b>	<b>Smoke production.....</b>	<b>33</b>
<b>A.6.1</b>	<b>Calculation of smoke production rate (<i>SPR</i>) .....</b>	<b>33</b>
<b>A.6.2</b>	<b>Calculation of <i>TSP</i>(<i>t</i>) and <i>TSP</i><sub>600s</sub> .....</b>	<b>36</b>
<b>A.6.3</b>	<b>Calculation of <i>SMOGRA</i> (smoke growth rate index) .....</b>	<b>37</b>
<b>A.7</b>	<b>Calculations for calibrations – Propane heat release .....</b>	<b>37</b>
<b>Annex B</b>	<b>(informative) Precision of test method .....</b>	<b>39</b>
<b>B.1</b>	<b>General remarks and results .....</b>	<b>39</b>
<b>B.2</b>	<b>Calculation of test results .....</b>	<b>40</b>
<b>B.3</b>	<b>Statistical analysis .....</b>	<b>41</b>
<b>B.4</b>	<b>Statistical results .....</b>	<b>41</b>
<b>Annex C</b>	<b>(normative) Calibration procedures .....</b>	<b>45</b>
<b>C.1</b>	<b>Procedures for separate pieces of equipment.....</b>	<b>45</b>
<b>C.1.1</b>	<b>General.....</b>	<b>45</b>
<b>C.1.2</b>	<b>Oxygen analyser adjustment .....</b>	<b>45</b>
<b>C.1.3</b>	<b>Oxygen analyser output noise and drift .....</b>	<b>45</b>
<b>C.1.4</b>	<b>Carbon dioxide analyser adjustment .....</b>	<b>46</b>
<b>C.1.5</b>	<b>Check of propane mass flow controller.....</b>	<b>46</b>
<b>C.1.6</b>	<b>Light system calibration.....</b>	<b>46</b>
<b>C.2</b>	<b>System response calibrations .....</b>	<b>47</b>
<b>C.2.1</b>	<b>Burner switch response time .....</b>	<b>47</b>
<b>C.2.2</b>	<b>Burner heat output step calibration .....</b>	<b>49</b>
<b>C.2.3</b>	<b>Heptane calibration .....</b>	<b>52</b>
<b>C.2.4</b>	<b>Velocity profile factor <i>k</i><sub>t,v</sub>.....</b>	<b>54</b>
<b>C.2.5</b>	<b>Flow factor <i>k</i><sub>t</sub> .....</b>	<b>56</b>
<b>Annex D</b>	<b>(informative) Calibration procedures .....</b>	<b>57</b>
<b>D.1</b>	<b>Procedures for separate pieces of equipment.....</b>	<b>57</b>
<b>D.1.1</b>	<b>General.....</b>	<b>57</b>
<b>D.1.2</b>	<b>Oxygen analyser adjustment .....</b>	<b>57</b>
<b>D.1.3</b>	<b>Carbon dioxide analyser adjustment .....</b>	<b>57</b>
<b>D.1.4</b>	<b>Check of propane mass flow controller.....</b>	<b>57</b>
<b>D.1.5</b>	<b>Optical filter check .....</b>	<b>58</b>
<b>D.2</b>	<b>Check of the thermal attack on the specimens .....</b>	<b>59</b>
<b>D.2.1</b>	<b>General .....</b>	<b>59</b>
<b>D.2.2</b>	<b>Procedure .....</b>	<b>59</b>
<b>Annex E</b>	<b>(normative) Design drawings.....</b>	<b>60</b>
<b>Annex F</b>	<b>(informative) Data file format.....</b>	<b>95</b>
<b>Annex G</b>	<b>(informative) Record sheet .....</b>	<b>98</b>
<b>Bibliography</b>	<b>.....</b>	<b>99</b>

## Foreword



This document (EN 13823:2010+A1:2014) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2015, and conflicting national standards shall be withdrawn at the latest by August 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 9 September 2014.

This document supersedes  EN 13823:2010 .

The start and finish of text introduced or altered by amendment is indicated in the text by tags  .

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

The classification of the reaction to fire performance of construction products established by EC Decision 2000/147/EC (OJEU L50 of 23.2.2000) defines in Table 1 the reaction to fire classes for building products excluding floorings. The relevant test methods for determining the reaction to fire are being prepared by CEN/TC 127.

### Safety warning

The attention of all persons concerned with managing and carrying out the tests described in this standard is drawn to the fact that fire testing can be hazardous and that toxic and/or harmful smoke and gases can be produced during the test.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Smoke and gases should be removed from the workplace. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

Special precautions are required for the propane gas supply system.

- The equipment, for example tubes, couplings, flow meters, should be approved for propane.
- The burner should be equipped with a remote-controlled ignition device, for example a pilot flame or a glow wire. There should be a warning system for leaking gas and a valve for immediate and automatic cut-off of the gas supply in case of extinction of the ignition flame. The pilot flames can be ignited directly by an operator in the test room, however, no one should be present in the test room during ignition of a burner.
- It should be possible to operate the switch between auxiliary and main (primary) burner and the preceding main valve (to open or stop the propane supply) from outside the test room.

Special precautions are required for the extinction of burning specimens.

When the extinction is carried out because of intensive combustion of the specimens, it is recommended that a second operator is ready to intervene. Means for extinguishing should be available (e.g. since the heat output during intensive combustion can damage the apparatus).

## **1 Scope**

This European Standard specifies a method of test for determining the reaction to fire performance of construction products excluding floorings, and excluding products which are indicated in Table 1 of EC Decision 2000/147/EC, when exposed to thermal attack by a single burning item (SBI). The calculation procedures are given in Annex A. Information on the precision of the test method is given in Annex B. The calibration procedures are given in Annexes C and D, of which C is a normative annex.

**NOTE** This European Standard has been developed to determine the reaction to fire performance of essentially flat products. The treatment of some families of products, e.g. linear products (pipes, ducts, cables etc.), can need special rules.

## **2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13238, *Reaction to fire tests for building products — Conditioning procedures and general rules for selection of substrates*

EN 13501-1:2007+A1:2009, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN 60584-1:1995, *Thermocouples — Part 1: Reference tables (IEC 60584-1:1995)*

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**