

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60079-1

October 2014

ICS 29.260.20

Supersedes EN 60079-1:2007

English Version

**Explosive atmospheres - Part 1: Equipment protection by
flameproof enclosures "d"
(IEC 60079-1:2014)**

Atmosphères explosives - Partie 1: Protection de l'appareil
par enveloppes antidéflagrantes "d"
(CEI 60079-1:2014)

Explosionsgefährdete Bereiche - Teil 1: Geräteschutz
durch druckfeste Kapselung "d"
(IEC 60079-1:2014)

This European Standard was approved by CENELEC on 2014-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 31/1111/FDIS, future edition 7 of IEC 60079-1, prepared by IEC/TC 31 "Equipment for explosive atmospheres" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60079-1:2014.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-05-01
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2017-08-01
standards conflicting with the
document have to be withdrawn

This document supersedes EN 60079-1:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For the relationship with EU Directive see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 60079-1:2014 was approved by CENELEC as a European Standard without any modification.

Annex ZA

(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60061	-	Lamp caps and holders together with gauges for the control of interchangeability and safety	-	-
IEC 60079-0 (mod)	-	Explosive atmospheres - Part 0: Equipment - General requirements	EN 60079-0	-
			+A11	2013
IEC 60079-7	-	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"	EN 60079-7	-
IEC 60079-11	-	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"	EN 60079-11	-
IEC 60079-15	-	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"	EN 60079-15	-
IEC 60127	series	Miniature fuses	EN 60127	series
ISO 965-1	-	ISO general purpose metric screw threads - Tolerances – Part 1: Principles and basic data	-	-
ISO 965-3	-	ISO general purpose metric screw threads - Tolerances – Part 3: Deviations for constructional screw threads	-	-
ISO 2738	-	Sintered metal materials, excluding hardmetals - Permeable sintered metal materials - Determination of density, oil content and open porosity	EN ISO 2738	-
ISO 4003	-	Permeable sintered metal materials - Determination of bubble test pore size	EN 24003	-
ISO 4022	-	Permeable sintered metal materials - Determination of fluid permeability	EN ISO 4022	-
ANSI/ASME B 1.20.1 -			-	-

Annex ZY (informative)

Significant changes between this European Standard and EN 60079-1:2007

This European Standard supersedes EN 60079-1:2007.

The significant changes with respect to EN 60079-1:2007 are as listed below.

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
<i>Normative references</i> (Removal of the edition date from the reference for 60079-0) IEC	2	X		
<i>Requirements for level of protection “da”</i> (Catalytic sensors for combustible gas detectors)	4.2		X	
Requirements for level of protection “dc” (“Enclosed break” devices from IEC 60079-15)	4.4, 15.5	X		
Flameproof joints, General requirements (Documentation clarification and examples of corrosion inhibiting grease)	5.1	X		
Flameproof joints, General requirements (Specific Conditions of Use that joints are not intended to be repaired)	5.1		X	
Flameproof joints, General requirements (Electroplating more than 0.008 mm thick)	5.1		X	
Non-threaded joints, Gap (<i>l</i>) (Intentional gaps between surface for flanged joints)	5.2.2	X		
Serrated joints (Use and test requirements)	5.2.8	X		
Multi-step joints (Not less than 3 adjacent segments and two path changes)	5.2.9		X	
Minimum width of joint and maximum gap for enclosures of groups IIA and IIB (Maximum gaps for flanged, cylindrical or spigot joints of 9,5 mm minimum width and volume greater than 2,000 cm ³)	Table 2		X	
Minimum width of joint and maximum gap for enclosures of groups I, IIA, IIB and IIC (ISO 80000-1 for constructional value rounding)	Table 2, Table 3	X		
Cylindrical threaded joints (ISO 965-1 standard in respect of thread form or quality of fit)	Table 4	X		
Taper threaded joints (External and internal thread construction)	Table 5	X		
Cemented joints (Supplemental mechanical means of securement)	6.1.2			C1
Cemented joints (Evaluation criteria if there is leakage)	6.1.2		X	
Fused glass joints (Glass-to-metal joints)	6.2		X	

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Thermal tests of breathing and draining devices (Temperature class based on external surface temperature after the 10 min test period)	10.9.3.2	X		
Test of the ability of the breathing and draining device to withstand pressure (Relocated from before thermal tests to after the non-transmission test)	10.9.3.4	X		
Ex component certificate (Service temperature range for non-metallic enclosures per IEC 60079-0)	10.9.4	X		
Fasteners and openings (Relocation of blanking element content to Clauses 13.8 and C.2.3)	11	X		
Fasteners and openings, Property class or yield stress (Certificate specific condition of use)	11.3	X		
Fasteners and openings (Openings in the wall of the enclosure)	11.8	X		
Materials (Material limitation in acetylene atmospheres)	12.8			C2
Entries for flameproof enclosures, General (Metric and NPT threaded entries)	13.1	X		
Entries for flameproof enclosures, General (Group I non-threaded joints)	13.1		X	
Entries for flameproof enclosures, Non-threaded holes (Group I application)	13.3		X	
Entries for flameproof enclosures, Cable glands (Group I application)	13.4		X	
Cable glands, Conduit sealing devices (Documentation to facilitate mounting)	13.4,13.5	X		
Plugs and sockets and cable couplers (Load requirement for arc-quenching test)	13.6.4			C3
Bushings (Documentation to facilitate mounting)	13.7	X		
Blanking elements (Relocated from Clause 11)	13.8	X		
Verification and tests (Maximum surface temperature conditions)	Table 6	X		
Type tests (Sequence and number of samples for tests)	15	X		
Determination of explosion pressure, General (Devices that can cause turbulence)	15.2.2.2	X		
Determination of explosion pressure, General (Number of tests for Group IIC)	15.2.2.2	X		
Determination of explosion pressure, General (Pressure pilling for Group IIB)	15.2.2.4	X		
Determination of explosion pressure, General (Equipment marked for a single gas)	15.2.2.5	X		
Overpressure test, General (Low ambient overpressure tests not required)	15.2.3	X		

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Overpressure test – First method (static) (3 times option when routine batch testing)	15.2.3.2		X	
Overpressure test – First method (static) (Adjustment for low ambient due to small size of equipment)	15.2.3.2		X	
Overpressure test – Second method (dynamic) (Number of tests to be made)	15.2.3.3	X		
Test for non-transmission of an internal ignition (Clarification regarding grease)	15.3	X		
Reduction in length of a threaded joint for non-transmission test (ISO 965-1 and 965-3 standards in respect of thread form and quality of fit)	Table 9	X		
Test factors to increase pressure or test gap (Group IIC adjustments for elevated ambients)	Table 10	X		
Test for non-transmission of an internal ignition, Groups I, IIA and IIB (Number of tests to be made)	15.3.2.3	X		
Test for non-transmission of an internal ignition, Group IIC testing by increased gap (Number of tests to be made)	15.3.3.2	X		
Test for non-transmission of an internal ignition, Group IIC (Oxygen enrichment of test gases)	15.3.3.4		X	
Thermal tests of enclosures with breathing and draining devices (Temperature class based on external surface temperature after the 10 min test period)	15.4.3.1	X		
Tests for “dc” devices (“Enclosed break” devices from IEC 60079-15)	15.5		X	
Routine tests, General (Adjustment for low ambient due to small size of equipment)	16.1.2		X	
Routine tests, General (Options when second method is chosen)	16.1.3	X		
Routine tests, General (Welded joint inspection options)	16.3		X	
Routine tests, General (Allowance for batch testing)	16.6		X	
Switchgear for Group I (Clarifying need for compliance with EPL Mb types of protection)	17.2.2, 17.2.3	X		
Non-metallic enclosures and non-metallic parts of enclosures, General (Exception for cemented joints)	19.1	X		
Non-metallic enclosures and non-metallic parts of enclosures, Resistance to tracking and creepage distances (Reference to both IEC 60079-7 and or IEC 60079-15)	19.2		X	
Non-metallic enclosures and non-metallic parts of enclosures, Requirements for type tests (Clarification of test sequence)	19.3	X		

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Instructions (Indication that repair of flamepaths is not intended)	21		X	
Bushings (Documentation regarding numbers of cores)	C.2.1.4	X		
Bushings (Criteria for non-transmission test)	C.2.1.4	X		
Bushings (Evaluation criteria if there is leakage)	C.2.1.4		X	
Flameproof joints, Threaded joints (Requirement options)	C.2.2.1	X		
Flameproof joints, Non-threaded joints (Group I application)	C.2.2.2		X	
Constructional requirements for Ex blanking elements (Relocated from Clause 11)	C.2.3.1	X		
Constructional requirements for Ex blanking elements (Metric and NPT Ex blanking elements)	C.2.3.2, C.2.3.3	X		
Constructional requirements for Ex blanking elements (Group I non-threaded construction)	C.2.3.4		X	
Sealing test, General (Allowance for re-tightening)	C.3.1.1	X		
Cable glands and conduit sealing devices with sealing ring (Mandrel to be corrosion-resistant metal)	C.3.1.2	X		
Type tests for Ex blanking elements, Torque test (Test-block to be steel)	C.3.3.1	X		
Tightening torque values (Addition of < 16 mm thread size)	Table C.1		X	
Tightening torque values (Addition of NPT thread sizes)	Table C.2		X	
Ex component enclosure requirements (Markings content)	D.3.8			C4
Ex component enclosure requirements (Certificate content)	D.3.10		X	
Utilization of an Ex component enclosure certificate to prepare an equipment certificate, Procedure (Devices that can create significant turbulence)	D.4.1		X	
Acceptable primary cells (Addition of Type B cells)	Table E.1		X	
Acceptable primary cells (Removal of Type T cells)	Table E.1			C5
Acceptable secondary cells (Addition of Lithium type cells)	Table E.2		X	
Prevention of excessive temperature and cell damage (Application of IEC 60079-11 requirement)	E.4.1.2	X		
Prevention of inadvertent charging of a battery by other voltage sources in the enclosure (Construction not requiring additional protection)	E.4.3		X	

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Recharging of secondary cells inside flameproof enclosures (Additional battery options)	E.5.1		X	
Introduction of an alternative risk assessment method encompassing equipment protection levels' for Ex equipment (Removal of previous Informative Annex)	Annex G	X		
Additional requirements for Flameproof enclosures with an internal source of release (containment system) (Addition of new Normative Annex)	Annex G		X	
Requirements for machines with flameproof "d" enclosures fed from converters (Addition of new Normative Annex)	Annex H		X	

Explanation of the Types of Significant Changes:

A) Definitions

1. Minor and editorial changes:

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2. Extension:

Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3. Major technical changes:


- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

Note These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major technical changes'

C1 – Supplemental mechanical means of securing the cemented joint shall not be defeated by the opening of doors or covers that are intended to be opened during installation or maintenance. For example, in the images below for a luminaire incorporating a cemented joint between the lens and the enclosure cover, the construction shown in the second image would be in accordance with this requirement, while the construction shown in the first image would not.



C2 – Addition of material limitations of enclosures of equipment and enclosures of Ex components for external mounting, if constructed of copper or copper alloys, when used in explosive gas atmospheres containing acetylene (12.8).

C3 – Addition of power factor requirement for evaluating the ability of a plug and socket to remain flameproof during the arc-quenching period while opening a test circuit (13.6.4).

C4 – Addition of marking requirements for Ex component enclosures, in addition to the requirements for marking of Ex components given in IEC 60079-0 (D.3.8).

C5 – Removal of Type T cells as acceptable primary cells (Table E.1).

Annex ZZ

(informative)

Coverage of Essential Requirements of EC Directives

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers only the following essential requirements out of those given in Annex II of the EC Directive 94/9/EC:

- ER 1.0.1, ER 1.0.2 (partly), ER 1.0.3, ER 1.0.4 (partly), ER 1.0.5, ER 1.0.6
- ER 1.1
- ER 1.2.1 (partly), ER 1.2.2 (partly), ER 1.2.3, ER 1.2.6, ER 1.2.7, ER 1.2.8, ER 1.2.9
- ER 1.3.1, ER 1.3.4
- ER 1.4
- ER 1.5
- ER 1.6.4
- ER 2.0
- ER 2.1
- ER 2.2.1
- ER 2.3

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directive[s] concerned.

WARNING: Other requirements and other EC Directives may be applicable to the products falling within the scope of this standard.



IEC 60079-1

Edition 7.0 2014-06

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Explosive atmospheres –
Part 1: Equipment protection by flameproof enclosures “d”**

**Atmosphères explosives –
Partie 1: Protection du matériel par enveloppes antidéflagrantes «d»**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
 3, rue de Varembe
 CH-1211 Geneva 20
 Switzerland

Tel.: +41 22 919 02 11
 Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 60079-1

Edition 7.0 2014-06

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Explosive atmospheres –
Part 1: Equipment protection by flameproof enclosures “d”**

**Atmosphères explosives –
Partie 1: Protection du matériel par enveloppes antidéflagrantes «d»**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XD

ICS 29.260.20

ISBN 978-2-8322-1663-7

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	8
1 Scope.....	16
2 Normative references	16
3 Terms and definitions	17
4 Level of protection (equipment protection level, EPL)	19
4.1 General.....	19
4.2 Requirements for level of protection “da”	19
4.3 Requirements for level of protection “db”	20
4.4 Requirements for level of protection “dc”.....	20
4.4.1 General	20
4.4.2 Construction of “dc” devices	20
4.4.3 Tests for “dc” devices	20
5 Flameproof joints.....	21
5.1 General requirements	21
5.2 Non-threaded joints	22
5.2.1 Width of joints (<i>L</i>)	22
5.2.2 Gap (<i>i</i>).....	22
5.2.3 Spigot joints.....	22
5.2.4 Holes in joint surfaces	23
5.2.5 Conical joints.....	25
5.2.6 Joints with partial cylindrical surfaces (not permitted for Group IIC)	25
5.2.7 Flanged joints for acetylene atmospheres	26
5.2.8 Serrated joints	26
5.2.9 Multi-step joints	27
5.3 Threaded joints	30
5.4 Gaskets (including O-rings).....	30
5.5 Equipment using capillaries	32
6 Sealed joints.....	32
6.1 Cemented joints	32
6.1.1 General	32
6.1.2 Mechanical strength.....	32
6.1.3 Width of cemented joints	33
6.2 Fused glass joints	33
6.2.1 General	33
6.2.2 Width of fused glass joints	33
7 Operating rods.....	33
8 Supplementary requirements for shafts and bearings.....	34
8.1 Joints of shafts	34
8.1.1 General	34
8.1.2 Cylindrical joints	34
8.1.3 Labyrinth joints	34
8.1.4 Joints with floating glands.....	34
8.2 Bearings	36
8.2.1 Sleeve bearings.....	36
8.2.2 Rolling-element bearings	36

9	Light-transmitting parts	36
10	Breathing and draining devices which form part of a flameproof enclosure	37
10.1	General.....	37
10.2	Openings for breathing or draining	37
10.3	Composition limits.....	37
10.4	Dimensions	37
10.5	Elements with measurable paths.....	37
10.6	Elements with non-measurable paths	37
10.7	Removable devices	38
10.7.1	General	38
10.7.2	Mounting arrangements of the elements	38
10.8	Mechanical strength.....	38
10.9	Breathing devices and draining devices when used as Ex components	38
10.9.1	General	38
10.9.2	Mounting arrangements of the elements and components.....	38
10.9.3	Type tests for breathing and draining devices used as Ex components	38
10.9.4	Ex component certificate	41
11	Fasteners and openings	42
12	Materials	43
13	Entries for flameproof enclosures	44
13.1	General.....	44
13.2	Threaded holes	44
13.3	Non-threaded holes (for Group I only)	44
13.4	Cable glands.....	45
13.5	Conduit sealing devices	45
13.6	Plugs and sockets and cable couplers	46
13.7	Bushings.....	47
13.8	Blanking elements.....	47
14	Verification and tests	47
15	Type tests	48
15.1	General.....	48
15.2	Tests of ability of the enclosure to withstand pressure	49
15.2.1	General	49
15.2.2	Determination of explosion pressure (reference pressure)	49
15.2.3	Overpressure test.....	52
15.3	Test for non-transmission of an internal ignition	53
15.3.1	General	53
15.3.2	Electrical equipment of Groups I, IIA and IIB.....	55
15.3.3	Electrical equipment of Group IIC	56
15.4	Tests of flameproof enclosures with breathing and draining devices	57
15.4.1	General	57
15.4.2	Tests of ability of the enclosure to withstand pressure	57
15.4.3	Thermal tests.....	58
15.4.4	Test for non-transmission of an internal ignition.....	58
15.5	Tests for “dc” devices	59
15.5.1	General	59
15.5.2	Preparation of “dc” samples.....	59
15.5.3	Test conditions for “dc” devices	59

16	Routine tests	60
16.1	General.....	60
16.2	Enclosures not incorporating a welded construction	61
16.3	Enclosures incorporating a welded construction	61
16.4	Bushings not specific to one flameproof enclosure	61
16.5	Acceptance criteria	61
16.6	Batch testing	61
17	Switchgear for Group I.....	62
17.1	General.....	62
17.2	Means of isolation.....	62
17.2.1	General	62
17.3	Doors or covers	62
17.3.1	Quick-acting doors or covers	62
17.3.2	Doors or covers fixed by screws	62
17.3.3	Threaded doors or covers	63
18	Lampholders and lamp caps	63
18.1	General.....	63
18.2	Device preventing lamps working loose.....	63
18.3	Holders and caps for lamps with cylindrical caps.....	63
18.4	Holders for lamps with threaded caps	63
19	Non-metallic enclosures and non-metallic parts of enclosures	63
19.1	General.....	63
19.2	Resistance to tracking and creepage distances on internal surfaces of the enclosure walls	64
19.3	Requirements for type tests	64
19.4	Test of erosion by flame.....	64
20	Marking	64
20.1	General.....	64
20.2	Caution and warning markings	65
20.3	Informative markings.....	65
21	Instructions.....	65
Annex A (normative) Additional requirements for crimped ribbon elements and multiple screen elements of breathing and draining devices		66
Annex B (normative) Additional requirements for elements, with non-measurable paths of breathing and draining devices		67
B.1	Sintered metal elements	67
B.2	Pressed metal wire elements	67
B.3	Metal foam elements.....	68
Annex C (normative) Additional requirements for flameproof entry devices		69
C.1	General.....	69
C.2	Constructional requirements	69
C.2.1	Sealing methods.....	69
C.2.2	Flameproof joints.....	70
C.2.3	Constructional requirements for Ex blanking elements	71
C.2.4	Constructional requirements for Ex thread adapters.....	73
C.3	Type tests	73
C.3.1	Sealing test	73
C.3.2	Test of mechanical strength.....	74

C.3.3	Type tests for Ex blanking elements	75
C.3.4	Type tests for Ex thread adapters	76
Annex D (normative)	Empty flameproof enclosures as Ex components.....	78
D.1	General.....	78
D.2	Introductory remarks	78
D.3	Ex component enclosure requirements.....	78
D.4	Utilization of an Ex component enclosure certificate to prepare an equipment certificate	80
D.4.1	Procedure.....	80
D.4.2	Application of the schedule of limitations	80
Annex E (normative)	Cells and batteries used in flameproof “d” enclosures	81
E.1	Introductory remarks	81
E.2	Acceptable electrochemical systems	81
E.3	General requirements for cells (or batteries) inside flameproof enclosures	82
E.4	Arrangement of safety devices	82
E.4.1	Prevention of excessive temperature and cell damage.....	82
E.4.2	Prevention of cell polarity reversal or reverse charging by another cell in the same battery	83
E.4.3	Prevention of inadvertent charging of a battery by other voltage sources in the enclosure	83
E.5	Recharging of secondary cells inside flameproof enclosures	84
E.6	Rating of protection diodes and reliability of protection devices.....	85
Annex F (informative)	Mechanical properties for screws and nuts	86
Annex G (normative)	Additional requirements for flameproof enclosures with an internal source of release (containment system)	87
G.1	General.....	87
G.2	Release conditions.....	87
G.2.1	No release	87
G.2.2	Limited release of a gas or vapour	88
G.2.3	Limited release of a liquid	88
G.3	Design requirements for the containment system	88
G.3.1	General design requirements	88
G.3.2	Infallible containment system.....	88
G.3.3	Containment system with a limited release	89
G.4	Type tests for the containment system	89
G.4.1	Overpressure test	89
G.4.2	Leakage test for an infallible containment system	89
G.4.3	Leakage test for a containment system with a limited release	90
Annex H (normative)	Requirements for machines with flameproof “d” enclosures fed from converters.....	91
H.1	General.....	91
H.2	Construction requirements for bearings.....	91
H.3	Temperature requirements	91
Bibliography		92
Figure 1 – Example of construction for indirect checking of a flanged Group I flameproof joint.....		22
Figure 2 – Spigot joints		23
Figure 3 – Holes in surfaces of flanged joints, example 1		24

Figure 4 – Holes in surfaces of flanged joints, example 2	24
Figure 5 – Holes in surfaces of flanged joints, example 3	24
Figure 6 – Holes in surfaces of spigot joints, example 1	24
Figure 7 – Holes in surfaces of spigot joints, example 2	25
Figure 8 – Holes in surfaces of spigot joints, example 3	25
Figure 9 – Examples of joint constructions	26
Figure 10 – Illustration of the requirements concerning gaskets – Example 1	31
Figure 11 – Illustration of the requirements concerning gaskets – Example 2	31
Figure 12 – Illustration of the requirements concerning gaskets – Example 3	31
Figure 13 – Illustration of the requirements concerning gaskets – Example 4	31
Figure 14 – Illustration of the requirements concerning gaskets – Example 5	31
Figure 15 – Illustration of the requirements concerning gaskets – Example 6	31
Figure 16 – Illustration of the requirements concerning gaskets – Example 7	32
Figure 17 – Example of cylindrical joint for shaft of rotating electrical machine	35
Figure 18 – Example of labyrinth joint for shaft of rotating electrical machine	35
Figure 19 – Example of joint with floating gland for shaft of rotating electrical machine	35
Figure 20 – Joints of shaft glands of rotating electrical machines	36
Figure 21 – Component test rig for breathing and draining devices	39
Figure 22 – Example of possible documentation	45
Figure 23 – Example of a regular shaped waveform	51
Figure 24 – Example of an irregular shaped waveform	51
Figure C.1 – Examples of blanking elements for unused entries	72
Figure C.2 – Device for the sealing tests for cable glands	74
Figure C.3 – Examples of Ex thread adapters	77
Figure E.1 – Fitting of diode arrangement for three cells in series	83
Figure E.2 – Fitting of blocking diodes to meet E.4.3 (third example)	84
Figure G.1 – Flameproof enclosure with containment system	87
Table 1 – Number of non-transmission tests for level of protection “da”	20
Table 2 – Minimum width of joint and maximum gap for enclosures of Groups I, IIA and IIB	28
Table 3 – Minimum width of joint and maximum gap for Group IIC enclosures	29
Table 4 – Cylindrical threaded joints	30
Table 5 – Taper threaded joints ^a , ^c	30
Table 6 – Conditions for the determination of maximum surface temperature	48
Table 7 – Test factors for reduced ambient conditions	50
Table 8 – Relative pressures for small equipment	52
Table 9 – Reduction in length of a threaded joint for non-transmission test	54
Table 10 – Test factors to increase pressure or test gap (i_E)	54
Table 11 – Minimum distance of obstructions from flameproof “d” flange openings	54
Table 12 – Gas/air mixtures	55
Table 13 – Static pressures	60
Table 14 – Text of caution or warning markings	65

Table 15 – Text of informative markings.....	65
Table C.1 – Tightening torque values, metric	76
Table C.2 – Tightening torque values, NPT.....	77
Table E.1 – Acceptable primary cells	81
Table E.2 – Acceptable secondary cells.....	82
Table F.1 – Mechanical properties for screws and nuts	86

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 1: Equipment protection by flameproof enclosures “d”**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-1 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This seventh edition cancels and replaces the sixth edition, published in 2007, and constitutes a technical revision.

The significance of the changes between IEC 60079-1, Edition 7.0 (2014) and IEC 60079-1 Edition 6.0 (2007) (including Corrigendum 1 (2008)), is as listed below:

		Type		
Explanation of the significance of the changes	Clause	Minor and editorial changes	Extension	Major technical changes
Normative references (Removal of the edition date from the reference for IEC 60079-0)	2	X		
Requirements for level of protection “da” (Catalytic sensors of portable combustible gas detectors)	4.2		X	
Requirements for level of protection “dc” (“Enclosed break” devices from IEC 60079-15)	4.4, 15.5	X		
Flameproof joints, General requirements (Documentation clarification and examples of corrosion inhibiting grease)	5.1	X		
Flameproof joints, General requirements (Specific Conditions of Use that joints are not intended to be repaired)	5.1		X	
Flameproof joints, General requirements (Electroplating more than 0,008 mm thick)	5.1		X	
Non-threaded joints, Gap (<i>i</i>) (Intentional gaps between surface for flanged joints)	5.2.2	X		
Serrated joints (Use and test requirements)	5.2.8	X		
Multi-step joints (Not less than 3 adjacent segments and two path changes)	5.2.9		X	
Minimum width of joint and maximum gap for enclosures of groups IIA and IIB (Maximum gaps for flanged, cylindrical or spigot joints of 9,5 mm minimum width and volume greater than 2 000 cm ³)	Table 2		X	
Minimum width of joint and maximum gap for enclosures of groups I, IIA, IIB and IIC (ISO 80000-1 for constructional value rounding)	Table 2, Table 3	X		
Cylindrical threaded joints (ISO 965-1 standard in respect of thread form or quality of fit)	Table 4	X		
Taper threaded joints (External and internal thread construction)	Table 5	X		
Cemented joints (Supplemental mechanical means of securement)	6.1.2			C1
Cemented joints (Evaluation criteria if there is leakage)	6.1.2		X	
Fused glass joints (Glass-to-metal joints)	6.2		X	
Thermal tests of breathing and draining devices (Temperature class based on external surface temperature after the 10 min test period)	10.9.3.2	X		
Test of the ability of the breathing and draining device to withstand pressure (Relocated from before thermal tests to after the non-transmission test)	10.9.3.4	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Ex component certificate (Service temperature range for non-metallic enclosures per IEC 60079-0)	10.9.4	X		
Fasteners and openings (Relocation of blanking element content to 13.8 and C.2.3)	11	X		
Fasteners and openings, Property class or yield stress (Certificate specific condition of use)	11.3	X		
Fasteners and openings (Openings in the wall of the enclosure)	11.8	X		
Materials (Material limitation in acetylene atmospheres)	12.8			C2
Entries for flameproof enclosures, General (Metric and NPT threaded entries)	13.1	X		
Entries for flameproof enclosures, General (Group I non-threaded joints)	13.1		X	
Entries for flameproof enclosures, Non-threaded holes (Group I application)	13.3		X	
Entries for flameproof enclosures, Cable glands (Group I application)	13.4		X	
Cable glands, Conduit sealing devices (Documentation to facilitate mounting)	13.4,13.5	X		
Plugs and sockets and cable couplers (Load requirement for arc-quenching test)	13.6.4			C3
Bushings (Documentation to facilitate mounting)	13.7	X		
Blanking elements (Relocated from Clause 11)	13.8	X		
Verification and tests (Maximum surface temperature conditions)	Table 6	X		
Type tests (Sequence and number of samples for tests)	15	X		
Determination of explosion pressure, General (Devices that can cause turbulence)	15.2.2.2	X		
Determination of explosion pressure, General (Number of tests for Group IIC)	15.2.2.2	X		
Determination of explosion pressure, General (Pressure pilling for Group IIB)	15.2.2.4	X		
Determination of explosion pressure, General (Equipment marked for a single gas)	15.2.2.5	X		
Overpressure test, General (Low ambient overpressure tests not required)	15.2.3	X		
Overpressure test – First method (static) (3 times option when routine batch testing)	15.2.3.2		X	

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Overpressure test – First method (static) <i>(Adjustment for low ambient due to small size of equipment)</i>	15.2.3.2		X	
Overpressure test – Second method (dynamic) <i>(Number of tests to be made)</i>	15.2.3.3	X		
Test for non-transmission of an internal ignition <i>(Clarification regarding grease)</i>	15.3	X		
Reduction in length of a threaded joint for non-transmission test <i>(ISO 965-1 and 965-3 standards in respect of thread form and quality of fit)</i>	Table 9	X		
Test factors to increase pressure or test gap <i>(Group IIC adjustments for elevated ambients)</i>	Table 10	X		
Test for non-transmission of an internal ignition, Groups I, IIA and IIB <i>(Number of tests to be made)</i>	15.3.2.3	X		
Test for non-transmission of an internal ignition, Group IIC testing by increased gap <i>(Number of tests to be made)</i>	15.3.3.2	X		
Test for non-transmission of an internal ignition, Group IIC <i>(Oxygen enrichment of test gases)</i>	15.3.3.4		X	
Thermal tests of enclosures with breathing and draining devices <i>(Temperature class based on external surface temperature after the 10 min test period)</i>	15.4.3.1	X		
Tests for “dc” devices <i>(“Enclosed break” devices from IEC 60079-15)</i>	15.5		X	
Routine tests, General <i>(Adjustment for low ambient due to small size of equipment)</i>	16.1.2		X	
Routine tests, General <i>(Options when second method is chosen)</i>	16.1.3	X		
Routine tests, General <i>(Welded joint inspection options)</i>	16.3		X	
Routine tests, General <i>(Allowance for batch testing)</i>	16.6		X	
Switchgear for Group I <i>(Clarifying need for compliance with EPL Mb types of protection)</i>	17.2.2, 17.2.3	X		
Non-metallic enclosures and non-metallic parts of enclosures, General <i>(Exception for cemented joints)</i>	19.1	X		
Non-metallic enclosures and non-metallic parts of enclosures, Resistance to tracking and creepage distances <i>(Reference to both IEC 60079-7 and or IEC 60079-15)</i>	19.2		X	
Non-metallic enclosures and non-metallic parts of enclosures, Requirements for type tests <i>(Clarification of test sequence)</i>	19.3	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Instructions (Indication that repair of flamepaths is not intended)	21		X	
Bushings (Documentation regarding numbers of cores)	C.2.1.4	X		
Bushings (Criteria for non-transmission test)	C.2.1.4	X		
Bushings (Evaluation criteria if there is leakage)	C.2.1.4		X	
Flameproof joints, Threaded joints (Requirement options)	C.2.2.1	X		
Flameproof joints, Non-threaded joints (Group I application)	C.2.2.2		X	
Constructional requirements for Ex blanking elements (Relocated from Clause 11)	C.2.3.1	X		
Constructional requirements for Ex blanking elements (Metric and NPT Ex blanking elements)	C.2.3.2, C.2.3.3	X		
Constructional requirements for Ex blanking elements (Group I non-threaded construction)	C.2.3.4		X	
Sealing test, General (Allowance for re-tightening)	C.3.1.1	X		
Cable glands and conduit sealing devices with sealing ring (Mandrel to be corrosion-resistant metal)	C.3.1.2	X		
Type tests for Ex blanking elements, Torque test (Test-block to be steel)	C.3.3.1	X		
Tightening torque values (Addition of < 16 mm thread size)	Table C.1		X	
Tightening torque values (Addition of NPT thread sizes)	Table C.2		X	
Ex component enclosure requirements (Markings content)	D.3.8			C4
Ex component enclosure requirements (Certificate content)	D.3.10		X	
Utilization of an Ex component enclosure certificate to prepare an equipment certificate, Procedure (Devices that can create significant turbulence)	D.4.1		X	
Acceptable primary cells (Addition of Type B cells)	Table E.1		X	
Acceptable primary cells (Removal of Type T cells)	Table E.1			C5
Acceptable secondary cells (Addition of Lithium type cells)	Table E.2		X	
Prevention of excessive temperature and cell damage (Application of IEC 60079-11 requirement)	E.4.1.2	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Prevention of inadvertent charging of a battery by other voltage sources in the enclosure (Construction not requiring additional protection)	E.4.3		X	
Recharging of secondary cells inside flameproof enclosures (Additional battery options)	E.5.1		X	
Introduction of an alternative risk assessment method encompassing equipment protection levels' for Ex equipment (Removal of previous Informative Annex)	Annex G	X		
Additional requirements for Flameproof enclosures with an internal source of release (containment system) (Addition of new Normative Annex)	Annex G		X	
Requirements for machines with flameproof "d" enclosures fed from converters (Addition of new Normative Annex)	Annex H		X	

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance can be found by referring to the Redline Version of the standard.

Explanations:

A) Definitions

Minor and editorial changes

Clarification
decrease of technical requirements
minor technical change
editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension

addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

Major technical changes

addition of technical requirements
increase of technical requirements


These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major Technical Changes'

C1 – Supplemental mechanical means of securing the cemented joint shall not be defeated by the opening of doors or covers that are intended to be opened during

installation or maintenance. For example, in the images below for a luminaire incorporating a cemented joint between the lens and the enclosure cover, the construction shown in the second image would be in accordance with this requirement, while the construction shown in the first image would not.



IEC 1932/14

- C2 – Addition of material limitations of enclosures of equipment and enclosures of Ex components for external mounting, if constructed of copper or copper alloys, when used in explosive gas atmospheres containing acetylene (12.8).
- C3 – Addition of power factor requirement for evaluating the ability of a plug and socket to remain flameproof during the arc-quenching period while opening a test circuit (13.6.4).
- C4 – Addition of marking requirements for Ex component enclosures, in addition to the requirements for marking of Ex components given in IEC 60079-0 (D.3.8).
- C5 – Removal of Type T cells as acceptable primary cells (Table E.1).

The text of this standard is based on the following documents:

FDIS	Report on voting
31/1111/FDIS	31/1125/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

EXPLOSIVE ATMOSPHERES –

Part 1: Equipment protection by flameproof enclosures “d”

1 Scope

This part of IEC 60079 contains specific requirements for the construction and testing of electrical equipment with the type of protection flameproof enclosure “d”, intended for use in explosive gas atmospheres.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard will take precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60061 (all parts), *Lamp caps and holders together with gauges for the control of interchangeability and safety*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety “e”*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection “n”*

IEC 60127 (all parts), *Miniature fuses*

ISO 965-1, *ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*

ISO 965-3, *ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads*

ISO 2738, *Sintered metal materials, excluding hardmetals – Permeable sintered metal materials – Determination of density, oil content and open porosity*

ISO 4003, *Permeable sintered metal materials – Determination of bubble test pore size*

ISO 4022, *Permeable sintered metal materials – Determination of fluid permeability*

ANSI/ASME B1.20.1, *Pipe threads, general purpose (inch)*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN