

STN	Výkonové transformátory. Časť 19: Pravidlá na určovanie neistôt merania strát výkonových transformátorov a tlmiviek.	STN EN 60076-19 35 1100
------------	---	---

Power transformers - Part 19: Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 02/16

Obsahuje: EN 60076-19:2015, IEC/TS 60076-19:2013

122356

Úrad pre normalizáciu, metrológiu a skúšobníctvo SR, 2016
Podľa zákona č. 264/1999 Z. z. v znení neskorších predpisov sa môžu slovenské technické normy rozmnožovať a rozširovať iba so súhlasom Úradu pre normalizáciu, metrológiu a skúšobníctvo SR.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60076-19

August 2015

ICS 29.180

English Version

**Power transformers - Part 19: Rules for the determination of
uncertainties in the measurement of the losses on power
transformers and reactors
(IEC/TS 60076-19:2013 , modified)**

Transformateurs de puissance - Partie 19: Règles pour la
détermination des incertitudes de mesure des pertes des
transformateurs de puissance et bobines d'inductance
(IEC/TS 60076-19:2013 , modifiée)

Leistungstransformatoren - Teil 19: Regeln für die
Bestimmung von Unsicherheiten in der Messung der
Verluste von Leistungstransformatoren und Drosselspulen
(IEC/TS 60076-19:2013 , modifiziert)

This European Standard was approved by CENELEC on 2015-06-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

EN 60076-19:2015 (E)

Foreword

This document (EN 60076-19:2015) consists of the text of IEC/TS 60079:2013 prepared by IEC/TC 14 "Power transformers", together with the common modifications prepared by CLC/TC 14 "Power transformers".

The following dates are fixed:

- latest date by which this document has to be (dop) 2016-06-25
implemented
at national level by publication of an identical
national standard or by endorsement
- latest date by which the national standards (dow) 2018-06-25
conflicting with this document
have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC/TS 60079:2013 was approved by CENELEC as a European Standard with agreed common modifications.

COMMON MODIFICATIONS

Introduction

Modify the first paragraph as follows:

The losses of the transformers (no- load and load losses) are object of guarantee and penalty in the majority of the contracts and play an important role in the evaluation of the total (service) costs and therefore in the investments involved. Furthermore, regional regulations, such as the European Union directive for EcoDesign, may also pose requirements on establishment of reliable values for losses.

Modify the third and fourth paragraphs as follows:

Corrections and uncertainties are also considered in IEC 60076-8 where some general indications are given for their determination.

This European Standard deals with the measurement of the losses that from a measuring point of view consist of the estimate of a measurand and the evaluation of the uncertainty that affects the measurand itself. The procedures can also be applied to loss measurements on power transformers and reactors as evaluation of the achievable performance of a test facility in the course of prequalification processes, as estimations of achievable uncertainty in the enquiry stage of an order or prior to beginning final testing at manufacturer's premises and for evaluations of market surveillance measurements.

Add before the fifth paragraph:

Evaluation of uncertainty in testing is often characterized as "top-down" or "bottom-up", where the first one relies on inter-laboratory comparisons on a circulated test object to estimate the dispersion and hence the uncertainty. The latter method instead relies on the formulation of a model function, where the test result y is expressed as a function of input quantities. This function is often the formula used for the calculation of the result. The "bottom-up" method is applied in this Document.

Replace the sixth paragraph by:

It is recommended that guarantee and penalty calculations should refer to the best estimated values of the losses without considering the measurement uncertainties, based on a shared risk concept, where both parties are aware of and accept the consequences of non-negligible measurement uncertainty.

In cases where the losses are required to conform to stated tolerance limits, it is recommended that the estimated uncertainty is less than the tolerance limit. This situation will occur for example in market surveillance activities. In lieu of other specifications it can be noted that 3 % is often used as estimate for the required uncertainty.

Modify the eighth paragraph as follows:

Standards mentioned in the text but not indispensable are listed at the end of the document.

EN 60076-19:2015 (E)

Replace the last paragraph by:

This European document is based on IEC/TS 60076-19. The technical content of the TS was not changed, but small numerical mistakes and consistent use of symbols in Annex A were corrected. The introduction was modified to enhance clarity.

1 Scope

Modify the first paragraph as follows:

This European Standard illustrates the procedures that should be applied to evaluate the uncertainty affecting the measurements of no-load and load losses during the routine tests on power transformers.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60076-1:2011, *Power transformers – Part 1: General* (IEC 60076-1:2011)

EN 60076-2:2011, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers* (IEC 60076-2:2011)

Annex A (informative)

Example of load loss uncertainty evaluation for a large power transformer

A.4 Model function of the measurand and deviation correction (see 7.2)

A.4.2 Correction of known systematic deviations

Modify the paragraph after the first equation as follows:

The remaining corrective term is given by the following equation: (erroneous K_C replaced by F_D)

Replace the second and the third equations by the following ones:

$$F_D = \frac{1}{1 - (\Delta_{\phi V} - \Delta_{\phi C}) \cdot \tan \varphi}$$

$$P_2 = k_{CN} \cdot k_{VN} \cdot P_W \cdot F_D$$

A.5 Results of the measurements

A.5.1 Load loss measurements

Modify the paragraph after Table A.2 as follows:

The estimate of the phase angle between voltage and current results (see 7.2 and A.6.1):

Replace the first equation by:

$$\varphi = \arccos\left(\frac{P_W}{I_M U_M}\right) - \Delta_{\phi V} + \Delta_{\phi C} = \arccos\left(\frac{6,625}{3,608 \times 86,60}\right) - \left(\frac{0,09}{100} + \frac{0,11}{100}\right) \cdot \frac{180}{\pi} = 88,782 - 0,115 = 88,670^\circ$$

Modify the paragraph after the first equation as follows:

The corresponding $\tan \varphi$ is therefore equal to 43,087.

Replace the second equation by:

$$F_D = \frac{1}{1 - (\Delta_{\phi V} + \Delta_{\phi C}) \cdot \tan \varphi} = \frac{1}{1 - (0,09 / 100 + 0,11 / 100) \cdot 43,087} = 1,0943$$

EN 60076-19:2015 (E)

Replace the third equation by:

$$P_2 = k_{\text{CN}} \cdot k_{\text{VN}} \cdot P_{\text{W}} \cdot F_{\text{D}} = 60 \cdot 200 \cdot 6,625 \cdot 1,0943 = 86\,997 \text{ W}$$

Add after the third equation:

NOTE This result differs slightly from the result obtained with the full formula given in clause A.4.1 because of the simplifications introduced in A.4.2.

A.6 Estimates of the single contributions to the uncertainty budget

A.6.3 Instrument transformer phase displacement uncertainties (see 10.3)

Replace the first, second and third equations by the following ones:

$$u_{\Delta\varphi C} = \frac{0,02}{\sqrt{3}} = 0,011\,5 \text{ crad}$$

$$u_{\Delta\varphi V} = \frac{0,010}{\sqrt{3}} = 0,005\,8 \text{ crad}$$

Add after the second equation:

and

$$u_{\Delta\varphi} = \sqrt{u_{\Delta\varphi V}^2 + u_{\Delta\varphi C}^2} = \sqrt{0,011\,5^2 + 0,005\,8^2} = 0,012\,9$$

NOTE In some cases, in the calibration certificates the uncertainty is directly indicated with a given confidence level and therefore the standard uncertainties can be directly obtained from these data.

A.6.4 Power analyzer uncertainties (see 10.5)

Modify the first paragraph as follows:

According to the manual for the instrument used, the accuracy on power measurement is obtained by the combination of a number of terms:

Modify the third paragraph after the first equation as follows:

The accuracy determined in accordance with the above relation resulted in $\pm 0,91\%$.

Modify the paragraph before the last equation as follows:

According to the manual for the instrument used, the accuracy for voltage measurement is $\pm 0,18\%$, which corresponds to the following standard uncertainty:

A.6.5 Corrective term uncertainty (see 10.3.2)

Modify the first paragraph as follows:

The uncertainty u_{FD} related to the phase displacement correction can be evaluated with the following simplified relations:

Replace the first and the second equations by the following ones:

$$u_{FD} \approx u_{\Delta\varphi} \cdot \tan \varphi$$

EN 60076-19:2015 (E)

$$u_{FD} = 0,0129 \cdot \tan \varphi = 0,0129 \cdot 43,087 = 0,56 \%$$

A.6.6 Uncertainty of the resistance at temperature θ_2 (see 10.8)

Modify the first paragraph as follows:

The standard uncertainty due to the measuring instruments is assumed equal to 0,35 % and that attributable to the winding temperature estimate equal to 2 K, with the latter deemed to be negligible.

A.7 Uncertainty of the load loss measured at ambient temperature (see 7.4)

Modify the first paragraph and Table A.4, fifth row, last cell, as follows:

The uncertainties that affect the load loss at ambient temperature can be estimated using the results of the previous elaborations and are summarized in Table A.4.

Table A.4 – Uncertainty contributions

Quantity	Estimate	Standard uncertainty	Sensitivity coefficient	Uncertainty contribution (%)
CT ratio error	η_C	u_C	1	-
VT ratio error	η_V	u_V	1	-
Power meter	P_W	u_P	1	0,53
Phase displacement	$\frac{1}{1 - (\Delta\varphi_V - \Delta\varphi_C)\tan\varphi}$	u_{FD}	1	0,56
Ampere meter	I_M	u_{IM}	2	0,24

Replace the equation by:

$$u_{P_2} = \sqrt{u_P^2 + u_{FD}^2 + u_{IM}^2} = \sqrt{0,53^2 + 0,56^2 + 0,24^2} = 0,81 \%$$

A.8 Expanded uncertainty of the measured load loss (see 7.4)

Replace the first and second equations by the following ones:

$$U_{P_2} = 2 u_{P_2} = 2 \cdot 0,81 = 1,61 \%$$

$$\dot{U}_{P_2} = \frac{U_{P_2}}{100} P_2 = \frac{1,61}{100} 86,997 = 1,4 \text{ kW}$$

Modify the second paragraph after Equation 2 as follows:

If the uncertainty is given in relative value, the load loss at ambient temperature 24,2 °C is to be expressed as follows:

Replace the third and the fourth equations by the following ones:

$$87,0 \text{ kW} \pm 1,6 \%$$

$$87,0 \text{ kW} \pm 1,4 \text{ kW}$$

Modify the last paragraph as follows:

The result shall be also completed with the indication of the coverage factor, which for the example made was $k = 2$ (confidence level of about 95 %).

A.9 Uncertainty for reported load loss at reference temperature (see 7.5)

Replace the text under A.9 as follows:

The additional loss at ambient temperature is given by:

$$P_{a2} = P_2 - I_N^2 \cdot R_2 = 86\,997 - 69\,500 = 17\,497 \text{ W}$$

The absolute uncertainty of the measured loss and $I_N^2 R$ loss are obtained as follows:

$$\dot{u}_{P2} = \frac{u_{P2}}{100} P_2 = \frac{0,80}{100} 86\,997 = 696 \text{ W} \quad \text{and} \quad \dot{u}_{R2} = \frac{u_{R2}}{100} I_N^2 R_2 = \frac{0,35}{100} 69\,500 = 243 \text{ W}$$

The absolute uncertainty of the additional loss at temperature θ_2 is given by (see Table 3):

$$\dot{u}_{Pa2} = \sqrt{\dot{u}_{P2}^2 + (I_N^2 R_2 \cdot u_{R2})^2} = \sqrt{696^2 + 243^2} = 737 \text{ W}$$

The reported load loss at reference temperature is calculated for copper conductors with $t=235$, reference temperature $\theta_r = 75$ °C and ambient temperature $\theta_2 = 24,2$ °C is given by:

$$\frac{t + \theta_r}{t + \theta_2} = 1,196 \quad \frac{t + \theta_2}{t + \theta_r} = 0,836 \quad I_N^2 R_2 \frac{t + \theta_r}{(t + \theta_2)^2} \cong 0,0046 I_N^2 R_2$$

The reported loss at the reference temperature is thus given by:

$$P_{LL} = 1,196 I_N^2 R_2 + 0,836 P_{a2} = 83\,122 + 14\,627 = 97\,749 \text{ W}$$

The various contributions to the absolute uncertainty are calculated according to Table 4:

EN 60076-19:2015 (E)

$$\text{For } I_N^2 R_2 \text{ loss: } \frac{t + \theta_r}{t + \theta_2} I_N^2 R_2 u_{R2} = 1,196 \cdot 69\,500 \cdot 0,35 / 100 = 291 \text{ W}$$

$$\text{For additional loss: } \frac{t + \theta_2}{t + \theta_r} \dot{u}_{Pa2} = 0,836 \cdot 737 = 616 \text{ W}$$

$$\text{For mean winding temperature: } \frac{t + \theta_r}{(t + \theta_2)^2} I_N^2 R_r u_{\theta2} = 0,004\,6 \times 69\,500 = 320 \text{ W}$$

The combined absolute standard uncertainty is given by:

$$\dot{u}_{LL} = \sqrt{(1,196 I_N^2 R_2 u_{R2})^2 + (0,836 \dot{u}_{Pa2})^2 + (0,004\,6 I_N^2 R_r u_{\theta2})^2} = \sqrt{291^2 + 616^2 + 320^2} = 753 \text{ W}$$

The expanded absolute uncertainty is obtained as:

$$\dot{U}_{LL} = 2 \dot{u}_{LL} = 2 \cdot 0,753 = 1,51 \text{ kW}$$

which corresponds to a coverage probability of approximately 95 %.

The relative standard uncertainty is then:

$$u_{LL} = \frac{\dot{u}_{LL}}{P_{LL}} 100 = \frac{753}{97\,749} 100 = 0,77 \%$$

and the expanded relative uncertainty:

$$U_{LL} = 2 u_{LL} = 2 \times 0,77 \approx 1,5 \%$$

which corresponds to a level of confidence of approximately 95 %.

A.10 Presentation of the results

Modify the second and fourth paragraphs and **replace** the first and second equations as follows:

If the uncertainty is given in relative value, the load loss at reference temperature 75 °C is expressed as follows:

$$97,7 \text{ kW} \pm 1,5 \%$$

$$97,7 \text{ kW} \pm 1,5 \text{ kW}$$

The text shall be also completed with the indication of the coverage factor that for the example made was $k = 2$ (coverage factor of about 95 %).

NOTE The probability that the loss is higher than $(97,7+1,5)$ kW is therefore 2,5 %.

Annex B (Informative)

Example of load loss uncertainty evaluation for a distribution transformer

B.4 Model function of the measurand (see 7.2)

Modify the first paragraph as follows:

The model function for load loss referred to rated current and ambient temperature is the following (considering that no voltage transformer is used):

Replace the first, second, third and the fourth equations by the following ones:

$$P_2 = k_{CN} \left(1 + \frac{\varepsilon_C}{100} \right) \cdot \frac{P_W}{1 + \Delta_{\varphi C} \tan \varphi} \cdot \left[\frac{I_N}{k_{CN} \times I_M} \right]^2$$

$$\varphi = \varphi_M + \Delta_{\varphi C} = \arccos \left(\frac{P_W}{I_M U_M} \right) + \Delta_{\varphi C}$$

$$\frac{1}{1 + \Delta_{\varphi C} \tan \varphi}$$

$$P_2 = k_{CN} \cdot \frac{P_W}{1 + \Delta_{\varphi C} \tan \varphi} \cdot \left[\frac{I_N}{k_{CN} \times I_M} \right]^2$$

B.5 Results of the measurements

Replace the first, second and the third equations as follows:

$$\varphi = \arccos \left(\frac{P_W}{I_M \cdot U_M} \right) + \Delta_{\varphi C} = \arccos \left(\frac{337,5}{4,812 \cdot \sqrt{3} \cdot 365,0} \right) + \frac{0,035}{100} \cdot \frac{180}{\pi} = 83,63 + 0,02 = 83,65^\circ$$

$$F_D = \frac{1}{1 + \Delta_{\varphi C} \tan \varphi} = \frac{1}{1 + \frac{0,035}{100} \cdot 8,99} = 0,997$$

$$P_2 = k_{CN} \cdot P_W \cdot F_D = 40 \cdot 337,5 \cdot 0,997 = 13\,460 \text{ W}$$

B.6 Estimate of the single contributions to the uncertainty formation

Modify the title of B.6.2 as follows:

B.6.2 Power meter (see 10.5)

Replace the first, second and the third equations by the following ones:

$$u_{PW} = \frac{0,57}{\sqrt{3}} = 0,33 \%$$

$$u_{IM} = \frac{0,42}{\sqrt{3}} = 0,24 \%$$

$$u_{UM} = \frac{0,25}{\sqrt{3}} = 0,14 \%$$

B.6.3 Current transformers (see 10.3)

Modify the second paragraph and Table B.3, second row, last cell, as follows:

For the type of transformer under test the values of the ratio error and displacement error given by the calibration certificate can be considered, as indicated in Table B.3. Uncertainty statements have been given as standard uncertainty in the table.

Table B.1 – Calibration of the current transformers

Rated ratio	Accuracy class	Ratio error (%)		Phase displacement (centiradians)	
		ε	u_c	Value	$u_{\Delta\varphi_c}$
200/5	0,1	0,0	0,01	+ 0,035	0,01
NOTE The errors reported in the table are those measured including burden and connections corresponding to the instrument used.					

B.6.4 Corrective term uncertainty (see 10.3.2)

Replace the equation by:

$$u_{FD} \approx \frac{u_{\Delta\varphi_c}}{100} \cdot \tan \varphi \cdot 100 = 0,01 \cdot 8,99 = 0,09 \%$$

EN 60076-19:2015 (E)

B.7 Uncertainty of the load loss measured at ambient temperature (see 7.4)**Modify** Table B.4, third row as follows:**Table B.2 – Uncertainty contribution**

Quantity	Estimate	Standard uncertainty	Sensitivity coefficient	Uncertainty contribution
Power meter	P_W	u_P	1	0,33 %
Phase displacement	$\frac{1}{1 + \Delta_{\varphi C} \tan \varphi}$	u_{FD}	1	0,09 %
Ampere meter	I_M	u_{IM}	2	0,48 %

Modify the second paragraph and **replace** the equation as follows:The combined uncertainty of load loss P_{LL} measured at ambient temperature is given by:

$$u_{LL} = \sqrt{u_P^2 + u_{FD}^2 + u_I^2} = \sqrt{0,33^2 + 0,09^2 + 0,48^2} = 0,59 \%$$

B.8 Expanded uncertainty of the load loss (see 7.4)**Replace** the first and second equations by the following ones:

$$U_{LL} = 2 u_{LL} = 2 \cdot 0,59 = 1,18 \%$$

$$\dot{U}_{LL} = \frac{U_{LL}}{100} P_{LL} = \frac{1,18}{100} 13,5 = 0,16 \text{ kW}$$

Modify the last paragraph as follows:The result shall be also completed with the indication of the coverage factor that for the example made was $k = 2$ (coverage factor of about 95 %).

Bibliography

Replace the bibliography by:

EN 61869-1, *Instrument transformers – Part 1: General requirements* (IEC 61869-1)

EN 61869-2, *Instrument transformers – Part 2: Additional requirements for current transformers* (IEC 61869-2)

EN 61869-3, *Instrument transformers – Part 3: Additional requirements for inductive voltage transformers* (IEC 61869-3)

EN ISO/IEC 17025:2005, *General requirements for the competence of testing and calibration laboratories* (ISO/IEC 17025:2005)

CLC/TR 50462:2008, *Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors*



TECHNICAL SPECIFICATION

SPÉCIFICATION TECHNIQUE

Power transformers –

Part 19: Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors

Transformateurs de puissance –

Partie 19: Règles pour la détermination des incertitudes de mesure des pertes des transformateurs de puissance et bobines d'inductance



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



TECHNICAL SPECIFICATION

SPÉCIFICATION TECHNIQUE

Power transformers –

Part 19: Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors

Transformateurs de puissance –

Partie 19: Règles pour la détermination des incertitudes de mesure des pertes des transformateurs de puissance et bobines d'inductance

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

W

ICS 29.180

ISBN 978-2-83220-693-5

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Symbols	8
4.1 General symbols	8
4.2 Symbols for uncertainty	9
5 Power measurement, systematic deviation and uncertainty	10
5.1 General	10
5.2 Model function.....	10
5.3 Measuring systems.....	10
6 Procedures for no-load loss measurement.....	11
6.1 General	11
6.2 Model function for no-load losses at reference conditions.....	11
6.3 Uncertainty budget for no-load loss	12
7 Procedures for load loss measurement.....	13
7.1 General	13
7.2 Model function for load loss measurement at rated current.....	13
7.3 Reporting to rated current and reference temperature	14
7.4 Uncertainty budget for the measured power P_2 reported to rated current	14
7.4.1 General	14
7.4.2 Uncertainties of measured load loss power P_2 at ambient temperature θ_2	14
7.5 Uncertainty budget for reported load loss at reference temperature	15
8 Three-phase calculations.....	16
8.1 Power measurement.....	16
8.2 Reference voltage	17
8.3 Reference current.....	17
9 Reporting	17
9.1 Uncertainty declaration.....	17
9.2 Traceability	17
10 Estimate of corrections and uncertainty contributions	18
10.1 Instrument transformers	18
10.2 Uncertainty contributions of ratio error of instrument transformers	18
10.3 Uncertainty contribution of phase displacement of instrument transformers	19
10.3.1 General	19
10.3.2 Complete reference procedure	19
10.3.3 Class index procedure	20
10.4 Voltage and current measurements	21
10.5 Power meter.....	21
10.6 Correction to sinusoidal waveform	22
10.7 Winding temperature at load loss measurement	23
10.8 Winding resistance measurement	23
Annex A (informative) Example of load loss uncertainty evaluation for a large power transformer	25

Annex B (Informative) Example of load loss uncertainty evaluation for a distribution transformer	33
Bibliography	37
Table 1 – Measured no-load loss uncertainties	12
Table 2 – Measured load loss uncertainties at ambient temperature	15
Table 3 – Absolute uncertainty of the additional losses at temperature θ_2	15
Table 4 – Absolute uncertainty of load losses P_{LL} reported at reference temperature	16
Table 5 – Procedures for the determination of phase displacement uncertainties	19
Table A.1 – Transformer ratings	25
Table A.2 – Loss measurement results (one phase)	27
Table A.3 – Calibration of voltage and current transformers	27
Table A.4 – Uncertainty contributions	29
Table B.1 – Transformer ratings	33
Table B.2 – Measured quantities	34
Table B.3 – Calibration of the current transformers	35
Table B.4 – Uncertainty contribution	36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER TRANSFORMERS –**Part 19: Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 60076-19, which is a technical specification, has been prepared by IEC technical committee 14: Power transformers.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
14/726/DTS	14/736A/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60076 series, published under the general title *Power transformers*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International Standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The losses of the transformers (no- load and load losses) are object of guaranty and penalty in the majority of the contracts and play an important role in the evaluation of the total (service) costs and therefore in the investments involved.

According to ISO/IEC 17025 the result of any measurement should be qualified with the evaluation of its uncertainty. A further requirement is that known corrections shall have been applied before evaluation of uncertainty.

Corrections and uncertainties are also considered in IEC 60076-8 were some general indications are given for their determination.

This Technical Specification deals with the measurement of the losses that from a measuring point of view consist of the estimate of a measurand and the evaluation of the uncertainty that affects the measurand itself.

The uncertainty range depends on the quality of the test installation and measuring system, on the skill of the staff and on the intrinsic measurement difficulties presented by the tested objects.

The submitted test results are to be considered the most correct estimate and therefore this value has to be accepted as it stands.

In the annexes to this document, two examples of uncertainty calculations are reported for load loss measurements on large power and distribution transformers.

Standards, technical reports and guides mentioned in the text are listed at the end of the document.

It is stated that guaranty and penalty calculations should refer to the best estimated values of the losses without considering the measurement uncertainties.

POWER TRANSFORMERS –

Part 19: Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactors

1 Scope

This part of IEC 60076, which is a Technical Specification, illustrates the procedures that should be applied to evaluate the uncertainty affecting the measurements of no-load and load losses during the routine tests on power transformers.

Even if the attention is especially paid to the transformers, when applicable the specification can be also used for the measurements of reactor losses, except large reactors with very low power factor.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-1:2011, *Power transformers – Part 1: General*

IEC 60076-2:2011, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN