

STN	Prístrojové transformátory. Časť 5: Dodatočné požiadavky na kapacitné transformátory napäťia. Norma na výrobky. Oprava AC	STN EN 61869-5/AC
		35 1309

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola označená vo Vestníku ÚNMS SR č. 02/16

Text opravy je iba v dokumente IEC.

Obsahuje: EN 61869-5:2011/AC Aug.:2015, IEC 61869-5:2011/COR1:2015

122369

Úrad pre normalizáciu, metrológiu a skúšobníctvo SR, 2016
Podľa zákona č. 264/1999 Z. z. v znení neskorších predpisov sa môžu slovenské technické normy
rozmnogoňovať a rozširovať iba so súhlasom Úradu pre normalizáciu, metrológiu a skúšobníctvo SR.

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 61869-5
Edition 1.0 2011-07

IEC 61869-5
Édition 1.0 2011-07

INSTRUMENT TRANSFORMERS –

Part 5: Additional requirements for capacitor voltage transformers

TRANSFORMATEURS DE MESURE –

Partie 5: Exigences supplémentaires concernant les transformateurs condensateurs de tension

C O R R I G E N D U M 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

6.502.2 Transients of ferro-resonance oscillations

Replace the existing formula by the following formula:

$$\hat{\varepsilon}_F = \frac{\hat{U}_{S(t=T_F)} - \frac{\sqrt{2} \times U_P}{k_r}}{\frac{\sqrt{2} \times U_P}{k_r}} = \frac{k_r \times \hat{U}_{S(t=T_F)} - \sqrt{2} \times U_P}{\sqrt{2} \times U_P}$$

Add the following new line at the end of the existing list:

t is the running time of the ferro-resonance oscillation test.

Table 508 – Test voltage for temperature rise test

Replace the existing Table 508 by the following table:

Table 508 – Test voltage for temperature rise test

Burden	Rated burden						Thermal limiting output from a secondary winding ^a	
Voltage factor & fault duration time	$F_V = 1,2$ continuous		$F_V = 1,5$ or $1,9$ 30 s		$F_V = 1,9$ 8 h		-	
Configuration of test	Electro-magnetic unit	Complete capacitor voltage transformer	Electro-magnetic unit	Complete capacitor voltage transformer	Electro-magnetic unit	Complete capacitor voltage transformer	Electro-magnetic unit	Complete capacitor voltage transformer
Test voltage till temperature rise is below 1 K/h.	$U_S = \frac{1,2 \times U_{Pr}}{k_f}$	$U_P = 1,2 \times U_{Pr}$	$U_S = \frac{1,2 \times U_{Pr}}{k_f}$	$U_P = 1,2 \times U_{Pr}$	$U_S = \frac{1,2 \times U_{Pr}}{k_f}$	$U_P = 1,2 \times U_{Pr}$	$U_C = \frac{U_{Pr}}{K_C}$	$U_P = U_{Pr}$
Test voltage for fault duration time	–	–	$U_S = \frac{F_V \times U_{Pr}}{k_f}$	$U_P = F_V \times U_{Pr}$	$U_S = \frac{1,9 \times U_{Pr}}{k_f}$	$U_P = 1,9 \times U_{Pr}$	–	–

^a Additional test if a thermal limiting output is specified.