

STN	Merače tepla. Časť 3: Výmena dát a rozhrania.	STN EN 1434-3 25 8512
------------	--	---

Heat meters - Part 3: Data exchange and interfaces

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 04/16

Obsahuje: EN 1434-3:2015

Oznámením tejto normy sa ruší
STN EN 1434-3 (25 8512) z mája 2009

122819

Úrad pre normalizáciu, metrológiu a skúšobníctvo SR, 2016
Podľa zákona č. 264/1999 Z. z. v znení neskorších predpisov sa môžu slovenské technické normy
rozmnožovať a rozširovať iba so súhlasom Úradu pre normalizáciu, metrológiu a skúšobníctvo SR.

EUROPEAN STANDARD

EN 1434-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2015

ICS 17.200.10

Supersedes EN 1434-3:2008

English Version

Heat meters - Part 3: Data exchange and interfaces

Compteurs d'énergie thermique - Partie 3 : Échange de
données et interfacesWärmezähler - Teil 3: Datenaustausch und
Schnittstellen

This European Standard was approved by CEN on 27 September 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

Contents	Page
European foreword	4
1 Scope	5
2 Normative references	5
3 Meter interfaces and protocols overview	6
4 Physical layer	6
4.1 General	6
4.2 Physical layer optical interface	6
4.3 Physical layer M-Bus	6
4.4 Physical layer wireless interface	6
4.5 Physical layer current loop interface	7
4.6 Physical layer Local Bus	7
5 Link layer	7
5.1 Link layer optical interface	7
5.2 Link layer of M-Bus and Local Bus	7
5.3 Link layer wireless interface	7
5.4 Link layer current-loop interface	7
6 Application layer	8
6.1 Application layer optical interface	8
6.2 Application layer M-Bus and Local Bus	9
7 Application	9
7.1 General	9
7.2 Physical layer	9
7.3 Link layer	9
7.4 Application layer	9
7.5 Control applications	9
Annex A (informative) Recommendation for heat meter test interface	10
Annex B (informative) Additional information for heat meters	11
B.1 Additional information regarding the EN 62056-21 protocol	11
B.2 Data set	11
B.3 Coding of the data set identification number	12
Annex C (informative) Automatic protocol detection and wake-up for the optical interface	21
C.1 Introduction	21
C.2 Trying EN 13757-2 protocol	21
C.3 Trying the EN 62056-21 protocol	21
Annex D (informative) Usage of heat meters in control applications	23
D.1 Heat meter	23
D.2 Controller	24
Annex E (informative) Protection techniques for M-Bus meters against surge/lightning	26

Annex F (informative) Additional information about the master-unit for the M-Bus.....	30
F.1 Master side interface to the M-Bus.....	30
F.2 Master side interface for local data read out.....	30
F.3 Full size level converter	31
Bibliography	33

European foreword

This document (EN 1434-3:2015) has been prepared by Technical Committee CEN/TC 294 "Communication systems for meters", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2016, and conflicting national standards shall be withdrawn at the latest by June 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1434-3:2008.

The following significant editorial changes compared to the previous edition have been incorporated in this European Standard:

- a) update of normative references;
- b) update of Table 1 "Possible combinations of interfaces and standards";
- c) addition of explanations to Table B.1 "Values for "UU", register codes".

EN 1434 consists of the following parts, under the general title "Heat meters":

- *Part 1: General requirements*
- *Part 2: Constructional requirements*
- *Part 4: Pattern approval tests*
- *Part 5: Initial verification tests*
- *Part 6: Installation, commissioning, operational monitoring and maintenance*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard specifies the general requirements and applies to heat meters. Heat meters are instruments intended for measuring the energy which in a heat-exchange circuit is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The meter indicates heat in legal units.

Part 3 specifies the data exchange between a meter and a readout device (POINT / POINT communication). For these applications using the optical readout head, the EN 62056-21 protocol is recommended.

For direct or remote local readout of a single or a few meters via a battery driven readout device, the physical layer of EN 13757-6 (local bus) is recommended.

For bigger networks with up to 250 meters, a master unit with AC mains supply according to EN 13757-2 is necessary to control the M-Bus. For these applications the physical and link layer of EN 13757-2 and the application layer of EN 13757-3 is required.

For wireless meter communications, EN 13757-4 describes several alternatives of walk/drive-by readout via a mobile station or by using stationary receivers or a network. Both unidirectionally and bidirectionally transmitting meters are supported by this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13757-2, *Communication systems for meters and remote reading of meters — Part 2: Physical and link layer*

EN 13757-3:2013, *Communication systems for meters and remote reading of meters — Part 3: Dedicated application layer*

EN 13757-4, *Communication systems for meters and remote reading of meters — Part 4: Wireless meter readout (Radio meter reading for operation in SRD bands)*

EN 13757-6, *Communication systems for meters — Part 6: Local Bus*

EN 62056-21:2002, *Electricity metering — Data exchange for meter reading, tariff and load control — Part 21: Direct local data exchange (IEC 62056-21:2002)*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN