

<b>STN</b>	<b>Tepelnoizolačné výrobky pre technické zariadenia budov a priemyselné inštalácie. Prefabrikované výrobky z fenolovej peny (PF). Špecifikácia.</b>	<b>STN EN 14314</b>  72 7247
------------	---	--

Thermal insulation products for building equipment and industrial installations - Factory made phenolic foam (PF) products - Specification

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 06/16

Obsahuje: EN 14314:2015

Oznámením tejto normy sa od 01.10.2017 ruší  
STN EN 14314+A1 (72 7247) z júna 2013

**123028**

EUROPEAN STANDARD

**EN 14314**

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2015

ICS 91.100.60

Supersedes EN 14314:2009+A1:2013

English Version

## Thermal insulation products for building equipment and industrial installations - Factory made phenolic foam (PF) products - Specification

Produits isolants thermiques pour l'équipement du bâtiment et les installations industrielles - Produits manufacturés en mousse phénolique (PF) - Spécification

Wärmedämmstoffe für die technische Gebäudeausrüstung und für betriebstechnische Anlagen in der Industrie - Werkmäßig hergestellte Produkte aus Phenolharzschaum (PF) - Spezifikation

This European Standard was approved by CEN on 24 October 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

<b>Contents</b>	<b>Page</b>
European foreword.....	4
<b>1 Scope</b> .....	<b>6</b>
<b>2 Normative references</b> .....	<b>6</b>
<b>3 Terms, definitions, symbols, units and abbreviated terms</b> .....	<b>8</b>
<b>3.1 Terms and definitions</b> .....	<b>8</b>
<b>3.1.1 Terms and definitions as given in EN ISO 9229</b> .....	<b>8</b>
<b>3.1.2 Additional terms and definitions</b> .....	<b>8</b>
<b>3.2 Symbols, units and abbreviated terms</b> .....	<b>9</b>
<b>3.2.1 Symbols and units used in this standard</b> .....	<b>9</b>
<b>3.2.2 Abbreviated terms used in this standard</b> .....	<b>10</b>
<b>4 Requirements</b> .....	<b>11</b>
<b>4.1 General</b> .....	<b>11</b>
<b>4.2 For all applications</b> .....	<b>11</b>
<b>4.2.1 Thermal conductivity</b> .....	<b>11</b>
<b>4.2.2 Dimensions and tolerances</b> .....	<b>11</b>
<b>4.2.3 Dimensional stability</b> .....	<b>13</b>
<b>4.2.4 Reaction to fire of the product as placed on the market</b> .....	<b>13</b>
<b>4.2.5 Durability characteristics</b> .....	<b>13</b>
<b>4.3 For specific applications</b> .....	<b>14</b>
<b>4.3.1 General</b> .....	<b>14</b>
<b>4.3.2 Maximum service temperature</b> .....	<b>14</b>
<b>4.3.3 Minimum service temperature</b> .....	<b>14</b>
<b>4.3.4 Dimensional stability under specified conditions</b> .....	<b>14</b>
<b>4.3.5 Compression resistance properties</b> .....	<b>15</b>
<b>4.3.6 Water vapour diffusion resistance</b> .....	<b>16</b>
<b>4.3.7 Water absorption</b> .....	<b>16</b>
<b>4.3.8 Closed cell content</b> .....	<b>17</b>
<b>4.3.9 Trace quantities of water soluble chloride and the pH-value</b> .....	<b>17</b>
<b>4.3.10 Release of dangerous substances</b> .....	<b>17</b>
<b>4.3.11 Continuous glowing combustion</b> .....	<b>17</b>
<b>5 Test methods</b> .....	<b>18</b>
<b>5.1 Sampling</b> .....	<b>18</b>
<b>5.2 Conditioning</b> .....	<b>18</b>
<b>5.3 Testing</b> .....	<b>18</b>
<b>5.3.1 General</b> .....	<b>18</b>
<b>5.3.2 Thermal conductivity</b> .....	<b>20</b>
<b>5.3.3 Reaction to Fire</b> .....	<b>21</b>
<b>6 Designation code</b> .....	<b>21</b>
<b>7 Assessment and Verification of the Constancy of Performance (AVCP)</b> .....	<b>21</b>
<b>7.1 General</b> .....	<b>21</b>
<b>7.2 Product Type Determination (PTD)</b> .....	<b>22</b>
<b>7.3 Factory Production Control (FPC)</b> .....	<b>22</b>
<b>8 Marking and labelling</b> .....	<b>22</b>

<b>Annex A (normative) Factory production control .....</b>	<b>23</b>
<b>Annex B (normative) Determination of the aged value of thermal conductivity .....</b>	<b>25</b>
<b>B.1 General .....</b>	<b>25</b>
<b>B.2 Preparation of test sample .....</b>	<b>25</b>
<b>B.3 Determination of the initial value of thermal conductivity .....</b>	<b>26</b>
<b>B.4 Determination of the aged value of thermal conductivity .....</b>	<b>26</b>
<b>B.5 Blowing agent .....</b>	<b>27</b>
<b>B.6 Declaration of thermal resistance and thermal conductivity .....</b>	<b>27</b>
<b>Annex C (normative) Determination of minimum service temperature .....</b>	<b>28</b>
<b>C.1 Definitions .....</b>	<b>28</b>
<b>C.2 Principle .....</b>	<b>28</b>
<b>C.3 Apparatus .....</b>	<b>28</b>
<b>C.4 Test specimens .....</b>	<b>29</b>
<b>C.5 Procedure .....</b>	<b>29</b>
<b>C.6 Calculation and expression of results .....</b>	<b>30</b>
<b>C.7 Accuracy of measurements .....</b>	<b>30</b>
<b>C.8 Test report .....</b>	<b>30</b>
<b>C.9 Modifications of and additions to the general test method for phenolic foams .....</b>	<b>31</b>
<b>Annex D (informative) Additional properties .....</b>	<b>34</b>
<b>D.1 General .....</b>	<b>34</b>
<b>D.2 Apparent density .....</b>	<b>34</b>
<b>D.3 Coefficient of thermal expansion .....</b>	<b>34</b>
<b>D.4 Water vapour transmission of preformed pipe insulation .....</b>	<b>34</b>
<b>D.5 Tensile strength perpendicular to faces .....</b>	<b>34</b>
<b>D.6 Shear strength .....</b>	<b>34</b>
<b>D.7 Bending strength .....</b>	<b>35</b>
<b>D.8 Cell gas composition .....</b>	<b>35</b>
<b>D.9 Cryogenic application .....</b>	<b>35</b>
<b>Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation .....</b>	<b>36</b>
<b>ZA.1 Scope and relevant characteristics .....</b>	<b>36</b>
<b>ZA.2 Procedures for AVCP of factory made phenolic foam .....</b>	<b>38</b>
<b>ZA.3 CE Marking and labelling .....</b>	<b>45</b>
<b>Bibliography .....</b>	<b>47</b>

## European foreword

This document (EN 14314:2015) has been prepared by Technical Committee CEN/TC 88 “Thermal insulating materials and products”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2016, and conflicting national standards shall be withdrawn at the latest by September 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14314:2009+A1:2013.

This document is identifying those clauses of the standard which are needed for the compliance of the European Standard with the Construction Products Regulation (CPR).

The main technical changes that have been made in this new edition of EN 14314 are the following:

- a) an addition to the foreword;
- b) modifications in 3.2.2;
- c) a new 4.3.10;
- d) modification of 5.3.2;
- e) replacement of Clause 7;
- f) modification of Clause 8;
- g) modification of Annex A;
- h) a new Annex ZA.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of Regulation (EU) No. 305/2011.

For relationship with Regulation (EU) No. 305/2011, see informative Annex ZA, which is an integral part of this document.

Locally responsible authorities and contracting entities, who are bound by EU Directives to specify their requirements using European harmonized product standards, are allowed to demand additional properties outside the provisions of this standard if this is technically necessary because of prevailing operational conditions of the building equipment or the industrial installation projected or because of safety regulations.

This European Standard contains five annexes:

- Annex A (normative), Factory production control;
- Annex B (normative), Determination of the aged value of thermal conductivity;
- Annex C (normative), Determination of minimum service temperature;
- Annex D (informative), Additional properties;

- Annex ZA (informative), Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation.

This document includes a bibliography.

This European Standard is one of a series of standards for insulation products used in building equipment and industrial installations but this standard can be used in other areas, where appropriate.

In pursuance of Resolution BT 20/1993 revised, CEN/TC 88 have proposed defining the standards listed below as a European package of standards, setting 21 months after availability as the date of withdrawal (dow) of national standards which conflict with the European Standards of this package.

The package of standards comprises the following group of interrelated standards for the specifications of factory made thermal insulation products, all of which come within the scope of CEN/TC 88:

EN 14303, *Thermal insulation products for building equipment and industrial installations — Factory made mineral wool (MW) products — Specification*

EN 14304, *Thermal insulation products for building equipment and industrial installations — Factory made flexible elastomeric foam (FEF) products — Specification*

EN 14305, *Thermal insulation products for building equipment and industrial installations — Factory made cellular glass (CG) products — Specification*

EN 14306, *Thermal insulation products for building equipment and industrial installations — Factory made calcium silicate (CS) products — Specification*

EN 14307, *Thermal insulation products for building equipment and industrial installations — Factory made extruded polystyrene foam (XPS) products — Specification*

EN 14308, *Thermal insulation products for building equipment and industrial installations — Factory made rigid polyurethane foam (PUR) and polyisocyanurate foam (PIR) products — Specification*

EN 14309, *Thermal insulation products for building equipment and industrial installations — Factory made products of expanded polystyrene (EPS) — Specification*

EN 14313, *Thermal insulation products for building equipment and industrial installations — Factory made polyethylene foam (PEF) products — Specification*

EN 14314, *Thermal insulation products for building equipment and industrial installations — Factory made phenolic foam (PF) products — Specification*

EN 15501, *Thermal insulation products for building equipment and industrial installations — Factory made expanded perlite (EP) and exfoliated vermiculite (EV) products — Specification*

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## 1 Scope

This European Standard specifies the requirements for factory made phenolic foam products which are used for the thermal insulation of building equipment and industrial installations with an operating temperature in the range of approximately - 200 °C to + 120 °C.

Below an operating temperature of - 50 °C, special tests regarding the suitability of the products in the intended application are advised (e.g. liquefaction of oxygen). Manufacturer's advice should be heeded in all cases.

The products are manufactured in the form of blocks, faced or unfaced, boards, pipe sections, segments and prefabricated ware.

This European Standard describes product characteristics and includes procedures for testing, evaluation of conformity, marking and labelling.

Products covered by this standard are also used in prefabricated thermal insulating systems and composite panels; the performance of systems incorporating these products is not covered.

This European Standard does not specify the required level of a given property that should be achieved by a product to demonstrate fitness for purpose in a particular application. The levels required for a given application can be found in regulations and invitations to tender.

Products with a declared thermal conductivity greater than 0,050 W/(m·K) at 10 °C are not covered by this standard.

This European Standard does not cover products for *in situ*-insulation (blowing or pouring) or products for the insulation of the building structure.

This European Standard does not cover the following acoustical aspects: direct airborne sound insulation and impact noise transmission index.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 822, *Thermal insulating products for building applications - Determination of length and width*

EN 823, *Thermal insulating products for building applications - Determination of thickness*

EN 824, *Thermal insulating products for building applications - Determination of squareness*

EN 825, *Thermal insulating products for building applications - Determination of flatness*

EN 826, *Thermal insulating products for building applications - Determination of compression behaviour*

EN 1604, *Thermal insulating products for building applications - Determination of dimensional stability under specified temperature and humidity conditions*

EN 1606, *Thermal insulating products for building applications - Determination of compressive creep*

EN 1608, *Thermal insulating products for building applications - Determination of tensile strength parallel to faces*

EN 1609, *Thermal insulating products for building applications - Determination of short term water absorption by partial immersion*

EN 12085, *Thermal insulating products for building applications - Determination of linear dimensions of test specimens*

EN 12086, *Thermal insulating products for building applications - Determination of water vapour transmission properties*

EN 12429, *Thermal insulating products for building applications - Conditioning to moisture equilibrium under specified temperature and humidity conditions*

EN 12667:2001, *Thermal performance of building materials and products - Determination of thermal resistance by means of guarded hot plate and heat flow meter methods - Products of high and medium thermal resistance*

EN 12939, *Thermal performance of building materials and products - Determination of thermal resistance by means of guarded hot plate and heat flow meter methods - Thick products of high and medium thermal resistance*

EN 13166, *Thermal insulation products for buildings - Factory made phenolic foam (PF) products - Specification*

EN 13172:2012, *Thermal insulation products - Evaluation of conformity*

EN 13467, *Thermal insulating products for building equipment and industrial installations - Determination of dimensions, squareness and linearity of preformed pipe insulation*

EN 13468, *Thermal insulating products for building equipment and industrial installations - Determination of trace quantities of water soluble chloride, fluoride, silicate, sodium ions and pH*

EN 13501-1:2007+A1:2009, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13823, *Reaction to fire tests for building products — Building products excluding flooring exposed to the thermal attack by a single burning item*

EN 14706, *Thermal insulating products for building equipment and industrial installations - Determination of maximum service temperature*

EN 14707, *Thermal insulating products for building equipment and industrial installations - Determination of maximum service temperature for preformed pipe insulation*

EN 15715:2009, *Thermal insulation products - Instructions for mounting and fixing for reaction to fire testing - Factory made products*

EN ISO 4590, *Rigid cellular plastics - Determination of the volume percentage of open cells and of closed cells (ISO 4590)*

EN ISO 8497, *Thermal insulation - Determination of steady-state thermal transmission properties of thermal insulation for circular pipes (ISO 8497)*

EN ISO 9229, *Thermal insulation - Vocabulary (ISO 9229)*

EN ISO 10456, *Building materials and products - Hygrothermal properties - Tabulated design values and procedures for determining declared and design thermal values (ISO 10456)*



**EN 14314:2015 (E)**

EN ISO 11925-2, *Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test (ISO 11925-2)*

EN ISO 13787, *Thermal insulation products for building equipment and industrial installations - Determination of declared thermal conductivity (ISO 13787)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**