

<b>STN</b>	<b>Energetická hospodárnosť budov Metóda výpočtu energetických požiadaviek systému a účinnosti systému Časť 4-2: Systémy výroby tepla, systémy tepelného čerpadla</b>	<b>STN EN 15316-4-2</b>  06 0237
------------	---	--

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-2: Space heating generation systems, heat pump systems, Module M3-8-2, M8-8-2

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 09/17

Obsahuje: EN 15316-4-2:2017

Oznámením tejto normy sa ruší  
STN EN 15316-4-2 (06 0237) z októbra 2008

**125294**

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2017  
Podľa zákona č. 264/1999 Z. z. o technických požiadavkách na výrobky a o posudzovaní zhody a o zmene a doplnení niektorých zákonov v znení neskorších predpisov sa slovenská technická norma a časti slovenskej technickej normy môžu rozmnožovať alebo rozširovať len so súhlasom slovenského národného normalizačného orgánu.



EUROPEAN STANDARD

**EN 15316-4-2**

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2017

ICS 91.140.10

Supersedes EN 15316-4-2:2008

English Version

**Energy performance of buildings - Method for calculation  
of system energy requirements and system efficiencies -  
Part 4-2: Space heating generation systems, heat pump  
systems, Module M3-8-2, M8-8-2**

Performance énergétique des bâtiments - Méthode de  
calcul des besoins énergétiques et des rendements des  
systèmes - Partie 4-2 : Systèmes de génération de  
chauffage des locaux, systèmes de pompes à chaleur  
Module M3-8-2, M8-8-2

Energetische Bewertung von Gebäuden - Verfahren zur  
Berechnung der Energieanforderungen und  
Nutzungsgrade der Anlagen - Teil 4-2:  
Wärmeerzeugung für die Raumheizung,  
Wärmepumpensysteme, Modul M3-8-2, M8-8-2

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Contents

Page

European foreword.....	4
Introduction .....	5
1 Scope.....	6
2 Normative references.....	9
3 Terms and definitions .....	9
4 Symbols and abbreviations .....	13
4.1 Symbols.....	13
4.2 Subscripts.....	13
5 Description of the methods .....	14
5.1 General.....	14
5.2 Multiple heat generators .....	14
5.3 System boundary.....	15
5.3.1 General.....	15
5.3.2 Physical factors taken into account:.....	15
5.4 Schematisation of the heat pump for heating.....	15
5.5 Energy input needed to meet the heat requirements for heat pumps system.....	16
5.6 Auxiliary energy ( $W_{HW;gen;aux}$ ) .....	18
5.7 Recoverable, recovered and unrecoverable heat losses .....	18
5.8 Calculation by zones.....	18
5.9 Combined heating and domestic hot water preparation.....	19
6 Generation with heat pump systems - Energy calculation (hourly, bin) - Method A .....	19
6.1 Output data.....	19
6.2 Input data.....	20
6.3 Multiple heat generators .....	26
6.4 Calculation time steps .....	26
6.5 Flow chart .....	26
6.6 Energy requirements for space heating and DHW mode for the time step considered .....	27
6.7 COP and energy used for heating, storage and domestic hot water .....	28
6.8 Auxiliary energy ( $W_{H;gen;aux}$ ) .....	39
6.9 Energy used from the heat source.....	39
6.10 Calculation of back-up heater.....	40
6.11 Total losses and total recoverable heat losses of the generation subsystem.....	40
7 Method B - Monthly and annual energy calculation method.....	43
7.1 Calculation time steps .....	43
7.2 Output data.....	43
7.3 Principle of the calculation method B.....	43
7.4 Additional input Data .....	44
7.5 Construction of the bins - Step 1 .....	46
7.6 Determination of energy requirement of the single bins - Step 2 .....	50
7.7 Determination of thermal performance of the heat pump (step 3).....	52
7.8 Determination of back-up energy of the single bins (step 4).....	53
7.9 Calculation of auxiliary energy input (step 5) .....	53

7.10	Calculation of recoverable generation subsystem losses (step 6).....	53
7.11	Calculation of the energy from the heat source (step 7) .....	54
7.12	Calculation of the total driving energy input to cover the requirements (step 8).....	54
8	Quality control.....	54
8.1	Hourly, bin or monthly method.....	54
8.2	Main sources of errors.....	55
9	Compliance check.....	55
Annex A (normative) Template for input data.....		56
A.1	Heat pump description data .....	56
A.2	System design data.....	60
A.3	Operating conditions.....	62
Annex B (informative) Default values.....		64
B.1	Heat pump description data .....	64
B.2	System design data.....	68
B.3	- Operating conditions .....	70
Annex C (informative) Tables of COP and energy at full load.....		72
C.1	General .....	72
C.2	Air - Water electrically driven heat pumps .....	72
C.3	COP and energy for exhaust air/ water electrically driven heat pump .....	73
C.4	COP and energy for water or brine/ water electrically driven heat pump.....	74
C.5	Air/water combustion-engine driven heat pumps.....	75
Annex D (normative) Adaptation of the COP to different conditions of temperature conditions.....		77
D.1	Principle.....	77
D.2	Application to electrically-driven heat pump .....	78
D.3	Application to thermally-driven heat pumps.....	78
D.4	Correction of COP with adaptation to the operational temperature spread .....	79
D.5	Tests results form EN 14825 .....	82
D.6	Input data for the calculation of COP and capacity at operating conditions.....	82
Bibliography .....		84

## European foreword

This document (EN 15316-4-2:2017) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems in buildings”, the secretariat of which is held by DIN.

This document supersedes EN 15316-4-2:2008.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2017, and conflicting national standards shall be withdrawn at the latest by October 2017.

The revision keeps the main principles of the calculation unchanged but the structure of the document was changed. Informative content was removed to the accompanying technical report CEN/TR 15316-6-2. The provisions cover also other energy carriers than heat now. The values may be altered in a national annex.

Calculation methods to determine energy source indicators like the renewable energy ratio have been added.

The main changes compared to EN 15316-4-2:2008 are:

- a) type of heat pumps are now limited to hot water production at the output of the condenser;
- b) informative content was removed to the accompanying technical report CEN/TR 15316-6-2;
- c) calculation for performance of the heat pumps at different conditions is based on interpolation provisions;
- d) input data for energy performance of the heat pumps are based on part load and/or full load information;
- e) Annex A contains a template for the data and parameters used in the standards and Annex B a set of default values.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

EPB standards deal with energy performance calculation and other related aspects (like system sizing) to provide the building services considered in the EPBD.

CEN/TC 228 deals with heating systems in buildings. Subjects covered by CEN/TC 228 are:

- energy performance calculation for heating systems;
- inspection of heating systems;
- design of heating systems;
- installation and commissioning of heating systems.

This standard specifies to take into account the energy performance of heat pump systems used for domestic or heating purpose.

For the correct use of this standard, Annex A is to be used to specify the choices with the required input data. Default values are presented in Annex B. In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements. These choices can be made available as National Annex or as separate (e.g. legal) document. It is expected, if the default values and choices in Annex A are not followed due to national regulations, policy or traditions, that:

- either the national standardization body will consider the possibility to add or include a National Annex in agreement with the template of Annex A.
- or the national or regional authorities will, in the building regulations, reference the standard and prepare data sheets containing the national or regional choices and values, in agreement with the template of Annex A.

This updated standard covers hourly, monthly, annual time-steps and temperatures classes (bin method).

## 1 Scope

This European Standard covers heat pumps for space heating, heat pump water heaters (HPWH) and heat pumps with combined space heating and domestic hot water production in alternate or simultaneous operation, where the same heat pump delivers the heat to cover the space heating and domestic hot water heat requirement.

The standard provides a calculation method under steady conditions that corresponds to one calculation step.

The results of this calculation are incorporated in larger building models and take in account the influence of the external conditions and building control that influence the energy requirements for heating supplied by the heat pump system.

The scope of this part is to standardize the:

- required inputs;
- calculation methods;
- required outputs

Generation for space heating and domestic hot water production of the following heat pump systems, including control of:

- electrically-driven vapour compression cycle (VCC) heat pumps;
- combustion engine-driven vapour compression cycle heat pumps;
- thermally-driven vapour absorption cycle (VAC) heat pumps,

using combinations of heat source and heat distribution listed in Table 1.

**Table 1 — Heating sources and energy distribution**

Source	Distribution
Outdoor air	<b>Water</b>
Exhaust-air	
Indirect ground source with brine	
Indirect ground source with water	
Direct ground source (Direct expansion (DX))	
Surface water	
Ground water	

This standard does not cover sizing or inspection of heat pumps.

This standard deals with heat generators for heating or for combined domestic hot water and heating service. Generators for domestic hot water only are taken into account into module M8-8.

NOTE 1 Heat pumps for cooling systems are taken into account into module M4-8.

NOTE 2 Heat pumps for space heating using air (distribution) are taken into account in module M5-8.



Other generation systems such as boilers are covered in other sub modules of part M3-8.

This is the revision of EN 15316-4-2:2008. The revision covers the adaptation of the standard to hourly and monthly energy calculation.

Table 2 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 3 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 4 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.

Table 2 — Position of this standard, within the modular structure of the set of EPB standards

Overarching		Building (as such)		Technical Building Systems										
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Hot Domestic water	Lighting	Building automation and control	Electricity production
sub 1		M1	sub1	M2	sub1	M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General		1	General	1	General	15316-1				15316-1			
2	Common terms and definitions; symbols, units and subscripts		2	Building Energy Needs	2	Needs					12831-3 ?			
3	Applications		3	(Free) Indoor Conditions without Systems	3	Maximum Load and Power	12831-1				12831-3			
4	Ways to Express Energy Performance		4	Ways to Express Energy Performance	4	Ways to Express Energy Performance	15316-1				15316-1			
5	Building Functions and Building Boundaries		5	Heat Transfer by Transmission	5	Emission and control	15316-2	15316-2						
6	Building Occupancy and Operating Conditions		6	Heat Transfer by Infiltration and Ventilation	6	Distribution and control	15316-3	15316-3			15316-3			
7	Aggregation of Energy Services and Energy Carriers		7	Internal Heat Gains	7	Storage and control	15316-5				15316-5 15316-4-3			
8	Building Partitioning		8	Solar Heat Gains	8	Generation								
					8-1	Combustion boilers	15316-4-1				15316-4-1			
					8-2	Heat pumps	15316-4-2				15316-4-2			
					8-3	Thermal solar Photovoltaics	15316-4-3				15316-4-3			15316-4-3
					8-4	On-site cogeneration	15316-4-4				15316-4-4			15316-4-4
					8-5	District heating and cooling	15316-4-5	15316-4-5						15316-4-5
					8-6	Direct electrical heater	15316-4-6				15316-4-6			
					8-7	Wind turbines								15316-4-7
					8-8	Radiant heating, stoves	15316-4-8							
9	Calculated Energy Performance		9	Building Dynamics (thermal mass)	9	Load dispatching and operating conditions								
10	Measured Energy Performance		10	Measured Energy Performance	10	Measured Energy Performance	15378-3				15378-3			
11	Inspection		11	Inspection	11	Inspection	15378-1				15378-1			
12	Ways to Express Indoor Comfort		12	-	12	BMS								
13	External Environment Conditions													
14	Economic Calculation	1545 9-1												

NOTE The shaded modules are not applicable

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12309-4, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 4: Test methods*

EN 12309-6, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 6: Calculation of seasonal performances*

EN 15316-3, *Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 3: Space distribution systems (DHW, heating and cooling), Module M3-6, M4-6, M8-6*

EN 15316-4-1, *Heating systems in buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-1: Space heating generation systems, combustion systems (boilers)*

EN 14511 (all parts), *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling*

EN 14825, *Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance*

EN 16147, *Heat pumps with electrically driven compressors - Testing, performance rating and requirements for marking of domestic hot water units*

EN ISO 15927-6, *Hygrothermal performance of buildings - Calculation and presentation of climatic data - Part 6: Accumulated temperature differences (degree-days) (ISO 15927-6)*

EN ISO 52000-1:2017, *Energy performance of buildings - Overarching EPB assessment - Part 1: General framework and procedures (ISO 52000-1:2017)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**