

STN	Káblové siete pre televízne signály, rozhlasové signály a interaktívne služby Časť 11: Bezpečnosť	STN EN 60728-11 36 7211
------------	--	---

Cable networks for television signals, sound signals and interactive services - Part 11: Safety

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 09/17

Obsahuje: EN 60728-11:2017, IEC 60728-11:2016, IEC 60728-11:2016/COR1:2016

Oznámením tejto normy sa od 26.05.2020 ruší
STN EN 60728-11 (36 7211) z februára 2011

125489

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2017
Podľa zákona č. 264/1999 Z. z. o technických požiadavkách na výrobky a o posudzovaní zhody a o zmene a doplnení niektorých zákonov v znení neskorších predpisov sa slovenská technická norma a časti slovenskej technickej normy môžu rozmnožovať alebo rozširovať len so súhlasom slovenského národného normalizačného orgánu.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60728-11

May 2017

ICS 33.060.40

Supersedes EN 60728-11:2010

English Version

Cable networks for television signals, sound signals
and interactive services -
Part 11: Safety
(IEC 60728-11:2016 + COR1:2016)

Réseaux de distribution par câbles pour signaux de
télévision, signaux de radiodiffusion sonore et services
interactifs -
Partie 11: Sécurité
(IEC 60728-11:2016 + COR1:2016)

Kabelnetze für Fernsehsignale, Tonsignale und interaktive
Dienste -
Teil 11: Sicherheitsanforderungen
(IEC 60728-11:2016 + COR1:2016)

This European Standard was approved by CENELEC on 2016-04-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 100/2592/FDIS, future edition 4 of IEC 60728-11 prepared by Technical Area 5 “Cable networks for television signals, sound signals and interactive services” of IEC/TC 100 “Audio, video and multimedia systems and equipment” was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60728-11:2017.

The following dates are fixed:

- latest date by which the document has to be (dop) 2017-11-26
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2020-05-26
standards conflicting with the
document have to be withdrawn

This document supersedes EN 60728-11:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

For this European Standard the informative Annex C of IEC 60728-11:2016 shall be disregarded and has been replaced by the Annexes ZB, A deviations and ZC, Special National Conditions.

Endorsement notice

The text of the International Standard IEC 60728-11:2016 + COR1:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60364 Series	NOTE	Harmonized as HD 60364 Series.
IEC 60728-1	NOTE	Harmonized as EN 60728-1.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
-	-	Coaxial cables	EN 50117	Series
-	-	Lightning Protection Components (LPC) - Part 1: Requirements for connection components	EN 50164-1	-
-	-	Lightning Protection Components (LPC) - Part 2: Requirements for conductors and earth electrodes	EN 50164-2	-
-	-	Information technology - Cabling installation - Part 2: Installation planning and practices inside buildings	EN 50174-2	-
-	-	Telecommunications bonding networks for buildings and other structures	EN 50310	-
IEC 60065 (mod)	2014	Audio, video and similar electronic apparatus - Safety requirements	EN 60065	2014
IEC 60364-1	-	Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, definitions	HD 60364-1	-
IEC 60364-4-44	-	Low-voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances	HD 60364-4-442	-
IEC 60364-5-52	-	Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems	HD 60364-5-52	-
IEC 60364-5-54	-	Low-voltage electrical installations - Part 5-54: Selection and erection of electrical equipment - Earthing arrangements and protective conductors	HD 60364-5-54	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60529	-	Degrees of protection provided by enclosures (IP Code)	EN 60529	-
IEC 60728-2	-	Cable networks for television signals, sound signals and interactive services - Part 2: Electromagnetic compatibility for equipment	EN 50083-2	-
IEC 60825-1	-	Safety of laser products - Part 1: Equipment classification and requirements	EN 60825-1	-
IEC 60825-2	-	Safety of laser products - Part 2: Safety of optical fibre communication systems (OFCS)	EN 60825-2	-
IEC 60950-1 (mod)	2005	Information technology equipment - Safety - Part 1: General requirements	EN 60950-1	2006
			+A11	2009
			+A12	2011
			+AC	2011
IEC 60990	-	Methods of measurement of touch current and protective conductor current	EN 60990	-
IEC 61140	2001	Protection against electric shock - Common aspects for installation and equipment	EN 61140	2002 ¹⁾
+A1 (mod)	2004		+A1	2006 ¹⁾
IEC 62305	Series	Protection against lightning	EN 62305	Series
IEC 62305-2 (mod)	2010	Protection against lightning - Part 2: Risk management	EN 62305-2	2012
IEC 62305-3 (mod)	2010	Protection against lightning - Part 3: Physical damage to structures and life hazard	EN 62305-3	2011
IEC 62305-4 (mod)	2010	Protection against lightning - Part 4: Electrical and electronic systems within structures	EN 62305-4	2011
ISO 3864-1	2011	Graphical symbols - Safety colours and safety signs - Part 1: Design principles for safety signs and safety markings	-	-

¹⁾ Superseded by EN 61140:2016 (IEC 61140:2016): DOW = 2019-05-27.

Annex ZB (informative)

A-deviations

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC national member.

This European Standard does not fall under any Directive of the EU.

In the relevant CEN-CENELEC countries, these A-deviations are valid instead of the provisions of the European Standard until they have been removed.

<u>Clause</u>	<u>Deviation</u>
---------------	------------------

9	ZB.1 France
----------	--------------------

(Arrêté interministériel, 2 April 1991)

This regulation specifies, among many other parameters, the minimum distance between electric supply wires (isolated and not isolated, low-voltage and high-voltage) and any other installation (e.g. buildings, antennas, telecommunication lines, etc.).

The main clauses of this regulation which concern the cable networks are Clauses 12, 25, 26, 33, 33bis, 38, 49, 51, 52 and 63.

Clause 9 of this standard specifies distances of 10 mm (indoors) and 20 mm (outdoors) and this is not sufficient to cover overhead cables. As an example, the minimum distance between an overhead telecommunication line and an overhead low-voltage (up to 1 kV) electricity supply line shall be 1 m (Clause 33). This distance may be reduced under specified conditions (Clauses 51, 52 and 63).

This regulation specifies also the minimum distance from high-voltage lines. This distance varies from 1 m to 4 m depending on the voltage, on the isolation of the cable and on the location (built-up area or not) (Clauses 33 and 63)

10.1	ZB.2 United Kingdom
-------------	----------------------------

In the UK the use of fully isolated system outlets is obligatory.

11	ZB.3 France
-----------	--------------------

(NF C 15100 - Décret n° 84-74 du 26 janvier 1984 modifié)

The use of TT distribution systems with 300 mA differential switching is not compatible with the interconnection of the earthing of two different buildings.

Annex ZC (normative)

Special national conditions

Special national condition: National characteristic or practice that cannot be changed even over a long period, e.g. climatic conditions, electrical earthing conditions.

NOTE If it affects harmonization, it forms part of the European Standard.

For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.

Clause Special National Condition

6.2 ZC.1 Norway

The following parts of the standard are not applicable due to Special National Conditions:

- For new and rebuilt coaxial electronic communication networks the outer conductor of the coaxial cable leading into a building shall be galvanic and isolated from the outer conductor of the coaxial cable inside the building;
- Examples of installations inside buildings described in 6.2g, 6.2i, 6.2l and shown in Figure 2, Figure 4, Figure 5 and Figure 7 shall be equipped with a galvanic isolator separating local earth from the cable network distribution lines;
- Galvanic isolators shall withstand the following requirements:
- Applying a 50 Hz AC voltage of 300 V_{RMS} between the input and the output of the outer conductor of the galvanic isolator for a period of not less than 20 min, the leakage current shall not exceed 8 mA_{RMS}. Applying a continues DC voltage of 2 120 V between the input and the output of the outer conductor of the galvanic isolator for a period of not less than 1 min, the leakage current shall not exceed 0,7 mA.

It shall not be possible to touch metallic parts of the galvanic isolator when connected.

6.3 ZC.2 Norway

ZC.2.1 Justification

In most parts of Norway, the AC mains power are built as an IT- or TT-network with a line-to-line voltage of 230 V (see Figure ZC.1).

These types of networks have no N-conductor, and the AC mains power is supplied to the equipment from two of the three line conductors (IEC 60950-1:2005, Annex V).




Figure ZC.1 – IT power distribution system in Norway

For a cable network covering an area with this type of power supply networks, special initiative should be taken to ensure that safety in the cable network is maintained. The following equipotential bonding arrangements described will provide necessary safety in such a network.

ZC.2.2 Equipotential bonding mechanism for cable networks

ZC.2.2.1 Installations in the vicinity of transformer stations

Any earth electrode in a cable network shall preferably be located at a minimum distance of 20 m from the nearest earth electrode in a high-power transformer station (high to mains voltage) (see Figure ZC.2 and ITU-T K.8 or EN 50174-3).


If the above-mentioned distance is less than 20 m, all equipment in the cable network shall be electrically isolated from local earth by mounting the equipment within a non-metallic enclosure, as shown in Figure ZC.3. Mains powered equipment with local power feeding should not be used in this case.

Before any work on the installation is started, measurements shall be carried out to reveal if there are any hazardous voltages between local earth and the earth for the cable network.

The safety sign "Warning about hazardous electrical voltage"  according to sign 7.4 of ISO 3864-1:2002 shall be attached to the non-metallic enclosure.


ZC.2.2.2 Cabinets for cable networks located near cabinets/ installations for mains

Cabinets for cable networks placed together with cabinets for mains power distributions should preferably be placed at a minimum of 2 m apart. If the distance is closer than 2 m, a common earth electrode between the cabinets shall be used. Examples of such installations are shown in Figure ZC.4, Figure ZC.5, Figure ZC.6 and Figure ZC.7.




1 Earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Mains supplied equipment
5 Transforming station	6 High-voltage power transmission system

Figure ZC.2 – Example of installations located farther than 20 m away from a transforming station




1 Earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Remotely supplied equipment
5 Transforming station	6 High-voltage power transmission system

Figure ZC.3 – Example of installations located closer than 20 m from a transforming station




1 Common earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Mains supplied equipment
5 Metallic enclosure	

Figure ZC.4 – Example of cabinets for cable network with locally fed equipment and mains placed less than 2 m apart




1 Common earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Remotely supplied equipment
5 Metallic enclosure	

Figure ZC.5 – Example of cabinets for cable network with remotely fed equipment and mains placed less than 2 m apart



1 Earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Mains supplied equipment
5 Metallic enclosure	

Figure ZC.6 – Example of cabinets for cable network with locally fed equipment and mains placed more than 2 m apart




1 Earth electrode	2 Non-metallic enclosure
3 Equipotential bonding bar	4 Remotely supplied equipment
5 Metallic enclosure	

Figure ZC.7 – Example of cabinets for cable network with remotely fed equipment and mains placed more than 2 m apart

ZC.2.3 Use of galvanic isolation in a cable network with remote power-feeding

When using galvanic isolation in cable networks with remote power feeding, the amplifier shall be placed in front of the galvanic isolator as shown in Figure ZC.8.



1 Galvanic isolator	2 Non-metallic enclosure
3 Voltage dependent protection device	4 Common earth electrode
5 CATV system	6 House internal cable-TV network

Figure ZC.8 – Example of an installation placing the amplifier in front of the galvanic isolator

A voltage dependent protective device is recommended in order to protect the galvanic isolator from transient voltages.

The amplifier shall be electrically isolated from the local electrical earth. In case the amplifier is mounted close to either local electrical earth or installations connected to local electrical earth, the amplifier shall be placed in such a way that it is not possible to physically touch both the amplifier and the installation without having to remove a cover or other safety arrangements. The covers and amplifiers shall be labelled with the safety sign given under ZC.2.2.1. The covers used shall be designed in such a way that they can only be removed using a key or a special tool.

ZC.2.4 Use of voltage dependent protective device in a cable network

Network, property and health shall be protected against failure in isolation between infrastructures with different levels of voltage and other unwanted high voltages caused by any kind of high voltage distribution networks or atmospheric discharges.

Depending on the voltages time span, all voltages with local earth as a reference shall be limited according to following values:


0 to 200 ms	1 030 V
201 to 350 ms	780 V
351 to 500 ms	650 V
501 to 1 000 ms	430 V
1 001 to 2 000 ms	300 V
2 001 to 3 000 ms	250 V

3 001 to 5 000 ms	200 V
5 001 to 10 000 ms	150 V
More than 10 000 ms	60 V

In Norway, network installations with no mains supplied equipment are usually installed isolated from local earth due to difficult ground conditions. When calculations show that the voltage level will rise above 650 V, measures must be taken to reduce the voltage level. This can be done by connecting a voltage dependent device between the network installation and local earth. The voltage dependent device must not connect the installations to local earth in case of a short circuit in mains power.

This implies a safe threshold voltage of 420 V.

Examples of protections using a voltage depending device are shown in Figure 3 and Figure ZC.9.



1 Amplifier / passive equipment	2 Equipotential bonding conductor
3 Voltage dependent protection device	4 Common earth electrode
5 Pylon	

Figure ZC.9 – Example of protection using a voltage depending device on network installations on poles

12.3 ZC.3 Finland

The required wind pressure value is 700 N/m² for buildings up to 30 m.



IEC 60728-11

Edition 4.0 2016-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Cable networks for television signals, sound signals and interactive services –
Part 11: Safety**

**Réseaux de distribution par câbles pour signaux de télévision, signaux de
radiodiffusion sonore et services interactifs –
Partie 11: Sécurité**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Cable networks for television signals, sound signals and interactive services –
Part 11: Safety**

**Réseaux de distribution par câbles pour signaux de télévision, signaux de
radiodiffusion sonore et services interactifs –
Partie 11: Sécurité**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.060.40

ISBN 978-2-8322-3161-6

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms, definitions, symbols and abbreviations.....	10
3.1 Terms and definitions.....	10
3.2 Symbols.....	17
3.3 Abbreviations.....	17
4 Fundamental requirements.....	18
4.1 General.....	18
4.2 Mechanical requirements.....	19
4.3 Accessible parts.....	19
4.4 Laser radiation.....	19
5 Protection against environmental influences.....	19
6 Equipotential bonding and earthing.....	19
6.1 General requirements.....	19
6.2 Equipotential bonding mechanisms.....	19
6.3 Equipotential bonding in meshed systems.....	30
6.3.1 References to other standards.....	30
6.3.2 General on AC mains.....	30
6.3.3 AC power distribution and connection of the protective conductor.....	30
6.3.4 Dangers and malfunction.....	30
6.3.5 Measures.....	31
7 Mains-supplied equipment.....	31
8 Remote power feeding in cable networks.....	32
8.1 Remote power feeding.....	32
8.1.1 Maximum allowed voltages.....	32
8.1.2 General requirements for equipment.....	32
8.1.3 Current-carrying capacity and dielectric strength of the components.....	32
8.2 Remote powering from subscriber premises.....	33
9 Protection against contact and proximity to electric power distribution systems.....	33
9.1 General.....	33
9.2 Overhead lines.....	33
9.2.1 Overhead lines up to 1 000 V.....	33
9.2.2 Overhead lines above 1 000 V.....	34
9.3 House installations up to 1 000 V.....	34
10 System outlets and transfer points.....	34
10.1 General.....	34
10.2 System outlet.....	35
10.2.1 Types of system outlets.....	35
10.2.2 Fully isolated system outlet.....	35
10.2.3 Semi-isolated system outlet.....	35
10.2.4 Non-isolated system outlet with protective element.....	35
10.2.5 Non-isolated system outlet without protective element.....	36
10.2.6 Fully-isolated system outlet provided by means of a FTTH system.....	36

10.3	Transfer point	36
11	Protection against atmospheric overvoltages and elimination of potential differences	37
11.1	General.....	37
11.2	Protection of the antenna system.....	38
11.2.1	Selection of appropriate methods for protection of antenna systems.....	38
11.2.2	Building equipped with a lightning protection system (LPS)	39
11.2.3	Building not equipped with an LPS	47
11.3	Earthing and bonding of the antenna system.....	51
11.3.1	Internal protection system	51
11.3.2	Earthing conductors	51
11.3.3	Earth termination system.....	54
11.4	Overvoltage protection	56
12	Mechanical stability	57
12.1	General requirements.....	57
12.2	Bending moment	58
12.3	Wind-pressure values	59
12.4	Mast construction	59
12.5	Data to be published	59
Annex A	(informative) Earth loop impedance	61
A.1	General.....	61
A.2	Earthing for fault conditions.....	61
A.3	Earthing to protect against hazardous touch voltage	62
A.4	Temporary safety measures	63
Annex B	(informative) Use of shield wires to protect installations with coaxial cables.....	64
B.1	General.....	64
B.2	Soil quality determines shield-wiring necessity.....	64
B.3	Protective measures against direct lightning strikes on under ground cables	64
Annex C	(informative) Differences in some countries	67
C.1	Subclause 6.1	67
C.1.1	France	67
C.1.2	Japan	67
C.2	Subclause 6.2.....	67
C.2.1	France	67
C.2.2	Norway	67
C.2.3	Japan and Poland	67
C.3	Subclause 6.3 – Norway.....	67
C.3.1	Justification	67
C.3.2	Equipotential bonding mechanism for cable networks.....	68
C.3.3	Use of galvanic isolation in a cable network with remote power-feeding.....	73
C.3.4	Use of voltage dependent protective device in a cable network	73
C.4	Subclause 8.1.1 – Japan	75
C.5	Subclause 9.1 – France.....	75
C.6	Subclause 9.2 – Japan	75
C.7	Subclause 10.1	75
C.7.1	Sweden	75
C.7.2	UK.....	75
C.8	Subclause 10.2 – Japan	75

C.9	Subclause 11.1 – Japan	76
C.10	Subclause 11.2	76
C.10.1	Germany	76
C.10.2	Japan	76
C.11	Subclause 11.3.2 – Japan	77
C.12	Subclause 11.3.3 – Japan	77
C.13	Subclause 12.2 – Japan	77
C.14	Subclause 12.3 – Finland	78
	Bibliography	79
	Figure 1 – Example of equipotential bonding and earthing of a metal enclosure inside a non-conductive cabinet for outdoor-use	21
	Figure 2 – Example of equipotential bonding of a building installation	22
	Figure 3 – Example of equipotential bonding and indirect earthing of a metal enclosure inside a non-conductive cabinet for outdoor-use	23
	Figure 4 – Example of equipotential bonding and earthing of a building installation (underground connection)	25
	Figure 5 – Example of equipotential bonding and earthing of a building installation (above ground connection)	26
	Figure 6 – Example of equipotential bonding with a galvanic isolated cable entering a building (underground connection)	27
	Figure 7 – Example of maintaining equipotential bonding whilst a unit is removed	29
	Figure 8 – MDU building installed with FTTH technology	36
	Figure 9 – Areas of antenna-mounting in or on buildings, where earthing is not mandatory	38
	Figure 10 – Flow chart for selection of the appropriate method for protecting the antenna system against atmospheric overvoltages	41
	Figure 11 – Example of equipotential bonded headends and antennas in a protected volume of the building LPS	43
	Figure 12 – Example of equipotential bonded headends and antennas in a protected volume of the building LPS	44
	Figure 13 – Example of equipotential bonded headends and antennas in a protected volume of an external isolated ATS	45
	Figure 14 – Example of equipotential bonded antennas (not installed in a protected volume) and headend with direct connection to building LPS	46
	Figure 15 – Example of equipotential bonded headend and earthed antennas (building without LPS)	49
	Figure 16 – Example of bonding for antennas and headend (building without LPS and lightning risk lower than or equal to the tolerable risk)	50
	Figure 17 – Example of protecting an antenna system (not installed in a protected volume) by additional bonding conductors ($R > R_T$)	53
	Figure 18 – Examples of earthing mechanisms (minimum dimensions)	56
	Figure 19 – Example of an overvoltage protective device for single dwelling unit	57
	Figure 20 – Example of bending moment of an antenna mast	58
	Figure A.1 – Systematic of earth loop resistance	62
	Figure B.1 – Principle of single shield wire	65
	Figure B.2 – Principle of two shield wires	66
	Figure C.1 – IT power distribution system in Norway	68

Figure C.2 – Example of installations located farther than 20 m away from a transforming station	69
Figure C.3 – Example of installations located closer than 20m from a transforming station	70
Figure C.4 – Example of cabinets for cable network with locally fed equipment and mains placed less than 2 m apart	71
Figure C.5 – Example of cabinets for cable network with remotely fed equipment and mains placed less than 2 m apart	71
Figure C.6 – Example of cabinets for cable network with locally fed equipment and mains placed more than 2 m apart	72
Figure C.7 – Example of cabinets for cable network with remotely fed equipment and mains placed more than 2m apart	72
Figure C.8 – Example of an installation placing the amplifier in front of the galvanic isolator	73
Figure C.9 – Example of protection using a voltage depending device on network installations on poles	74
Figure C.10 – Example of the installation of a safety terminal in Japan	76
Figure C.11 – Examples of installation of a lightning protection system in Japan	77
Table 1 – Maximum allowed operation voltages and maximum recommended currents for coaxial cables in the EN 50117 series	33
Table 2 – Solutions for protection of antenna systems against atmospheric overvoltages	39
Table B.1 – Conductivity of different types of soil.....	64
Table B.2 – Protection factors (K_p) of protection measures against direct lightning strokes for buried cables.....	65

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**CABLE NETWORKS FOR TELEVISION SIGNALS,
SOUND SIGNALS AND INTERACTIVE SERVICES –****Part 11: Safety****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60728-11 has been prepared by technical area 5: Cable networks for television signals, sound signals and interactive services, of IEC technical committee 100: Audio, video and multimedia systems and equipment.

This fourth edition cancels and replaces the third edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition.

- Correction of minimum cross-section of bonding conductor in Figure 6, Figure 14 and Figure 17.
- Verbal modification of 11.3.1.2.

- Creation of new symbols for “overvoltage protective device – (OPD)” and for “coaxial overvoltage protective device – (COPD)”.
- Introduction of new OPD symbol to 3.2, Figure 3 and Figure 6.
- Introduction of new COPD symbol to 3.2 and Figure 19.
- In 3.1 replacement of terms CATV, MATV and SMATV by new terms and definitions due to changes in technology and use of cable networks.
- New Figures 18a to 18d.
- Deletion of Figure 19.
- Extension for remote feeding voltage on subscriber feeder.
- Adaption to Edition 2.0 of the IEC 62305 series.
- Deletion of informative Annex C and normative reference to the simplified software for the calculation of risk due to lightning (Annex J of IEC 62305-2:2006¹).
- New subclause 10.2.6 Fully-isolated system outlet provided by means of a FTTH system.

The text of this standard is based on the following documents:

FDIS	Report on voting
100/2592/FDIS	100/2636/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The list of all the parts of the IEC 60728 series, under the general title *Cable networks for television signals, sound signals and interactive services*, can be found on the IEC website.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

¹ IEC 62305-2:2006, *Protection against lightning – Part 2: Risk management*

INTRODUCTION

Standards and other deliverables of the IEC 60728 series deal with cable networks including equipment and associated methods of measurement for headend reception, processing and distribution of television and sound signals and for processing, interfacing and transmitting all kinds of data signals for interactive services using all applicable transmission media. These signals are typically transmitted in networks by frequency-multiplexing techniques.

This includes for instance

- regional and local broadband cable networks,
- extended satellite and terrestrial television distribution networks and systems
- individual satellite and terrestrial television receiving systems,

and all kinds of equipment, systems and installations used in such cable networks, distribution and receiving systems.

The extent of this standardization work is from the antennas and/or special signal source inputs to the headend or other interface points to the network up to the terminal input of the customer premises equipment.

The standardization work will consider coexistence with users of the RF spectrum in wired and wireless transmission systems.

The standardization of any user terminals (i.e. tuners, receivers, decoders, multimedia terminals, etc.) as well as of any coaxial, balanced and optical cables and accessories thereof is excluded.

CABLE NETWORKS FOR TELEVISION SIGNALS, SOUND SIGNALS AND INTERACTIVE SERVICES –

Part 11: Safety

1 Scope

This part of IEC 60728 deals with the safety requirements applicable to fixed sited systems and equipment. As far as applicable, it is also valid for mobile and temporarily installed systems, for example, caravans.

Additional requirements may be applied, for example, referring to

- electrical installations of buildings and overhead lines,
- other telecommunication services distribution systems,
- water distribution systems,
- gas distribution systems,
- lightning systems.

This standard is intended to provide specifically for the safety of the system, personnel working on it, subscribers and subscriber equipment. It deals only with safety aspects and is not intended to define a standard for the protection of the equipment used in the system.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60364-1, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-4-44, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-52, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60364-5-54, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60728-2, *Cable networks for television signals, sound signals and interactive services – Part 2: Electromagnetic compatibility for equipment*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 60825-2, *Safety of laser products – Part 2: Safety of optical fibre communication systems (OFCS)*

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

IEC 60990, *Methods of measurement of touch current and protective conductor current*

IEC 61140:2001, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61140:2001/AMD1:2004

IEC 62305 (all parts), *Protection against lightning*

IEC 62305-2:2010, *Protection against lightning – Part 2: Risk management*

IEC 62305-3:2010, *Protection against lightning – Part 3: Physical damage to structures and life hazard*

IEC 62305-4:2010, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

ISO 3864-1:2011, *Graphical symbols – Safety colours and safety signs – Part 1: Design principles for safety signs in workplaces and public areas*

EN 50117 (all parts), *Coaxial cables*

EN 50164-1, *Lightning Protection Components (LPC) – Part 1: Requirements for connection components*

EN 50164-2, *Lightning Protection Components (LPC) – Part 2: Requirements for conductors and earth electrodes*

EN 50174-2, *Information technology – Cabling installation – Part 2: Installation planning and practices inside buildings*

EN 50310, *Application of equipotential bonding and earthing in buildings with information technology equipment*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN