

<b>STN</b>	<b>Elektrické inštalácie nízkeho napätia Časť 4-41: Zaistenie bezpečnosti Ochrana pred zásahom elektrickým prúdom</b>	<b>STN 33 2000-4-41</b>  33 2000
------------	-------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 01/18

Obsahuje: HD 60364-4-41:2017, IEC 60364-4-41:2005, IEC 60364-4-41:2005/AMD1:2017

Oznámením tejto normy sa od 07.07.2020 ruší  
STN 33 2000-4-41 z októbra 2007

**125860**

---

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2018  
Podľa zákona č. 264/1999 Z. z. o technických požiadavkách na výrobky a o posudzovaní zhody a o zmene a doplnení niektorých zákonov v znení neskorších predpisov sa slovenská technická norma a časti slovenskej technickej normy môžu rozmnožovať alebo rozširovať len so súhlasom slovenského národného normalizačného orgánu.



HARMONIZATION DOCUMENT

**HD 60364-4-41**

DOCUMENT D'HARMONISATION

HARMONISIERUNGSDOKUMENT

July 2017

ICS 13.260; 91.140.50

Supersedes HD 60364-4-41:2007

English Version

**Low-voltage electrical installations -  
Part 4-41: Protection for safety - Protection against  
electric shock  
(IEC 60364-4-41:2005 , modified + A1:2017 , modified)**

Installations électriques à basse tension -  
Partie 4-41: Protection pour assurer la sécurité - Protection  
contre les chocs électriques  
(IEC 60364-4-41:2005 , modifiée + A1:2017 , modifiée)

Errichten von Niederspannungsanlagen -  
Teil 4-41: Schutzmaßnahmen - Schutz gegen  
elektrischen Schlag  
(IEC 60364-4-41:2005 , modifiziert + A1:2017 , modifiziert)

This Harmonization Document was approved by CENELEC on 2016-12-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## HD 60364-4-41:2017

### European foreword

The text of document 64/2147/FDIS, future IEC 60364-4-41:2005/A1, prepared by IEC/TC 64, Electrical installations and protection against electric shock, was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as HD 60364-4-41:2017.

A draft amendment, which covers common modifications to IEC 60364-4-41:2005/A1 (64/2147/FDIS), was prepared by CLC/TC 64 "Electrical installations and protection against electric shock", was submitted to the formal vote and approved by CENELEC.

A further draft amendment, prepared by WG 09, Disconnection times and related matters, of CLC/TC 64 "Electrical installations and protection against electric shock", was submitted to the formal vote.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-01-07
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-07-07

Annexes ZA and ZB have been added by CENELEC.

In this document, the common modifications to the International Standard are indicated by a vertical line in the left margin of the text.

This Harmonization Document supersedes HD 60364-4-41:2007.

HD 60364-4-41:2017 includes the following significant technical changes with respect to HD 60364-4-41:2007:

- The requirements of clause 411.3.1.2, relating to protective bonding, have been revised in a number of respects.
- Clause 411.3.2.1 now requires that the device providing automatic disconnection in the event of a fault shall be suitable for isolation of at least the line conductors.
- The disconnection times referred to in clause 411.3.2.2 now apply also to final circuits with a rated current not exceeding 63 A with one or more socket-outlets.
- Certain requirements of clause 411.3.2.5 relating to where it is not feasible for an overcurrent protective device to interrupt the supply or the use of a residual current protective device (RCD) for this purpose are not appropriate have been relocated to an annex (Annex D) and modified.
- The range of rated currents of socket-outlets that are required by clause 411.3.3 to be provided with additional protection by means of a residual current protective device (RCD) with a rated residual operating current not exceeding 30 mA has been extended up to 32 A.
- A new clause, 411.3.4, requires that lighting circuits of a TN or TT system in single household premises shall be provided with protection by a residual current protective device with a rated residual operating current not exceeding 30 mA.
- The note in clause 411.4.4 now gives product standard numbers and certain other particulars for residual current devices for use in connection with the requirements of

the clause.

- In clause 411.6.2, relating to earthing of exposed-conductive-parts in IT systems, the condition  $R_A \times I_d \leq 120 \text{ V}$  for d.c. systems has been deleted.
- The requirements of clause 411.6.3.1 for fault protection in IT systems have been revised in a number of respects.
- The requirements of clause 412.2.4.1 for wiring systems providing basic protection and fault protection considered to meet the requirements for the protective measure of double or reinforced insulation have been revised in a number of respects.
- The former content of Annex D, relating to correspondence between IEC 60364-4-41:2001 and IEC 60364-4-41:2005, has been deleted and is replaced by content relating to provisions where automatic disconnection according to clause 411.3.2 is not feasible.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Annexes which are additional to those in IEC 60364-4-41:2005/A1:2017 are prefixed "Z".

### Endorsement notice

The text of the International Standard IEC 60364-4-41:2005/A1:2017 was approved by CENELEC as a Harmonization Document with agreed common modifications.

---

**HD 60364-4-41:2017****Contents**

European foreword .....	2
410 Introduction .....	5
410.1 Scope.....	6
410.2 Normative references .....	6
410.3 General requirements.....	7
411 Protective measure: automatic disconnection of supply .....	8
411.1 General .....	8
411.2 Requirements for basic protection .....	8
411.3 Requirements for fault protection .....	8
411.4 TN systems .....	10
411.5 TT systems.....	11
411.6 IT systems.....	12
411.7 Functional extra-low voltage (FELV).....	14
412 Protective measure: double or reinforced insulation.....	15
412.1 General .....	15
412.2 Requirements for basic protection and fault protection .....	15
413 Protective measure: electrical separation .....	17
413.1 General .....	17
413.2 Requirements for basic protection .....	18
413.3 Requirements for fault protection.....	19
414 Protective measure: extra-low-voltage provided by SELV and PELV.....	18
414.1 General .....	18
414.2 Requirements for basic protection and fault protection .....	19
414.3 Sources for SELV and PELV .....	19
414.4 Requirements for SELV and PELV circuits.....	19
415 Additional protection.....	21
415.1 Additional protection: residual current protective devices (RCDs).....	21
415.2 Additional protection: supplementary protective equipotential bonding.....	21
Annex A (normative) Provisions for basic protection (protection against direct contact) .....	22
Annex B (normative) Obstacles and placing out of reach .....	23
Annex C (normative) Protective measures for application only when the installation is controlled or under the supervision of skilled or instructed persons.....	24
Annex D (normative) Provisions where automatic disconnection according to 411.3.2 is not feasible .....	28
Annex E (informative) List of notes concerning certain countries .....	
Bibliography.....	37
Annex ZA (normative) Special national conditions.....	29
Annex ZB (informative) A-deviations .....	34
Figure B.1 - Zone of arm's reach.....	23
Table 41.1 - Maximum disconnection times.....	9

## **410 Introduction**

This Part 4-41 of HD 60364 deals with protection against electric shock as applied to electrical installations. It is based on EN 61140 which is a basic safety standard that applies to the protection of persons and livestock. EN 61140 is intended to give fundamental principles and requirements that are common to electrical installations and equipment or are necessary for their co-ordination.

The fundamental rule of protection against electric shock, according to EN 61140, is that hazardous-live-parts must not be accessible and accessible conductive parts must not be hazardous live, neither under normal conditions nor under single fault conditions.

According to 4.2 of EN 61140, protection under normal conditions is provided by basic protective provisions and protection under single fault conditions is provided by fault protective provisions. Alternatively, protection against electric shock is provided by an enhanced protective provision, which provides protection under normal conditions and under single fault conditions.

This standard in accordance with IEC Guide 104 has the status of a group safety publication (GSP) for protection against electric shock.

## HD 60364-4-41:2017

### 410.1 Scope

Part 4-41 of HD 60364 specifies essential requirements regarding protection against electric shock, including basic protection (protection against direct contact) and fault protection (protection against indirect contact) of persons and livestock. It deals also with the application and co-ordination of these requirements in relation to external influences.

Requirements are also given for the application of additional protection in certain cases.

### 410.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-5-52, *Electrical installations of buildings – Part 5-52: Selection and erection of electrical equipment - Wiring systems*

HD 60364-5-54, *Electrical installations of buildings – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors* (IEC 60364-5-54, modified)

HD 60364-6, *Low-voltage electrical installations – Part 6: Verification* (IEC 60364-6, modified)

EN 60439-1, *Low-voltage switchgear and controlgear assemblies* (IEC 60439-1)

IEC 60449, *Voltage bands for electrical installations of buildings*

IEC 60614 (all parts), *Conduits for electrical installations - Specification*

IEC 61084 (all parts), *Cable trunking and ducting systems for electrical installations*

EN 61140, *Protection against electric shock – Common aspects for installation and equipment* (IEC 61140)

EN 61386 (all parts), *Conduit systems for cable management* (IEC 61386 – all parts)

EN 61558-2-6, *Safety of power transformers, power supply units and similar – Part 2-6: Particular requirements for safety isolating transformers for general use* (IEC 61558-2-6)

IEC Guide 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**