

# Energetická hospodárnosť budov Regulácia vykurovacích systémov Časť 5: Spínacie zariadenia na programovo riadené zapnutie - vypnutie vykurovacích systémov Moduly M3-5,6,7,8

STN EN 12098-5

06 0330

Energy Performance of Buildings - Controls for heating systems - Part 5: Start-stop schedulers for heating systems - Modules M3-5,6,7,8

Táto norma obsahuje anglickú verziu európskej normy. This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 12/17

Obsahuje: EN 12098-5:2017

Oznámením tejto normy sa ruší STN EN 12098-5 (06 0330) z apríla 2006

# EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 12098-5

May 2017

ICS 91.140.10; 97.120

Supersedes EN 12098-5:2005

### **English Version**

# Energy Performance of Buildings - Controls for heating systems - Part 5: Start-stop schedulers for heating systems - Modules M3-5.6.7.8

Performance énergétique des bâtiments - Régulation pour les systèmes de chauffage - Partie 5 : Programmateurs d'intermittences pour les systèmes de chauffage - Modules M3-5, 6, 7, 8 Energetische Bewertung von Gebäuden - Mess-, Steuerund Regeleinrichtungen für Heizungen - Teil 5: Schalteinrichtungen zur programmierten Ein- und Ausschaltung von Heizungsanlagen - Module M3-5, 6,

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 12098-5:2017 E

Con	tents	Page
Europ	oean foreword	4
Introd	duction	5
1	Scope	6
2	Normative references	8
3	Terms and definitions	
4	Symbols, subscripts and abbreviations	
* 4.1	Symbols	
4.2	Subscripts	
5	Functionality	11
6	Requirements	
6.1	Data protection	
6.2	Scheduler operating modes	
6.3	Start-stop switch times	14
6.3.1	Timers	
6.3.2	Clock schedulers	
6.3.3	Exception handling	
6.3.4	Start period	
6.3.5	Tariff compensation	
6.4	Parameter setting facilities	
6.5	Factory settings	
6.6	Switching output relays	
6.7	Electrical requirements	
6.7.1	General	
6.7.2	Supply voltage	
6.7.3	Protection against electric shock	
6.7.4	Electromagnetic compatibility	
6.7.5	Degree of protection	
6.7.6	Electrical power consumption	
6.7.7	Environmentally induced stress due to temperature	
6.7.8	Materials	
6.8	Use of graphical symbols	
7	Test methods	
7.1	General	
7.2	Data protection	
7.3	Scheduler operating modes	
7.4	Start-stop switch times	
7.4.1	General	
7.4.2	Timers	
7.4.3	Clock schedulers	
7.4.4	Exception handling	
7.4.5	Start period	
7.4.6 7.5	Tariff compensation	
7.5 7.6	Manual operationParameter setting facilities	
/ .n	rarameter secung facilities	Z(

7.7	Factory settings	20
8	Marking	20
9	Documentation	21
9.1	Technical documents	21
9.2	Technical specifications	21
9.3	Instruction for installation	
9.4	Instruction for operator	22
Bibli	iography	23

# **European foreword**

This document (EN 12098-5:2017) has been prepared by Technical Committee CEN/TC 247 "Building Automation, Controls and Building Management", the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2017, and conflicting national standards shall be withdrawn at the latest by November 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12098-5:2005.

This document has been prepared under a mandate [12] given to CEN by the European Commission and the European Free Trade Association.

This document is part of the set of standards on the energy performance of buildings (the set of EPB standards).

In case this standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements.

Further target groups are users of the voluntary common European Union certification scheme for the energy performance of non-residential buildings (EPBD art.11.9) and any other regional (e.g. Pan European) parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

#### Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called "EPB set of standards".

As part of the "EPB set of standards" it complies with the requirements for the set of basic EPB documents EN ISO 52000-1 (see Normative references), CEN/TS 16628 and CEN/TS 16629 (see bibliography [2] and [3]) developed under a mandate given to CEN by the European Commission and the European Free Trade Association (Mandate M/480).

The standards issued by TC 247 for M/480 belong to the EPB set of standards and are in line with the over-arching standard (EN ISO 52000-1) and drafted in accordance with the basic principles and detailed technical rules developed in the Phase I of the mandate.

Also these standards are clearly identified in the modular structure developed to ensure a transparent and coherent EPB standard set. BAC (Building Automation and Control) is identified in the modular structure as Technical Building System M10. However, the standards of TC 247 deal with control accuracy, control functions and control strategies using standards communications protocol (these last standards do not belong to the EPB standards set).

To avoid a duplication of calculation due to the BAC (avoid double impact), no calculation are done in BAC EPB standard set, but in each underlying standard of EPB set of standards (from M1 to M9 in the Modular Structure), an IDENTIFIER developed and present in the M10 covered by EN 15232-1 is used where appropriate. These way of interaction is described in detailed in the Technical Report (CEN ISO/TR 52000-2) accompanying the over-arching standard. As consequence, the Annex A and Annex B concept as EXCEL sheet with the calculation formulas used in the EPB standards are not applicable for the standards issued by TC 247 for M/480.

The main target groups of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 12098-8 [5]).

This second edition cancels and replaces the first edition EN 12098-5:2005.

The most important changes are:

- respect the presentation of the project in the frame EPB in accordance with the drafting rules;
- modify classification of clocks A to E for a new classification based on periodicity: daily, weekly, yearly, introducing new requirements for digital, networked clocks;
- for homogeneity with EN 12098-1, EN 12098-3 and many other TC247 standards: deletion of block schematic describing functions in details.

## 1 Scope

This European Standard applies to scheduling equipment for heating systems. The signals can be processed by using either analogue or digital techniques, or both.

It applies to start-stop scheduling functions and sets minimum acceptable standards for functions, performance and documentation.

NOTE 1 The start-stop function can be integrated within a main control device. In this case, the controller would be expected to this standard for scheduling function.

Safety requirements on heating systems and heating control systems remain unaffected by this European Standard. The actuators and the dynamic behaviour of the valves are not covered in this European Standard. This control equipment may or may not be connected to a data network.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 2 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 3 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively.

Table 1 — Position of this standard (in casu M3-5,6,7,8), within the modular structure of the set of EPB standards

Sub1   M1   M2   M3   M4   M5   M6   M7   M8   M9   M10   M2		Over-arching	Building (as such)	Technical Building System									
Common terms and definitions; symbols, units and subscripts   Suilding Energy Needs   Suilding Energy Performance   Suilding Energy Energy Performance   Suilding Energy Energy Performance   Suilding Energy Energy Energy Performance   Suilding Energy Energy Energy Energy Performance   Suilding Energy Energonance Energy Energy Energonance Energy Energonan	Submodule	Descriptions	Descriptions	Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot waters	Lighting	Building automation and control	PV, wind,
2 Common terms and definitions; symbols, units and subscripts  3 Application  (Free) Indoor Conditions without Systems  4 Ways to Express Energy Performance  Building Functions and Building Occupancy and Operating Conditions  Transmission  6 Building Occupancy and Operating Conditions  Aggregation of Energy Performance  7 Aggregation of Energy Performance  Building Partitioning  Solar Heat Gains  Control  X Calculated Energy Performance  Building Occupancy and Operating Conditions  Maximum Load and Power  Ways to Express Energy Performance  Express Energy Performance  Emission and x control  X Carriers  Storage and control  X Carriers  Building Occupancy and Operating Conditions  Solar Heat Gains  Control  X Calculated Energy Performance  Building Dynamics (thermal mass)  Calculated Energy Performance  Measured Energy Performance  The Measured Energy Performance  Inspection  Inspection  Inspection  Inspection  Inspection  Inspection  BMS	sub1	M1	M2		М3	M4	М5	М6	M7	М8	М9	M10	M11
and definitions; symbols, units and subscripts  Application  (Free) Indoor Conditions without Systems  Application  (Free) Indoor Conditions without Systems  Application  (Free) Indoor Conditions without Systems  Energy Performance  Ways to Express Energy Performance  Building Building Boundaries  Building Occupancy and Operating Conditions Orditions  Aggregation of Energy Services and Energy Carriers  Building Partitioning  Solar Heat Gains Control  Calculated Energy Performance  Measured Energy Performance	1	General	General	General									
Application   Conditions without Systems   Maximum Load and Power	2	and definitions; symbols, units		Needs									
Energy Performance   Express Energy   Expr	3	Application	Conditions										
Functions and Building Boundaries  Building Occupancy and Operating Conditions  Aggregation of Energy Services and Energy Performance  Building Occupancy and Operating Conditions  Aggregation of Energy Services and Energy Performance  Building Occupancy and Operating Conditions  Carriers  Storage and control x  Generation and control x  Calculated Energy Performance  Building Dynamics (thermal mass)  Load dispatching and operating conditions  Measured Energy Performance  Measured Energy Performance  Measured Energy Performance  Measured Energy Performance  Building Dynamics (thermal mass)  Storage and x Control x  Load dispatching and operating conditions  Measured Energy Performance  Building Dynamics (thermal mass)  Storage and x Control x  Menut Storage and control x  Distribution and x  Measured Denergy Performance  Energy Performance  Measured Energy Performance  Benergy Performance  BMS	4	Energy	Energy	Express Energy									
Coccupancy and Operating Conditions   Distribution and Ventilation	5	Functions and Building			х								
The Energy Services and Energy Carriers  Building Partitioning  Calculated Energy Performance  Measured Energy Performance  Energy Performance  Measured Energy Performance  Internal Heat Gains  Generation and control  Load dispatching and operating conditions  Measured Energy Performance  Energy Performance  Measured Energy Performance  Inspection  Inspection  Inspection  BMS	6	Occupancy and Operating	Infiltration and		х								
Partitioning Solar Heat Gains control X  Calculated Energy Performance (thermal mass)  Measured Measured Energy Performance Performance Performance  Inspection Inspection  Building Dynamics (thermal mass)  Control X  Load dispatching and operating conditions  Measured Energy Performance Energy Performance  Inspection Inspection  BMS	7	Energy Services and Energy			х								
9 Energy Performance (thermal mass) dispatching and operating conditions  10 Measured Energy Energy Performance Performance Performance  11 Inspection Inspection  12 Ways to Express Indoor Comfort  Building Dynamics dispatching and operating conditions  Measured Energy Performance  Energy Performance  Performance Performance  BMS	8		Solar Heat Gains		х								
10     Energy Performance     Energy Performance     Energy Performance       11     Inspection     Inspection       12     Ways to Express Indoor Comfort     BMS	9	Energy	Dynamics	dispatching and operating									
12 Ways to Express Indoor Comfort BMS	10	Energy	Energy	Energy									
12 Indoor Comfort BNIS	11	Inspection	Inspection	Inspection									
	12			BMS									
External Environment Conditions	13												
14 <sup>a</sup> Economic Calculation	<b>14</b> <sup>a</sup>												

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 52000-1:2017, Energy performance of buildings - Overarching EPB assessment - Part 1: General framework and procedures (ISO 52000-1:2017)

EN 60038, CENELEC standard voltages (IEC 60038)

EN 60529, Degrees of protection provided by enclosures (IP Code) (IEC 60529)

EN 60730-series, Automatic electrical controls for household and similar use (IEC 60730-1)

EN ISO 7345:1995, Thermal insulation - Physical quantities and definitions (ISO 7345:1987)

# koniec náhľadu – text ďalej pokračuje v platenej verzii STN