

STN	<p>Vonkajšie elektrické vedenia so striedavým napäťím nad 1 kV Časť 2-8: Národné normatívne hľadiská (NNA) pre Francúzsko (založené na EN 50341-1: 2012)</p>	<p>STN EN 50341-2-8</p>
		33 3300

Overhead electrical lines exceeding AC 1 kV - Part 2-8: National Normative Aspects (NNA) for France (based on EN 50341-1:2012)

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola označená vo Vestníku ÚNMS SR č. 02/18

Obsahuje: EN 50341-2-8:2017

126340

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2018

Podľa zákona č. 264/1999 Z. z. o technických požiadavkách na výrobky a o posudzovaní zhody a o zmene a doplnení niektorých zákonov v znení neskorších predpisov sa slovenská technická norma a časti slovenskej technickej normy môžu rozmnôžovať alebo rozširovať len so súhlasom slovenského národného normalizačného orgánu.

EUROPEAN STANDARD

EN 50341-2-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2017

ICS 29.240.20

English Version

Overhead electrical lines exceeding AC 1 kV - Part 2-8: National
Normative Aspects (NNA) for France (based on EN 50341-
1:2012)

This European Standard was approved by CENELEC on 2017-08-09.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN 50341-2-8:2017 E

Contents

European foreword	6
0 Introduction	7
1 Scope	8
1.1 General	8
1.2 Field of application	8
2 Normative references, definitions and symbols	9
2.1 Normative references	9
2.2 Definitions	10
2.3 Symbols	10
3 Basis of design	11
3.2 Requirements of overhead lines	11
3.2.2 Reliability requirements	11
3.2.5 Strength coordination	11
3.2.6 Additional considerations	11
3.3 Limit states	12
3.3.3 Serviceability limit states	12
3.7 Partial factor method and design formula	12
3.7.2 Basic design formula	12
4 Actions on lines	13
4.1 Introduction	13
4.3 Wind loads	13
4.3.1 Field of application and basic wind velocity	13
4.4 Wind forces on overhead line components	15
4.4.1 Wind forces on conductors	15
4.4.2 Wind forces on insulator sets	15
4.4.3 Wind forces on lattice towers	15
4.4.4 Wind forces on poles	16
4.5 Ice loads	16
4.5.1 General	16
4.6 Combined wind and ice loads	19
4.6.1 Combined probabilities	19
4.7 Temperature effects	20
4.8 Security loads	20
4.8.1 General	20
4.8.2 Torsional loads	20
4.8.3 Longitudinal loads	21
4.9 Safety loads	21
4.9.1 Construction and maintenance loads	21
4.9.2 Loads related to the weight of linesmen	22
4.10 Forces due to short-circuit currents	22

4.11	Other special forces	22
4.11.1	Avalanches, creeping snow	22
4.11.2	Earthquakes	22
4.12	Load cases.....	23
4.12.2	Standard load cases	23
4.13	Partial factors for actions	25
5	Electrical requirements	27
5.2	Currents	27
5.2.2	Short-circuit current.....	27
5.5	Minimum air clearances to avoid flashover.....	27
5.5.2	Application of the theoretical method in Annex E	27
5.5.3	Empirical method based on European experience	27
5.6	Load cases for calculation of clearances	28
5.6.2	Maximum conductor temperature	28
5.6.3	Wind loads for determination of electric clearances	28
5.6.3.1	Wind load cases.....	28
5.6.3.2	Nominal wind loads for determination of internal and external clearances	29
5.6.3.3	Extreme wind loads for determination of internal clearances	29
5.6.4	Ice loads for determination of electric clearances.....	29
5.6.5	Combined wind and ice loads	30
5.8	Internal clearances within the span and at the top of the support	31
5.9	External clearances	33
5.9.1	General	33
5.9.2	External clearances to ground in areas remote from buildings, roads, etc.....	34
5.9.3	External clearances to residential and other buildings	37
5.9.4	External clearances to crossing traffic routes	38
5.9.5	External clearances to adjacent traffic routes	44
5.9.6	External clearances to other power lines or overhead telecommunication lines	45
5.9.7	External clearances to recreational areas (playgrounds, sports areas, etc.)	49
5.10	Corona effect.....	50
5.10.2	Audible noise.....	50
5.10.2.3	Noise limits	50
5.10.3	Corona loss	50
5.11	Electric and magnetic fields	50
5.11.1	Electric and magnetic fields under a line	50
6	Earthing systems	51
6.1	Introduction	51
6.1.3	Earthing measures against lightning effects	51
6.4	Design calculation with regard to human safety	51
6.4.1	Permissible values for touch voltages.....	51

6.4.2	Touch voltage limits at different locations	51
6.4.3	Basic design of earthing systems with regard to permissible touch voltages ..	51
7	Supports.....	52
7.3	Lattice steel towers	52
7.3.6	Ultimate limit states	52
7.3.6.1	General	52
7.3.8	Resistance of connections	52
7.3.9	Design assisted by testing	52
7.4	Steel poles	52
7.4.6	Ultimate limit states (EN 1993-1-1:2005 – Chapter 6).....	52
7.4.6.1	General	52
7.4.8	Resistance of connections	53
7.4.8.2	Bolts (other than holding-down bolts)	53
7.4.8.3	Slip joint connections	53
7.4.8.5	Welded connections.....	53
7.4.8.6	Direct embedding into the concrete	53
7.4.9	Design assisted by testing	53
7.5	Wood poles	53
7.5.8	Design assisted by testing	53
7.6	Concrete poles	53
7.6.6	Design assisted by testing	53
7.8	Other structures	54
7.9	Corrosion protection and finishes	54
7.9.3	Metal spraying.....	54
7.10	Maintenance facilities.....	54
7.10.1	Climbing	54
7.10.3	Safety requirements	54
8	Foundations	55
8.2	Basis of geotechnical design (EN 1997-1:2004 – Section 2)	55
8.2.2	Geotechnical design by calculation.....	55
8.2.3	Design by prescriptive measures	56
8.2.4	Load tests and tests on experimental models	56
8.3	Soil investigation and geotechnical data (EN 1997 1:2004 – Section 3).....	56
8.6	Interactions between support foundations and soil.....	56
9	Conductors and earth wires.....	57
9.1	Introduction	57
9.2	Aluminium-based conductors.....	57
9.2.3	Conductor service temperature and grease characteristics	57
9.2.4	Mechanical requirements	57
9.3	Steel-based conductors	57
9.3.3	Conductor service temperature and grease characteristics	57
9.3.4	Mechanical requirements	58

9.5	Conductors and earth wires containing optical fibre telecommunication circuits	58
9.5.3	Conductor service temperatures.....	58
9.5.4	Mechanical requirements.....	58
10	Insulators	59
10.2	Standard electrical requirements	59
11	Hardware	60
11.9	Characteristics and dimensions of fittings	60
12	Quality assurance, checks and taking-over.....	61
Annex J (normative)	Angles in lattice steel towers.....	62
Annex K (normative)	Steel poles	63
Annex M (informative)	Geotechnical and structural design of foundations	64

European foreword

- 1 The French National Committee (NC) is identified by the following address:
AFNOR Normalisation
Département Electrotechnologies
11, rue Francis de Pressensé
93571 La Plaine Saint-Denis Cedex
Tel.: +33 (0)1 41 62 80 00
Fax: +33 (0)1 49 17 90 00
www.afnor.org
- 2 The French NC has prepared the present EN 50341-2-8:2017 (Part 2-8), listing the French National Normative Aspects; it is solely responsible for it and has duly incorporated it into the procedures of CENELEC and CLC/TC 11.

Note The French NC takes full responsibility for the satisfactory technical coordination of the present Part 2-8 and EN 50341-1:2012. Any quality control/assurance checks necessary have been performed. However, it should be noted that such quality control/assurance has been performed under the general responsibility of the French NC pursuant to national laws and regulations.

- 3 Part 2-8 is normative in France and informative for other countries.
- 4 Part 2-8 shall be read in conjunction with EN 50341-1:2012 (Part 1). All Clause numbers used in the present Part 2-8 correspond to the numbering in Part 1. Specific subclauses with the prefix "FR" shall be read as amendments to the associated text in Part 1. All requests for clarification relating to the application of Part 2-8 in relation to Part 1 shall be sent to the French NC which, in conjunction with CLC/TC 11, will clarify the requirements.

When no reference is made to a specific subclause in Part 2-8, Part 1 applies.

- 5 For the "boxed values" defined in Part 1, any amended values defined in Part 2-8 shall be applied in France. None of the boxed values present in Part 1 or Part 2-8 shall be amended in such a way as to increase the risk in a Project Specification.
- 6 The regulations and standards specifically used in the present Part 2-8 and relating to overhead electrical lines exceeding AC 1 kV are listed in subclauses 2.1/FR.1 to 2.1/FR.6.

NOTE All national standards referred to in the present Part 2-8 will be replaced by the related European Standards as they become available and are declared applicable by the French NC and therefore reported to the secretariat of CLC/TC 11.

0 Introduction

Part 1 applies without change.

1 Scope**1.1 General****(ncpt) FR.1 Scope of Part 1 and Part 2-8**

Part 1 and the present Part 2-8 apply to new overhead lines as defined in 1.1/FR.2 "Definition of a new overhead line".

(ncpt) FR.2 Definition of a new overhead line

A new overhead line denotes any new overhead electrical line exceeding AC 1 kV built on new foundations and:

- flanked by two substations or two terminal towers preceding said substations.
- or
- flanked by a substation or a terminal tower at one end and in a branch situation (including branch tower) or tapping situation at the other end.

(ncpt) FR.3 Application to existing overhead lines

This standard does not apply to existing overhead lines exceeding AC 1 kV in France.

(ncpt) FR.4 Application to overhead lines for which technical studies are underway

Any decision to apply the requirements of the present standard to new overhead line projects for which technical studies are underway shall be stipulated in the Project Specification.

(ncpt) FR.5 Application to overhead lines under construction

The requirements of the present standard do not apply to overhead lines under construction.

1.2 Field of application**(ncpt) FR.1 Application to radio telecommunication equipment**

Part 1 and Part 2-8 apply to radio telecommunication equipment mounted on the towers of new overhead lines, particularly with respect to wind and ice assumptions. Radio equipment shall be arranged on the support so that it can be accessed and operations performed in accordance with safety regulations.

2 Normative references, definitions and symbols

2.1 Normative references

(a-dev) **FR.1 Interministerial Decree of 17 May 2001**

The Interministerial Decree of 17 May 2001, published in the Official Journal of the French Republic of 12 June 2001, contains the minimum requirements for the distribution and transmission of power.

The (a-dev) subclauses of the present Part 2-8 refer to the Interministerial Decree of 17 May 2001 and form a brief description thereof. Reference should be made to the original document for details of the requirements of the Interministerial Decree.

(a-dev) **FR.2 Law no. 91-1414 of 31 December 1991**

Law no. 91-1414 of 31 December 1991 amends the French Employment Code and the French Public Health Code to promote the prevention of occupational risks, and transposes EU directives relating to occupational health and safety.

(a-dev) **FR.3 Law no. 93-1418 of 31 December 1993**

Law no. 93-1418 of 31 December 1993 amends the provisions of the French Employment Code applicable to building and civil engineering operations to ensure the safety and protect the health of workers, and transposes Council Directive no. 92/57/EEC of 24 June 1992. Said directive relates to the implementation of minimum safety and health requirements at temporary or mobile construction sites.

(a-dev) **FR.4 Interministerial Decree of 14 May 1963**

The Interministerial Decree of 14 May 1963 specifies the characteristics of the safety data plates to be affixed to power line supports.

(ncpt) **FR.5 Standards**

Reference	Title
NF C11-201	<i>Réseaux de distribution publique d'énergie électrique [Public electrical power systems]</i>
NF C18-510	<i>Opérations sur les ouvrages et installations électriques et dans un environnement électrique - Prévention du risque électrique [Operations on electrical networks and installations and in an electrical environment - Electrical risk prevention]</i>
NF EN 50540	<i>Conductors for overhead lines. Aluminium conductors steel supported (ACSS)</i>
NF EN 61672-1	<i>Electroacoustics. Sound level meters. Part 1: Specifications</i>
NF P94-261	<i>Justification of geotechnical work - National application standards for the implementation of Eurocode 7 - Shallow Foundations - Geotechnical design</i>
NF P94-262	<i>Justification of geotechnical work - National application standards for the implementation of Eurocode 7 - Deep Foundations</i>
NF S31-010	<i>Acoustics - Environmental noise characterization and measurement. Special measuring methods</i>
UTE C11-001	<i>Conditions techniques auxquelles doivent satisfaire les distributions d'énergie électrique [Technical conditions to be met by electrical power distribution systems] – Illustrated Technical Decree of 17 May 2001</i>

(ncpt) **FR.6 Reference national standards**

Standard UTE C11-001 reproduces, annotates and illustrates the Interministerial Decree of 17 May 2001 (see 2.1/FR.1). Certain subclauses (a-dev or ncpt) of the present Part 2-8 are taken from this standard.

Standard NF C11-201 defines the construction rules for the structures (overhead lines, underground networks and substations) forming electrical power distribution networks with a nominal voltage of less than AC 50 kV. Certain subclauses (ncpt) of the present Part 2-8 are taken from this standard.

The requirements relating to human safety in relation to electrical hazards during electrical or non-electrical operations, on networks or installations or in an environment the voltage of which is less than or equal to 500 kV AC or DC, are given in NF C18-510. The present Part 2-8 is not intended to replace the provisions of this standard.

(ncpt)

FR.7 Scientific publications

[1] Ducloux, H. and Figueroa, L.: Background information about the wind action model of CENELEC EN 50341-1 (2012) and associated expected reliability of electrical overhead lines, *Journal of Wind Engineering and Industrial Aerodynamics*, Volume 157, Pages 104-117, October 2016, ISSN 0167-6105, doi:10.1016/j.jweia.2016.08.006.

[2] Ducloux, H. and Nygaard, B. E.: 50-year return-period wet-snow load estimation based on weather station data for overhead line design in France, *Nat. Hazards Earth Syst. Sci.*, Volume 14 Issue 11, Pages 3031-3041, November 2014, ISSN 3031-3041, doi:10.5194/nhess-14-3031-2014.

[3] Chaigneau, L. and Ducloux, H.: Justification du coefficient de modèle $\gamma_{R;d1}$ utilisé dans la norme NF EN 50341-2-8 pour le dimensionnement des micropieux de catégorie 18 utilisés comme fondations de pylônes de lignes électriques aériennes [Justification of the model factor $\gamma_{R;d1}$ used in NF EN 50341-2-8 for the design calculation of category 18 micropiles used as overhead power line tower foundations], *Revue Française de Géotechnique*, Volume 147, Article number 4, October 2016, DOI: 10.1051/geotech/2016008

koniec náhl'adu – text d'alej pokračuje v platenej verzii STN