

STN	Plynomery Turbínové plynometry	STN EN 12261
		25 7864

Gas meters - Turbine gas meters

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola označená vo Vestníku ÚNMS SR č. 08/18

Obsahuje: EN 12261:2018

Oznámením tejto normy sa ruší
STN EN 12261 (25 7864) z februára 2004

127108

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 12261

March 2018

ICS 91.140.40

Supersedes EN 12261:2002

English Version

Gas meters - Turbine gas meters

Compteurs de gaz - Compteurs de gaz à turbine

Gaszähler - Turbinenradgaszähler

This European Standard was approved by CEN on 9 November 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	5
1 Scope	6
2 Normative references	6
3 Terms, definitions and symbols	7
3.1 Terms and definitions	7
3.2 Symbols	10
4 Meter classification	11
4.1 Flange pressure ratings	11
4.2 Gas meter sizes, rangeability and connection diameter sizes	12
4.3 Connections and dimensions	13
4.4 Temperature ranges	13
4.5 Climatic environment	13
5 Metrological performance requirements	13
5.1 General	13
5.2 Type testing	14
5.2.1 Error of indication	14
5.2.2 Metrological stability	15
5.2.3 Linearity	16
5.2.4 Endurance	16
5.2.5 Meter position	17
5.2.6 Temporary overload	17
5.2.7 Temperature range	17
5.2.8 Installation conditions	19
5.2.9 Maximum permissible pressure loss	19
5.2.10 Output shaft (where fitted)	20
6 Design and material requirements	20
6.1 General	20
6.2 Robustness	21
6.2.1 General	21
6.2.2 Meter casing	21
6.2.3 Resistance to internal pressure	21
6.2.4 External leak tightness	22
6.2.5 Bending and torsional moment	23
6.2.6 Resistance to impact	24
6.2.7 Transportation and storage	24
6.3 Resistance to environmental conditions	25
6.3.1 General	25
6.3.2 Resistance to ultra-violet radiation	25
6.3.3 Resistance to external corrosion	25
6.4 Removable meter mechanisms	28
6.4.1 Integrity	28
6.4.2 Performance	29
6.5 Indicating devices and accessories	29

6.5.1	General.....	29
6.5.2	Magnetic drive units.....	30
6.6	Pressure and temperature tappings	30
6.6.1	Pressure tappings	30
6.6.2	Temperature tappings	31
6.7	Lubrication	31
6.7.1	Requirements	31
6.7.2	Type test	31
7	Meter output	32
7.1	General.....	32
7.2	Indicating device	32
7.2.1	General.....	32
7.2.2	Capacity.....	32
7.2.3	Unit of indication.....	32
7.2.4	Readability.....	32
7.2.5	Adjustment	33
7.3	Pulse generator.....	33
7.3.1	General.....	33
7.3.2	Electrical specifications for pulse generators	33
7.3.3	Electrical connections.....	34
7.4	Output shaft.....	34
7.5	Test element.....	35
7.5.1	General provisions.....	35
7.5.2	Test element in case of mechanical indicating device	35
7.5.3	Pulse generator used as test element	35
8	Marking.....	36
8.1	General.....	36
8.2	Data plate	36
8.3	Direction of flow	36
8.4	Working position.....	36
8.5	Other connections	37
8.5.1	General.....	37
8.5.2	Pressure tappings	37
8.5.3	Pulse generators.....	37
8.5.4	Output shafts.....	37
9	Documentation.....	37
9.1	General.....	37
9.2	Declaration of conformity	37
9.3	Instruction manual	38
	Annex A (normative) Test facility specifications.....	39
A.1	Test medium	39
A.2	Leakage	39
A.3	Installation conditions	39
A.4	Reference standards	39
	Annex B (normative) Perturbation testing	40
B.1	General.....	40
B.2	Terms and definitions	40

B.3 Requirements	40
B.3.1 Low level perturbation.....	40
B.3.2 High level perturbation.....	41
B.4 Tests.....	41
B.4.1 Low level perturbations.....	41
B.4.2 High level perturbations.....	43
B.5 Similarity.....	44
B.6 Flow conditioner.....	44
Annex C (informative) Recommendations for use	46
C.1 Pressure loss	46
C.2 Spin test	46
C.3 Locations of temperature measuring devices.....	46
Annex D (normative) Individual factory testing	47
D.1 General.....	47
D.2 Meter report.....	47
Annex E (normative) Metrological requirements and tests for each meter prior to dispatch (Individual meter testing)	48
E.1 Information required from the purchaser (user)	48
E.2 Determination of number of tests	48
E.2.1 Criteria	48
E.3 Error of indication	49
E.3.1 Requirements	49
E.3.2 Test	50
E.4 Linearity	50
E.4.1 Requirements	50
E.4.2 Test	50
E.5 Weighted mean error (WME).....	50
E.5.1 Requirement	50
E.5.2 Test	50
E.5.3 Adjustment	51
E.6 Data plate specification.....	51
E.7 Test certificate.....	51
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2014/32/EU Measuring Instruments Directive aimed to be covered	53
Bibliography	60

European foreword

This document (EN 12261:2018) has been prepared by Technical Committee CEN/TC 237 "Gas meters", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2018, and conflicting national standards shall be withdrawn at the latest by September 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12261:2002.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

In the preparation of this European Standard, the content of ISO 9951, the content of OIML Publication, "International Recommendation 6" and "International Recommendation 32" and the content of member bodies national standards on turbine meters have been taken into account.

The metrological aspects of this European Standard may be subject to amendments to bring it into line with the proposed Measuring Instruments Directive (MID).

Electronic Indexes are not specifically covered by this standard, however, work to produce a standard covering these devices is in progress under CEN/TC 237.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This document specifies the measuring conditions, requirements and tests for the construction, performance and safety of class 1,0 axial and radial turbine gas meters with mechanical indicating devices, herein after referred to as a meter(s), having in-line pipe connections for gas flow measurement.

This document applies to turbine gas meters used to measure the volume of fuel gases of the 1st and 2nd gas families, the composition of which is specified in EN 437, at maximum working pressures up to 420 bar, actual flow rates up to 25 000 m³/h over a gas temperature range of at least 40 K and for a climatic environmental temperature range of at least 50 K.

This document applies to meters that are installed in locations with vibration and shocks of low significance and in

- closed locations (indoor or outdoor with protection as specified by the manufacturer) with condensing or with non-condensing humidity

or, if specified by the manufacturer,

- open locations (outdoor without any covering) with condensing humidity or with non-condensing humidity

and in locations with electromagnetic disturbances.

Unless otherwise specified in this document:

- all pressures used are gauge;
- all influence quantities, except the one under test, are kept relatively constant at their reference value.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 10204, *Metallic products — Types of inspection documents*

EN 22768-1:1993, *General tolerances — Part 1: Tolerances for linear and angular dimensions without individual tolerance indications (ISO 2768-1:1989)*

EN 60079-0, *Explosive atmospheres — Part 0: Equipment — General requirements (IEC 60079-0)*

EN 60079-11, *Explosive atmospheres — Part 11: Equipment protection by intrinsic safety "i" (IEC 60079-11)*

EN 60529, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*

EN 60947-5-6, *Low-voltage switchgear and controlgear — Part 5-6: Control circuit devices and switching elements — DC interface for proximity sensors and switching amplifiers (NAMUR) (IEC 60947-5-6)*

EN 62246-1, *Reed switches — Part 1: Generic specification (IEC 62246-1)*

EN ISO 5167-1:2003, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 1: General principles and requirements (ISO 5167-1:2003)*

ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

koniec náhľadu – text d'alej pokračuje v platenej verzii STN