

|            |   |  |
|------------|---|--|
| <b>STN</b> | <b>Merače tepelnej energie</b><br><b>Časť 1: Všeobecné požiadavky</b> | <b>STN</b><br><b>EN 1434-1+A1</b><br><br>25 8512 |
|------------|---|--|

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 04/19

Obsahuje: EN 1434-1:2015+A1:2018

Oznámením tejto normy sa ruší  
STN EN 1434-1 (25 8512) z decembra 2016

**128314**

EUROPEAN STANDARD

**EN 1434-1:2015+A1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2018

ICS 17.200.10

English Version

**Thermal energy meters - Part 1: General requirements**Compteurs d'énergie thermique - Partie 1 :  
Prescriptions générales

Wärmezähler - Teil 1: Allgemeine Anforderungen

This European Standard was approved by CEN on 5 September 2015 and includes Amendment 1 approved by CEN on 18 July 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

| <b>Contents</b>  | <b>Page</b> |
|--|-------------|
| European foreword.....   | 4           |
| <b>1 Scope</b> .....   | <b>6</b>    |
| <b>2 Normative references</b> .....  | <b>6</b>    |
| <b>3 Terms and definitions</b> .....   | <b>6</b>    |
| <b>4 Types of instruments</b> .....  | <b>11</b>   |
| 4.1 General.....   | 11          |
| 4.2 Complete instrument.....   | 11          |
| 4.3 Combined instrument.....   | 11          |
| 4.4 Hybrid instrument.....   | 11          |
| 4.5 Sub-assemblies of a $\square_{A1}$ thermal energy meter $\square_{A1}$ , which is a combined instrument..... | 11          |
| 4.5.1 General.....   | 11          |
| 4.5.2 Flow sensor.....   | 12          |
| 4.5.3 Temperature sensor pair.....   | 12          |
| 4.5.4 Calculator.....  | 12          |
| 4.6 Equipment under test (EUT).....  | 12          |
| <b>5 Rated operating conditions</b> .....  | <b>12</b>   |
| 5.1 Limits of temperature range.....   | 12          |
| 5.2 Limits of temperature differences.....   | 12          |
| 5.3 Limits of flow rate.....   | 12          |
| 5.4 Limit of thermal power.....  | 13          |
| 5.5 Limits of working pressure ( $P_S$ and $P_{min}$ ).....  | 13          |
| 5.6 Nominal pressure (PN).....   | 13          |
| 5.7 Limits in ambient temperature.....   | 13          |
| 5.8 Limits in deviations in supply voltage.....  | 13          |
| 5.9 Maximum pressure loss.....   | 13          |
| 5.10 Specific requirements on registration devices.....  | 13          |
| 5.10.1 General.....  | 13          |
| 5.10.2 Suitability.....  | 13          |
| 5.10.3 Rated operated conditions.....  | 14          |
| 5.10.4 Indication.....   | 14          |
| 5.10.5 MPE.....  | 15          |
| <b>6 Technical characteristics</b> .....   | <b>15</b>   |
| 6.1 Materials and construction.....  | 15          |
| 6.2 Requirements outside the limiting values of the flow rate.....   | 16          |
| 6.3 Display.....   | 16          |
| 6.4 Protection against fraud.....  | 17          |
| 6.5 Supply voltage.....  | 17          |
| 6.6 Qualifying immersion depth of a temperature sensor.....  | 17          |
| 6.7 The influence on a temperature sensor pair caused by mounting in pockets.....                                | 17          |
| 6.8 Reproducibility.....   | 17          |
| 6.9 Repeatability.....   | 18          |
| 6.10 Software.....   | 18          |
| <b>7 Specified working range</b> .....   | <b>18</b>   |
| 7.1 General.....   | 18          |

|   |   |    |
|---|---|----|
| 7.2   | Temperature difference.....   | 18 |
| 7.3   | Flow rate .....   | 18 |
| 8   | Heat transmission formula .....   | 18 |
| 9   | Metrological characteristics (Maximum Permissible Error, MPE).....  | 19 |
| 9.1   | General .....   | 19 |
| 9.2   | Values of maximum permissible errors .....  | 19 |
| 9.2.1   | Maximum permissible relative errors of complete $\square_{A_1}$ thermal energy meters $\square_{A_1}$ ..... | 19 |
| 9.2.2   | Maximum permissible relative error of sub-assemblies .....  | 20 |
| 9.3   | Application of maximum permissible errors .....   | 20 |
| 10  | Environmental classification.....   | 21 |
| 10.1  | General .....   | 21 |
| 10.2  | Environmental class A (Domestic use, indoor installations).....   | 21 |
| 10.3  | Environmental class B (Domestic use, outdoor installations) .....   | 21 |
| 10.4  | Environmental class C (Industrial installations) .....  | 21 |
| 10.5  | Mechanical classes M1 to M3 .....   | 21 |
| 11  | $\square_{A_1}$ Thermal energy meter $\square_{A_1}$ specification .....                                    | 22 |
| 11.1  | General .....   | 22 |
| 11.2  | Flow sensor .....   | 22 |
| 11.3  | Temperature sensor pair.....  | 23 |
| 11.4  | Calculator.....   | 24 |
| 11.5  | Complete meters.....  | 25 |
| 12  | Information to be made available by the manufacturer or supplier .....                                      | 27 |
| 12.1  | Installation instructions.....  | 27 |
| 12.2  | Parameter setting instructions.....   | 28 |
| 12.3  | Adjustment instructions .....   | 28 |
| 12.4  | Maintenance instructions.....   | 29 |
| 12.5  | Hints for disposal instructions .....   | 29 |
| Annex A (normative) Heat coefficient equations .....  |   | 30 |
| Annex B (normative) Flow conditioner package.....   |   | 32 |
| Annex C (normative) Fast response meters.....   |   | 34 |
| Annex ZA (informative) Relationship between this European Standard and the essential requirements of Directive 2014/32/EU aimed to be covered ..... |   | 35 |
| Bibliography .....  |   | 38 |

**EN 1434-1:2015+A1:2018 (E)****European foreword**

This document (EN 1434-1:2015+A1:2018) has been prepared by Technical Committee CEN/TC 176 “Thermal energy meters”, the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2019, and conflicting national standards shall be withdrawn at the latest by May 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1, approved by CEN on 2018-07-18.

This document supersedes A1 EN 1434-1:2015 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For relationship with EU Directive, see informative Annex ZA, which is an integral part of this document.

EN 1434, A1 *Thermal energy meters* A1 consists of the following parts:

- *Part 1: General requirements*
- *Part 2: Constructional requirements*
- *Part 3: Data exchange and interfaces<sup>1)</sup>*
- *Part 4: Pattern approval tests*
- *Part 5: Initial verification tests*
- *Part 6: Installation, commissioning, operational monitoring and maintenance*

In comparison to EN 1434-1:2007, the following changes have been made:

- special cases for combined A1 bifunctional thermal energy meters A1 are added;
- additional functionality for smart metering applications are added;
- metrological requirements for smart metering applications are added;
- definitions and requirements for the cooling meter are added;
- tariff meters are added;

---

<sup>1)</sup> EN 1434-3 is maintained by CEN/TC 294.

- terms and definitions, requirements for registration devices and cooling meters are added;
- requirements for fast response meters are added (informative Annex C).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**EN 1434-1:2015+A1:2018 (E)****1 Scope**

This European Standard specifies the general requirements for **A1** thermal energy meters **A1**. **A1** Thermal energy meters **A1** are instruments intended for measuring the energy which in a heat-exchange circuit is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The **A1** thermal energy meter **A1** indicates the quantity of heat in legal units.

Electrical safety requirements are not covered by this European Standard.

Pressure safety requirements are not covered by this European Standard.

Surface mounted temperature sensors are not covered by this European Standard.

This standard covers meters for closed systems only, where the differential pressure over the thermal load is limited.

**2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

**A1** EN 1434-2:2015+A1:2018, *Thermal energy meters — Part 2: Constructional requirements* **A1**

**A1** EN 1434-4:2015+A1:2018, *Thermal energy meters — Part 4: Pattern approval test* **A1**

EN 60751, *Industrial platinum resistance thermometers and platinum temperature sensors (IEC 60751)*

EN 61010-1, *Safety requirements for electrical equipment for measurement, control and laboratory use — Part 1: General requirements (IEC 61010-1)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**