

<b>STN</b>	<b>Vysokonapäťové spínacie a riadiace zariadenia Zvárané kryty zložené zo zliatin hliníka na odliatky a na tvárnenie izolované plynom</b>	<b>STN EN 50069</b>  35 7179
------------	---	--

High-voltage switchgear and controlgear - Gas-filled welded composite enclosures of cast and wrought aluminium alloys

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 06/19

Obsahuje: EN 50069:2018

Oznámením tejto normy sa od 03.09.2021 ruší  
STN EN 50069+A1 (35 7179) z januára 2002

**128883**

EUROPEAN STANDARD

**EN 50069**

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2018

ICS 29.130.10

Supersedes EN 50069:1991

English Version

## High-voltage switchgear and controlgear - Gas-filled welded composite enclosures of cast and wrought aluminium alloys

Appareillage électrique haute tension - Enveloppes soudées en alliage d'aluminium comportant des parties moulées et des parties en métal corroyé sous pression de gaz

Hochspannungs-Schaltgeräte und Schaltanlagen - Geschweißte, gasgefüllte Kapselungen von Teilen aus Aluminium-Guss und Aluminium-Knetlegierungen

This European Standard was approved by CENELEC on 2018-09-03. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

<b>Contents</b>		<b>Page</b>
<b>European foreword</b> .....		<b>3</b>
<b>Introduction</b> .....		<b>4</b>
<b>1</b>	<b>Scope</b> .....	<b>5</b>
<b>2</b>	<b>Normative references</b> .....	<b>5</b>
<b>3</b>	<b>Terms and definitions</b> .....	<b>6</b>
<b>4</b>	<b>Quality assurance</b> .....	<b>9</b>
<b>5</b>	<b>Normal and special service conditions</b> .....	<b>9</b>
<b>6</b>	<b>Materials</b> .....	<b>9</b>
<b>6.1</b>	<b>Selection of material</b> .....	<b>9</b>
<b>6.2</b>	<b>Chemical analysis</b> .....	<b>11</b>
<b>7</b>	<b>Design</b> .....	<b>12</b>
<b>7.1</b>	<b>General</b> .....	<b>12</b>
<b>7.2</b>	<b>Calculation methods</b> .....	<b>12</b>
<b>7.3</b>	<b>Inspection and access openings</b> .....	<b>12</b>
<b>8</b>	<b>Manufacture and workmanship</b> .....	<b>12</b>
<b>9</b>	<b>Repair of welding defects</b> .....	<b>12</b>
<b>10</b>	<b>Inspection, testing and certification</b> .....	<b>12</b>
<b>10.1</b>	<b>Type tests</b> .....	<b>12</b>
<b>10.2</b>	<b>Inspection and routine tests</b> .....	<b>12</b>
<b>10.3</b>	<b>Welding procedure specifications</b> .....	<b>13</b>
<b>10.4</b>	<b>Welder performance tests</b> .....	<b>13</b>
<b>10.5</b>	<b>Non-destructive testing</b> .....	<b>13</b>
<b>10.6</b>	<b>Design specification, drawings and data sheets</b> .....	<b>13</b>
<b>10.7</b>	<b>Certificate</b> .....	<b>13</b>
<b>10.8</b>	<b>Stamping</b> .....	<b>13</b>
<b>10.9</b>	<b>Final inspection</b> .....	<b>13</b>
<b>11</b>	<b>Pressure relief devices</b> .....	<b>13</b>
<b>Annex A (informative) A-deviation</b> .....		<b>14</b>
<b>Bibliography</b> .....		<b>15</b>

## European foreword

This document (EN 50069:2018) has been prepared by CLC/TC 17AC, "*High-voltage switchgear and controlgear*".

The following dates are fixed:

- latest date by which this document has (dop) 2019-09-03  
to be implemented at national level by  
publication of an identical national  
standard or by endorsement
- latest date by which the national (dow) 2021-09-03  
standards conflicting with this document  
have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 50069:1991 and EN 50069:1991/A1:1993.

This document has been revised by CENELEC Technical Committee 17AC, "High-voltage switchgear and controlgear". It supplements the relevant product standards on gas-insulated switchgear and controlgear in that it provides specific requirements for pressurized high-voltage switchgear and controlgear.

The present EN has been written to get a European specification for the design, construction, testing, inspection and certification of pressurized enclosures used in high-voltage switchgear and controlgear.

In this respect, this document constitutes the exclusion of HV switchgear from the scope of the Directive 2014/68/EU (superseding 97/23/EC) concerning pressure equipment. Article 1, 2. (l) excludes "enclosures for high-voltage electrical equipment such as switchgear, controlgear, transformers, and rotating machines" from the scope of the Directive.

This standard deals with gas-filled welded composite enclosures of cast and wrought aluminium alloys. For different enclosure materials, other European Standards are available.

## Introduction

This document covers the requirements for the design, construction, testing, inspection and certification of gas-filled enclosures for use specifically in high-voltage switchgear and controlgear, or for associated gas-filled equipment.

Special consideration is given to these enclosures for the following reasons.

- (a) The enclosures usually form the containment of electrical equipment, thus their shape is determined by electrical rather than mechanical requirements.
- (b) The enclosures are installed in restricted access areas and the equipment is operated by instructed, authorized persons only.
- (c) As the thorough drying of the inert, non-corrosive gas-filling medium is fundamental to the satisfactory operation of the electrical equipment, the gas is periodically checked. For this reason, no internal corrosion allowance is required on the wall thickness of these enclosures.
- (d) The enclosures are subjected to only small fluctuations of pressure as the gas-filling density will be maintained within close limits to ensure satisfactory insulating and arc-quenching properties. Therefore, the enclosures are not liable to fatigue due to pressure cycling.
- (e) The operating pressure is relatively low.

Due to the foregoing reasons and to ensure maximum service continuity as well as to reduce the risk of moisture and dust entering the enclosures which could endanger safe electrical operation of the switchgear, no pressure tests should be carried out after installation and before placing in service and no periodic inspection of the enclosure interiors or pressure tests should be carried out after the equipment is placed in service.

## 1 Scope

This document applies to welded composite enclosures of cast and wrought aluminium alloy pressurized with dry air, inert gases (e.g. sulphur hexafluoride or nitrogen or a mixture of such gases), used in indoor and outdoor installations of high-voltage switchgear and controlgear with rated voltages above 1 kV, where the gas is used principally for its dielectric and/or arc-quenching properties with rated voltages:

- above 1 kV and up to and including 52 kV concerning gas-filled compartments with design pressure higher than 300 kPa relative pressure (gauge);
- above 52 kV concerning all gas-filled compartments.

The enclosures comprise parts of electrical equipment not necessarily limited to the following examples:

- circuit-breakers;
- switch-disconnectors;
- disconnectors;
- earthing switches;
- current transformers;
- voltage transformers;
- surge arrestors;
- busbars and connections;
- etc.

The scope also covers enclosures of pressurized components such as the centre chamber of live tank switchgear, gas-insulated current transformers, etc.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13445-8:2014, *Unfired pressure vessels - Part 8: Additional requirements for pressure vessels of aluminium and aluminium alloys*

EN 50052:2016, *High-voltage switchgear and controlgear - Gas-filled cast aluminium alloy enclosures*

EN 50064:2018, *High-voltage switchgear and controlgear — Gas-filled wrought aluminium and aluminium alloy enclosures*

EN 62271-1:2017, *High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear (IEC 62271-1:2017)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**