

STN	Stupne ochrany krytom (krytie - IP kód) Zmena A2/Oprava AC	STN EN 60529/A2/AC 33 0330
------------	---	--

Degrees of protection provided by enclosures (IP code)

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 06/19

Obsahuje: EN 60529:1991/A2:2013/AC Feb.:2019, IEC 60529:1989/AMD2:2013/COR1:2019

128897

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN
60529:1991/A2:2013/AC:2019
-02

February 2019

ICS 13.260; 29.020

English Version

Degrees of protection provided by enclosures (IP Code)
(IEC 60529:1989/A2:2013/COR1:2019)

Degrés de protection procurés par les enveloppes (Code
IP)
(IEC 60529:1989/A2:2013/COR1:2019)

Schutzarten durch Gehäuse (IP-Code)
(IEC 60529:1989/A2:2013/COR1:2019)

This corrigendum becomes effective on 22 February 2019 for incorporation in the English language version of the EN.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Endorsement notice

The text of the corrigendum IEC 60529:1989/A2:2013/COR1:2019 was approved by CENELEC as EN 60529:1991/A2:2013/AC:2019-02 without any modification.

IEC 60529:1989/AMD2:2013/COR1:2019 – 1 –

© IEC 2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 60529
Amendment 2 to Edition 2.0 2013-08

IEC 60529
Amendement 2 à l'Édition 2.0 2013-08

DEGREES OF PROTECTION PROVIDED BY
ENCLOSURES (IP CODE)

DEGRÉS DE PROTECTION PROCURÉS PAR LES
ENVELOPPES (CODE IP)

CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

6 Degrees of protection against ingress of water indicated by the second characteristic numeral

After the instruction "Replace the seventh paragraph by the following", replace the text by the following new text:

An enclosure designated with second characteristic numeral 7 or 8 only is considered unsuitable for exposure to water jets (designated by second characteristic numeral 5 or 6) and need not comply with requirements for numeral 5 or 6 unless it is multiple coded. An enclosure designated with second characteristic numeral 9 only is considered unsuitable for exposure to water jets (designated by second characteristic numeral 5 or 6) and immersion in water (designated by second characteristic numeral 7 or 8) and need not comply with requirements for numeral 5, 6, 7 or 8 unless it is multiple coded as follows: