

STN	<p>Priemyselné komunikačné siete Špecifikácie prevádzkových zberníc Časť 3-21: Definícia služieb údajovej vrstvy Prvky typu 21</p>	<p>STN EN IEC 61158-3-21</p>
		18 4020

Industrial communication networks - Fieldbus specifications - Part 3-21: Data-link layer service definition - Type 21 elements

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola označená vo Vestníku ÚNMS SR č. 09/19

Obsahuje: EN IEC 61158-3-21:2019, IEC 61158-3-21:2019

Oznámením tejto normy sa od 29.05.2022 ruší
STN EN 61158-3-21 (18 4020) z decembra 2012

129502

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 61158-3-21

June 2019

ICS 25.040.40; 35.100.20; 35.110

Supersedes EN 61158-3-21:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 3-21: Data-link layer service definition - Type 21 elements
(IEC 61158-3-21:2019)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 3-21: Définition des services de
couche liaison de données - Eléments de Type 21
(IEC 61158-3-21:2019)

Industrielle Kommunikationsnetze - Feldbusse - Teil 3-21:
Dienstfestlegungen des Data Link Layer
(Sicherungsschicht) - Typ 21-Elemente
(IEC 61158-3-21:2019)

This European Standard was approved by CENELEC on 2019-05-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61158-3-21:2019 (E)**European foreword**

The text of document 65C/945/FDIS, future edition 2 of IEC 61158-3-21, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-3-21:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-02-29
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-05-29

This document supersedes EN 61158-3-21:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61158-3-21:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- IEC 61158-1:2019 NOTE Harmonized as EN IEC 61158-1:2019 (not modified)
IEC 61158-5-21:2019 NOTE Harmonized as EN IEC 61158-5-21:2019 (not modified)
IEC 61784-2:2019 NOTE Harmonized as EN IEC 61784-2:2019 (not modified)
IEC 61918:2018 NOTE Harmonized as EN IEC 61918:2018 (not modified)

Annex ZA
(normative)**Normative references to international publications
with their corresponding European publications**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 7498-1	-	Information technology - Open Systems-Interconnection - Basic reference model: The basic model		-
ISO/IEC 7498-3	-	Information technology - Open Systems-Interconnection - Basic Reference Model: Naming and addressing		-
ISO/IEC 10731	-	Information technology - Open Systems-Interconnection - Basic Reference Model - Conventions for the definition of OSI services		-
ISO/IEC/IEEE 8802--3		Standard for Ethernet	-	-

**IEC 61158-3-21**

Edition 2.0 2019-04

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 3-21: Data-link layer service definition – Type 21 elements**





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.



INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 3-21: Data-link layer service definition – Type 21 elements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.20; 35.110

ISBN 978-2-8322-6790-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	5
INTRODUCTION	7
1 Scope	8
1.1 Overview	8
1.2 Specifications	8
1.3 Conformance	8
2 Normative references	9
3 Terms, definitions, symbols, abbreviations, and conventions	9
3.1 Reference model terms and definitions	9
3.2 Service convention terms and definitions	11
3.3 Common data-link service terms and definitions	12
3.4 Additional Type 21 data-link specific definitions	15
3.5 Common symbols and abbreviations	15
3.6 Additional Type 21 symbols and abbreviations	16
3.7 Common conventions	16
3.8 Additional Type 21 conventions	17
4 Data-link layer services and concepts	17
4.1 General	17
4.1.1 Overview	17
4.1.2 Overview of full duplex flow control	17
4.1.3 Types and classes of DL-layer service	18
4.2 Detailed description of the data service	21
4.2.1 General	21
4.2.2 Sequence of primitives	21
4.2.3 Transmit/receive data	22
4.3 Detailed description of the sporadic data service	23
4.3.1 General	23
4.3.2 Sequence of Primitive	24
4.3.3 Transmit/receive sporadic data	24
4.4 Detailed description of network control message service	25
4.4.1 General	25
4.4.2 Sequence of Primitives	25
4.4.3 Transmit/receive network control message	25
5 Data-link management services	28
5.1 General	28
5.2 Data link management service (DLMS) facilities	28
5.3 Data link management service (DLMS)	28
5.3.1 Overview	28
5.3.2 Reset	29
5.3.3 Set-value	29
5.3.4 Get-value	29
5.3.5 SAP-allocation	29
5.3.6 SAP-deallocation	29
5.3.7 Get-SAP information	29
5.3.8 Get-diagnostic-information	29
5.3.9 Event	29

5.3.10	Get-path	29
5.4	Overview of interactions.....	29
5.5	Detailed specification of service and interactions	31
5.5.1	Reset.....	31
5.5.2	Set-value	31
5.5.3	Get-value.....	32
5.5.4	SAP-allocation.....	33
5.5.5	SAP-deallocation	34
5.5.6	Get-SAP-information.....	35
5.5.7	Get-diagnostic-information.....	36
5.5.8	Event.....	37
5.5.9	Get-path	38
6	MAC control service	39
6.1	General.....	39
6.2	MAC control service	39
6.2.1	Overview	39
6.2.2	MAC-reset	39
6.2.3	MAC-forward-control.....	39
6.3	Overview of interactions.....	39
6.4	Detailed specification of service and interactions	40
6.4.1	MAC-reset	40
6.4.2	MAC-forward-control.....	41
7	Ph-control service.....	42
7.1	General.....	42
7.2	Ph-control service	42
7.2.1	Overview	42
7.2.2	Ph-reset	42
7.2.3	Ph-get-link-status	42
7.2.4	Ph-link-status-change	42
7.3	Overview of interactions.....	42
7.4	Detailed specification of service and interactions	43
7.4.1	Ph-reset	43
7.4.2	Ph-get-link-status	44
7.4.3	Ph-link-status-change	45
	Bibliography.....	46
	Figure 1 – Full-duplex flow control	18
	Figure 2 – Sequence diagram of DL-DATA service	18
	Figure 3 – Sequence diagram of DL-SPDATA service	19
	Figure 4 – Sequence diagram of NCM service primitive	19
	Figure 5 – Relationships of DLSAPs, DLSAP-addresses, and group DL-addresses	20
	Figure 6 – DL-DATA service	21
	Figure 7 – Sequence diagram of Reset, Set-value, Get-value, SAP-allocation, SAP-deallocation, Get-SAP information and Get-diagnostic information service primitives	30
	Figure 8 – Sequence diagram of Event service primitive	31
	Figure 9 – Sequence diagram of MAC-reset and MAC-forward-control service primitive.....	40
	Figure 10 – Sequence diagram of Ph-reset and Ph-get-link-status service primitive	43

Figure 11 – Sequence diagram of Ph-link-status-change service primitive 43

Table 1 – Destination DL-address	20
Table 2 – Primitives and parameters used in DL-DATA service.....	22
Table 3 – DL-DATA Primitives and Parameters	22
Table 4 – Primitives and parameters used in DL-SPDATA service	24
Table 5 – DL-SPDATA Primitives and Parameters	24
Table 6 – Primitives and parameters used on DL-NCM_SND service	25
Table 7 – DL-NCM_SND Primitives and Parameters	26
Table 8 – Summary of Network Control Message Type	27
Table 9 – Summary of DL-management primitives and parameters	30
Table 10 – DLM-RESET primitives and parameters.....	31
Table 11 – DLM-SET_VALUE primitives and parameters	32
Table 12 – DLM-GET_VALUE primitives and parameters	33
Table 13 – DLM-SAP_ALLOC primitives and parameters	34
Table 14 – DLM-SAP DEALLOC primitives and parameters	35
Table 15 – DLM-GET_SAP_INFO primitives and parameters	35
Table 16 – DLM-GET_DIAG primitives and parameters.....	36
Table 17 – DLM-EVENT primitives and parameters.....	37
Table 18 – DLM event identifier	38
Table 19 – DLM-GET_PATH primitives and parameters	38
Table 20 – Summary of MAC control primitives and parameters.....	40
Table 21 – MAC-RESET primitives and parameters	40
Table 22 – MAC-FW_CTRL primitives and parameters.....	41
Table 23 – Summary of Ph-control primitives and parameters	42
Table 24 – Ph-RESET primitives and parameters.....	43
Table 25 – Ph-GET_LINK_STATUS primitives and parameters	44
Table 26 – Ph-LINK_STATUS_CHANGE primitives and parameters.....	45

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 3-21: Data-link layer service definition –
Type 21 elements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-3-21 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- added Network Control Message Type;
- miscellaneous editorial corrections.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/945/FDIS	65C/954/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-21: Data-link layer service definition – Type 21 elements

1 Scope

1.1 Overview

This part of IEC 61158 provides the common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” in this context means the prioritized full-duplex collision-free time-deterministic communication, of which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the required time risks the failure of the applications requesting the actions, with attendant risk to equipment, plant, and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 21 data-link layer in terms of:

- the primitive actions and events of the service;
- the parameters associated with each primitive action and event, and the form that they take; and
- the interrelationships between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- The Type 21 application layer at the boundary between the application and DLLs of the fieldbus reference model;
- Systems management at the boundary between the DLL and the systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual DLL services suitable for time-critical communications, and to supplement the OSI Basic Reference Model in guiding the development of data link protocols for time-critical communications. A secondary objective is to provide migration paths from previously existing industrial communications protocols.

This document may be used as the basis for formal data link programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this document, including:

- a) The sizes and octet ordering of various multi-octet service parameters;
- b) The correlation of paired primitives for request and confirm, or indication and response.

1.3 Conformance

This document does not specify individual implementations or products, nor do they constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition document. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfils the Type 21 DLL services defined in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC/IEEE 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Standard for Ethernet*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN