

STN	<p style="text-align: center;">Bezpečnostné úschovné objekty Klasifikácia a metódy skúšania odolnosti proti požiaru Ľahké protipožiarne úschovné objekty</p>	<p style="text-align: center;">STN EN 15659</p>
		93 7709

Secure storage units - Classification and methods of test for resistance to fire - Light fire storage units

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola označená vo Vestníku ÚNMS SR č. 02/20

Obsahuje: EN 15659:2019

Oznámením tejto normy sa ruší
STN EN 15659 (93 7709) z novembra 2009

130334

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 15659

August 2019

ICS 13.220.40; 13.310

Supersedes EN 15659:2009

English Version

**Secure storage units - Classification and methods of test
for resistance to fire - Light fire storage units**

Unités de stockage en lieu sûr - Classification et
méthodes d'essais de résistance au feu - Meubles
ignifugés premier niveau

Wertbehältnisse - Klassifizierung und Methoden zur
Prüfung des Widerstandes gegen Brand - Leichte
Brandschutzschränke

This European Standard was approved by CEN on 8 March 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

	Page
European foreword.....	3
Introduction	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 Requirements, classification and locks.....	6
5 Technical design range	6
5.1 General requirements	6
5.2 Internal base of a technical design range	6
5.2.1 Accepted deviation in internal width	6
5.2.2 Accepted deviation in internal depth	7
6 Test specimen, technical documentation and correlation.....	7
6.1 Test specimen.....	7
6.2 Technical documentation.....	7
6.3 Correlation of test specimens and technical documentation.....	8
7 Test methods	8
7.1 Principle	8
7.2 Test equipment.....	8
7.3 Preparation for test.....	9
7.4 Procedure.....	11
7.4.1 Correlation.....	11
7.4.2 Fire endurance test.....	12
7.4.3 Examination	13
8 Test report.....	13
9 Marking.....	14
Annex A (informative) Calculation examples for technical design ranges.....	15
A.1 Example 1.....	15
A.2 Example 2	16
Bibliography.....	17

European foreword

This document (EN 15659:2019) has been prepared by Technical Committee CEN/TC 263 "Secure storage of cash, valuables and data media", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2020, and conflicting national standards shall be withdrawn at the latest by February 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15659:2009.

Compared with EN 15659:2009, the following changes were made:

- The protection levels were renamed from LFS 30 P and LFS 60 P to LFS 30 and LFS 60;
- that customers know the difference between this fire resistance standard and the fire resistance standard EN 1047-1, the scope of the standard was adapted;
- as the standard could lead to different interpretations in different test houses regarding the choice of test specimens a new Clause 5 and an Annex A have been added as well as Clause 6.1 has been adapted;
- due to testing knowledge gained since the publication of the standard EN 15659 in 2009 it could be seen that the depth is not as critical as the width of a specimen. Therefore, the tolerance on the depth was changed from $\pm 15\%$ to $\pm 20\%$;
- the fire exposure time now starts from the beginning of the test (7.4.2);
- the requirement for the 3 % wall tolerance has been updated in clause 5.1 (for series production) and 6.2 (for the test specimens);
- a shrinking tube for the measuring device cables is not needed anymore (7.3.3), the testing laboratory doesn't need to turn off the flames after 30 min or 60 min (7.4.2) and the photographic record shall now also include details of the interior of the test specimen. (7.4.3);
- references to the standards have been updated;
- editorial changes have been made in 3.1, 3.2, 4.1, 4.2, 6.1, 6.2 and 7.4.1.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The testing conditions given in this document provide a basis for simulating fires to determine, in a reproducible way, the fire resistance of light fire storage units at various protection levels. The protection levels enable a comparison to be made of the resistance against fire provided by different constructions.

The threshold value for the maximum temperature increase of 150 K at every measuring point in the protection levels LFS 30 and LFS 60 for light fire storage units from a starting temperature of $(21 \pm 1)^\circ\text{C}$, as defined in this document, refers to the relatively short-term stress due to high temperatures during a fire test. It is not normally experienced by paper media stored in light fire storage units in the normal and correct way.

1 Scope

This document specifies requirements for light fire storage units providing protection against fire.

The method of test is specified to determine the ability of light fire storage units to protect paper media from the effects of fire. Two levels of fire exposure periods (LFS 30 and LFS 60) are specified using the maximum temperature increase permitted within the storage space of the light fire storage unit.

Protection after the fire exposure of 30 min (LFS 30) or 60 min (LFS 60) is not ensured by this document, but by European Standard EN 1047-1. Requirements are also specified for the test specimen, the technical documentation for the test specimen, correlation of the test specimen with the technical documentation, preparation for type testing and test procedures.

A scheme to classify the light fire storage units from the test results is also given (see Table 1).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:2012, *Fire resistance tests - Part 1: General Requirements*

EN 60584-1, *Thermocouples - Part 1: EMF specifications and tolerances*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN