

STN	Skúšobné metódy na zisťovanie zvýšenia požiarnej odolnosti konštrukčných prvkov Časť 1: Vodorovné ochranné membrány	STN EN 13381-1 92 0814
------------	--	--

Test methods for determining the contribution to the fire resistance of structural members - Part 1: Horizontal protective membranes

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 10/20

Obsahuje: EN 13381-1:2020

Oznámením tejto normy sa od 01.02.2021 ruší
STN EN 13381-1 (92 0814) z augusta 2015

131594

EUROPEAN STANDARD

EN 13381-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2020

ICS 13.220.50; 79.060.20

Supersedes EN 13381-1:2014

English Version

Test methods for determining the contribution to the fire resistance of structural members - Part 1: Horizontal protective membranes

Méthodes d'essai pour déterminer la contribution à la résistance au feu des éléments de construction - Partie 1 : Membranes de protection horizontales

Prüfverfahren zur Bestimmung des Beitrages zum Feuerwiderstand von tragenden Bauteilen - Teil 1: Horizontal angeordnete Brandschutzbekleidungen

This European Standard was approved by CEN on 7 May 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	5
Introduction	7
1 Scope	8
2 Normative references	8
3 Terms and definitions, symbols and units	9
3.1 Terms and definitions	9
3.2 Symbols and units	10
4 Test equipment	10
4.1 General	10
4.2 Furnace	10
4.3 Loading equipment	11
5 Test conditions	11
5.1 General	11
5.2 Support and restraint conditions	11
5.3 Loading conditions	11
6 Test specimens	12
6.1 General	12
6.2 Fixtures and fittings	12
6.3 Horizontal protective membranes	13
6.4 Structural building members supporting horizontal protective membranes	13
6.5 Properties of test materials	15
6.6 Verification of the test specimen	15
6.7 Optional and additional plate thermometers within the cavity	16
7 Installation of the test construction	16
8 Conditioning	16
9 Application of instrumentation	16
9.1 General	16
9.2 Instrumentation for measurement of furnace temperature	16
9.3 Instrumentation for measurement of specimen temperature	16
9.4 Instrumentation for measurement of pressure	18
9.5 Instrumentation for measurement of deflection	19
9.6 Instrumentation for measurement of applied load	19
10 Test procedure	19
10.1 General	19
10.2 Furnace temperature and pressure	19
10.3 Application and control of load	19
10.4 Temperatures of test specimen	19
10.5 Deflection	19
10.6 Observations	19
10.7 Termination of the test	20
11 Test results	20

11.1	Acceptability of test results	20
11.2	Presentation of test results	20
12	Test report.....	21
13	Assessment.....	21
13.1	General.....	21
13.2	Assessment of loadbearing capacity	22
13.3	Assessment of data for calculation purposes.....	23
14	Report of the assessment	23
15	Limits of applicability of the results of the assessment	25
15.1	Type of structural building member.....	25
15.2	Type of concrete	31
15.3	Type of steel beam.....	32
15.4	Type of steel/concrete composite structures.....	32
15.5	Type of timber structure	33
15.6	Height of the cavity	33
15.7	Exposed width of test specimen.....	33
15.8	Properties of the horizontal protective membrane	33
15.9	Size of panels within the horizontal protective membrane	33
15.10	Fixtures and fittings	33
15.11	Gaps between grid members and test frame or walls	34
Annex A	(normative) Exposure to a semi-natural fire.....	40
A.1	General.....	40
A.2	Semi-natural fire source.....	40
A.3	Test equipment.....	40
A.4	Test conditions.....	41
A.5	Test specimen.....	41
A.6	Installation of the test specimen	42
A.7	Conditioning.....	42
A.8	Application of instrumentation	42
A.9	Test procedure.....	42
A.10	Test results.....	42
A.11	Test report.....	42
A.12	The assessment.....	42
A.13	The assessment report.....	43
Annex B	(normative) Measurement of properties of horizontal protective membranes and components.....	44
B.1	General.....	44
B.2	Thickness of horizontal protective membrane and its components.....	44
B.3	Density of horizontal protective membranes and components thereof.....	45
B.4	Moisture content of horizontal protective membrane and components thereof.....	46
Annex C	(normative) Test method to the smouldering fire (slow heating curve).....	47

EN 13381-1:2020 (E)

C.1	Introduction.....	47
C.2	Test equipment.....	47
C.3	Test specimens	47
C.4	Termination of test.....	47
C.5	Evaluation of the results.....	48
	Bibliography	49

European foreword

This document (EN 13381-1:2020) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2021, and conflicting national standards shall be withdrawn at the latest by January 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13381-1:2014.

The main changes with respect to the previous edition are listed below:

Clarifications regarding the following items:

- a) determination of the characteristic surface temperature curve;
- b) limits of applicability (addition of integrity and insulation performances in the tables);
- c) assessment when the semi-natural fire test is performed (Annex A).

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This document is one of a series of standards for evaluating the contribution to the fire resistance of structural members by applied fire protection materials. The other parts of this series are:

- *Part 2: Vertical protective membranes,*
- *Part 3: Applied protection to concrete members,*
- *Part 4: Applied passive protection to steel members,*
- *Part 5: Applied protection to concrete/profiled sheet steel composite members,*
- *Part 6: Applied protection to concrete filled hollow steel columns,*
- *Part 7: Applied protection to timber members,*
- *Part 8: Applied reactive protection to steel members,*
- *Part 9: Applied fire protection systems to steel beams with web openings.*

The fire protection capacity of the horizontal protective membrane can be nullified by the presence of combustible materials in the cavity above the membrane. The applicability of the results of the assessment is limited according to the quantity and position of such combustible materials within that cavity. The amount of combustible material permissible in the cavity is typically given in national regulations.

EN 13381-1:2020 (E)

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

CAUTION: The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing can be hazardous and that there is a possibility that toxic and/or harmful smoke and gases can be evolved during the test. Mechanical and operational hazards can also arise during the construction of test elements or structures, their testing and the disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

The specific health and safety instructions contained within this document should be followed.

WARNING: When performing this test method, laboratories should expect that there can be significant quantities of smoke released. This smoke release is expected to be very significant where the fire test involves timber and timber based components. Laboratories should ensure that appropriate smoke extraction facilities are provided.

EN 13381-1:2020 (E)**1 Scope**

This document specifies a test method for determining the ability of a horizontal protective membrane, when used as a fire resistant barrier, to contribute to the fire resistance of standard horizontal structural building members as defined in 6.4.2.

Test of horizontal protective membrane installed under a specific non-standard floor should be tested according to EN 1365-2.

This document contains the fire test which specifies the tests which are carried out whereby the horizontal protective membrane, together with the structural member to be protected, is exposed to a fire test according to the procedures defined herein. The fire exposure, to the temperature/time curve given in EN 1363-1, is applied from below the membrane itself.

The test method makes provision, through specified optional additional procedures, for the collection of data which can be used as direct input to the calculation of fire resistance according to the processes given within EN 1992-1-2, EN 1993-1-2, EN 1994-1-2 and EN 1995-1-2.

This document also contains the assessment which provides information relative to the analysis of the test data and gives guidance for the interpretation of the results of the fire test, in terms of loadbearing capacity criteria of the protected horizontal structural member.

In special circumstances, where specified in national building regulations, there can be a need to subject the protection material to a smouldering curve. The test for this and the special circumstances for its use are detailed in Annex C.

The limits of applicability of the results of the assessment arising from the fire test are defined, together with permitted direct application of the results to different structures, membranes and fittings.

This document applies only where there is a gap and a cavity between the horizontal protective membrane and the structural building member. Otherwise, the test methods in EN 13381-3, EN 13381-4 or EN 13381-5, as appropriate, apply.

Tests are intended to be carried out without additional combustible materials in the cavity.

Annex A gives details of assessing the performance of the ceiling when exposed to a semi-natural fire.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:2020, *Fire resistance tests — Part 1: General Requirements*

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN 1992-1-1, *Eurocode 2: Design of concrete structures — Part 1-1: General rules and rules for buildings*

EN 1992-1-2, *Eurocode 2: Design of concrete structures — Part 1-2: General rules — Structural fire design*

EN 1993-1-1, *Eurocode 3: Design of steel structures — Part 1-1: General rules and rules for buildings*

EN 1993-1-2, *Eurocode 3: Design of steel structures — Part 1-2: General rules — Structural fire design*

EN 1994-1-1, *Eurocode 4: Design of composite steel and concrete structures — Part 1-1: General rules and rules for buildings*

EN 1994-1-2, *Eurocode 4 — Design of composite steel and concrete structures — Part 1-2: General rules — Structural fire design*

EN 1995-1-1, *Eurocode 5: Design of timber structures — Part 1-1: General — Common rules and rules for buildings*

EN 1995-1-2, *Eurocode 5: Design of timber structures — Part 1-2: General — Structural fire design*

EN 312, *Particleboards — Specifications*

EN 823, *Thermal insulating products for building applications — Determination of thickness*

EN 12467, *Fibre-cement flat sheets — Product specification and test methods*

EN 13381-4, *Test methods for determining the contribution to the fire resistance of structural members — Part 4: Applied passive protection to steel members*

EN 13381-5, *Test methods for determining the contribution to the fire resistance of structural members — Part 5: Applied protection to concrete/profiled sheet steel composite member*

EN 13381-7, *Test methods for determining the contribution to the fire resistance of structural members — Part 7: Applied protection to timber members*

EN ISO 13943, *Fire safety — Vocabulary (ISO 13943)*

ISO 8421-2, *Fire protection — Vocabulary — Part 2: Structural fire protection*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN