

STN	<p style="text-align: center;">Priemyselné komunikačné siete Siete s vysokou pohotovosťou pre automatizáciu Časť 2: Protokol MRP (Media Redundancy Protocol)</p>	<p style="text-align: center;">STN EN IEC 62439-2</p>
		18 4020

Industrial communication networks - High availability automation networks - Part 2: Media Redundancy Protocol (MRP)

Táto norma obsahuje anglickú verziu európskej normy.

This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 04/22

Obsahuje: EN IEC 62439-2:2022, IEC 62439-2:2021

Oznámením tejto normy sa od 19.01.2025 ruší
STN EN 62439-2 (18 4020) z augusta 2018

134651



EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 62439-2

February 2022

ICS 25.040.40; 35.100.05

Supersedes EN 62439-2:2017 and all of its amendments
and corrigenda (if any)

English Version

Industrial communication networks - High availability automation
networks - Part 2: Media Redundancy Protocol (MRP)
(IEC 62439-2:2021)

Réseaux de communication industriels - Réseaux de haute
disponibilité pour l'automatisation - Partie 2: Protocole de
redondance du support (MRP)
(IEC 62439-2:2021)

Industrielle Kommunikationsnetze: Hochverfügbare
Automatisierungsnetze - Teil 2: Medienredundanz-Protokoll
(MRP)
(IEC 62439-2:2021)

This European Standard was approved by CENELEC on 2022-01-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 62439-2:2022 (E)**European foreword**

The text of document 65C/1118/FDIS, future edition 3 of IEC 62439-2, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62439-2:2022.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-10-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2025-01-19

This document supersedes EN 62439-2:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62439-2:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-1 NOTE Harmonized as EN IEC 61158-1

IEC 61784-1 NOTE Harmonized as EN IEC 61784-1

IEC 61784-2 NOTE Harmonized as EN IEC 61784-2

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-192	-	International Electrotechnical Vocabulary (IEV) - Part 192: Dependability	-	-
IEC 61158-6-10	2019	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	EN IEC 61158-6-10	2019
IEC 62439-1	2010	Industrial communication networks - High availability automation networks - Part 1: General concepts and calculation methods	EN 62439-1	2010
AMD1	2012		A1	2012
AMD2	2016		A2	2017
ISO/IEC 10164-1		Information technology - Open Systems Interconnection - Systems Management: Object Management Function	-	-
ISO/IEC/IEEE 8802-3		Telecommunications and exchange between information technology systems - Requirements for local and metropolitan area networks - Part 3: Standard for Ethernet	-	-
IEEE Std 802.1Q	2018	IEEE Standard for Local and Metropolitan Area Network - Bridges and Bridged Networks	-	-
IEEE Std 802.3	2018	IEEE Standard for Ethernet	-	-



IEC 62439-2

Edition 3.0 2021-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –
Part 2: Media Redundancy Protocol (MRP)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour
l'automatisation –
Partie 2: Protocole de redondance du support (MRP)**





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
 3, rue de Varembé
 CH-1211 Geneva 20
 Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
 The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
 Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
 If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 62439-2

Edition 3.0 2021-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –
Part 2: Media Redundancy Protocol (MRP)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour
l'automatisation –
Partie 2: Protocole de redondance du support (MRP)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-1057-3

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD	7
INTRODUCTION	9
1 Scope	10
1.1 General.....	10
1.2 Code component distribution.....	10
2 Normative references	11
3 Terms, definitions, abbreviated terms and conventions	11
3.1 Terms and definitions.....	11
3.2 Abbreviated terms.....	12
3.3 Conventions.....	12
4 MRP Overview.....	12
5 MRP Media redundancy behavior	16
5.1 General.....	16
5.2 Ring ports	16
5.3 Media Redundancy Manager (MRM)	17
5.4 Media Redundancy Client (MRC)	19
5.5 Redundancy domain	19
5.6 Media Link Check	19
5.7 Application of the Continuity Check protocol	20
5.7.1 General	20
5.7.2 Continuity Check Message Interval	20
5.7.3 Maintenance Domain Level.....	20
5.7.4 Maintenance Association ID (MAID).....	20
5.7.5 Maintenance Association End Point ID (MEPID)	21
5.7.6 Sender ID TLV.....	21
5.7.7 Port Status TLV	21
5.7.8 Interface Status TLV	21
5.8 Usage with diagnosis and alarms	21
5.9 Ring diagnosis	22
5.10 Multiple MRM in a single ring: Manager voting option.....	22
5.10.1 General	22
5.10.2 Basic principle of the manager voting process	23
5.10.3 The manager voting process.....	24
5.11 BLOCKED not supported (Option).....	26
5.12 Interconnection port	26
5.13 Media redundancy Interconnection Manager (MIM)	28
5.14 Media redundancy Interconnection Client (MIC)	30
5.15 Interconnection domain	31
5.16 Interconnection diagnosis	31
6 MRP Class specification	31
6.1 General.....	31
6.2 Template.....	32
6.2.1 Media redundancy template	32
6.2.2 Media redundancy Interconnection template	33
6.3 Attributes	34
7 MRP Service specification	38

7.1	Start MRM	38
7.2	Stop MRM	39
7.3	State Change	40
7.4	Start MRC	41
7.5	Stop MRC	42
7.6	Read MRM	43
7.7	Read MRC	45
7.8	Start MIM	46
7.9	Stop MIM	48
7.10	Interconnection State Change	49
7.11	Start MIC	49
7.12	Stop MIC	51
7.13	Read MIM	52
7.14	Read MIC	53
8	MRP protocol specification	55
8.1	PDU description	55
8.1.1	Basic data types	55
8.1.2	DLPDU abstract syntax reference	55
8.1.3	Coding of the DLPDU field SourceAddress	56
8.1.4	Coding of the DLPDU field DestinationAddress	56
8.1.5	Coding of the field TagControllInformation	56
8.1.6	Coding of the field LT	57
8.1.7	MRP APDU abstract syntax	57
8.1.8	Coding of the field MRP_TLVHeader	59
8.1.9	Coding of the field MRP_SubTLVHeader	59
8.1.10	Coding of the field MRP_Ed1Type and MRP_Ed1ManufacturerData	60
8.1.11	Coding of the field MRP_Version	60
8.1.12	Coding of the field MRP_SequenceID	60
8.1.13	Coding of the field MRP_SA	60
8.1.14	Coding of the field MRP_OtherMRMSA	61
8.1.15	Coding of the field MRP_Prio	61
8.1.16	Coding of the field MRP_OtherMRMPrio	61
8.1.17	Coding of the field MRP_PortRole	61
8.1.18	Coding of the field MRP_RingState	62
8.1.19	Coding of the field MRP_Interval	62
8.1.20	Coding of the field MRP_Transition	62
8.1.21	Coding of the field MRP_TimeStamp	62
8.1.22	Coding of the field MRP_Blocked	63
8.1.23	Coding of the field MRP_ManufacturerOUI	63
8.1.24	Coding of the field MRP_IECOUI	63
8.1.25	Coding of the field MRP_ManufacturerData	63
8.1.26	Coding of the field MRP_DomainUUID	63
8.1.27	Coding of the field MRP_InState	64
8.1.28	Coding of the field MRP_InID	64
8.1.29	Coding of the field MRP_LinkInfo	64
8.2	Protocol machines	64
8.2.1	MRM protocol machine	64
8.2.2	MRC protocol machine	75
8.2.3	MRA protocol machine	81

8.2.4	MRA, MRM and MRC functions	102
8.2.5	FDB clear timer	106
8.2.6	Topology change timer	106
8.2.7	MIM protocol machine	107
8.2.8	MIC protocol machine	115
8.2.9	MIM and MIC functions	122
8.2.10	Interconnection Topology Change timer	127
8.2.11	Interconnection Link Status Poll timer	127
9	MRP installation, configuration and repair	128
9.1	Ring port and Interconnection port parameters	128
9.2	Ring topology parameters	128
9.3	MRM parameters	129
9.4	MRC parameters and constraints	129
9.5	MRA compatibility to earlier Automanager protocol version	130
9.6	Interconnection topology parameters	130
9.7	MIM parameters	130
9.8	MIC parameters and constraints	131
9.9	Calculation of MRP ring recovery time	132
9.9.1	Overview	132
9.9.2	Deduction of formula	132
9.9.3	Worst-case calculation for recovery time of 10 ms	134
9.9.4	Worst-case calculation for 50 devices	135
9.10	Calculation of MRP Automanager voting time	135
9.11	Calculation of MRP Interconnection recovery time	135
10	MRP Management Information Base (MIB)	137
10.1	General	137
10.2	MRP MIB with a monitoring view	137
10.3	MRP MIB with a management and monitoring view	151
Annex A (normative)	Optional earlier version of the Automanager protocol	166
Annex B (informative)	Timing considerations for 10 Mbit/s link speed	167
Annex C (informative)	Using MRP together with scheduling and shaping mechanisms as defined in IEEE Std 802.1Q and interspersing express traffic as defined in IEEE Std 802.3	169
C.1	General	169
C.2	Avoiding negative impact on the recovery time of an MRP ring	169
C.2.1	General	169
C.2.2	Interspersing express traffic	169
C.2.3	Enhancements for scheduled traffic	170
C.3	Configuration guidelines for increased performance of MRP	170
C.3.1	General	170
C.3.2	Interspersing express traffic	170
C.3.3	Enhancements for scheduled traffic	171
C.4	Calculation of MRP ring recovery time	171
C.4.1	Worst-case calculation for recovery time of 10 ms, using frame preemption	171
C.4.2	Worst-case calculation for 50 devices, using frame preemption	172
Annex D (informative)	Advanced MRP and MRP Interconnection topologies	173
D.1	General	173
D.2	MRP Single Switch Multiple Rings (MRP-SSMR)	173

D.3	Multiple MRP Interconnection	173
D.4	MRP Interconnection Dual Switch Multiple Couplings (MRP-I DSMC).....	174
Bibliography.....		175
Figure 1 – Two MRP rings redundantly connected via MRP Interconnection	14	
Figure 2 – MRP stack	16	
Figure 3 – MRP ring topology with one manager and clients	17	
Figure 4 – MRP open ring with MRM.....	18	
Figure 5 – MRP ring with MRA at network startup	23	
Figure 6 – MRP ring after the manager voting process.....	23	
Figure 7 – Manager voting process	25	
Figure 8 – MRA located outside the MRP ring.....	26	
Figure 9 – MRP Interconnection topology.....	28	
Figure 10 – MRP ring interconnection open	29	
Figure 11 – MRP protocol machine for MRM	65	
Figure 12 – MRP protocol machine for MRC	76	
Figure 13 – MRP protocol machine for MRA.....	82	
Figure 14 – MRP protocol machine for MIM in RC-mode and LC-mode	107	
Figure 15 – MRP protocol machine for MIC in RC-mode and LC-mode.....	115	
Figure D.1 – MRP Topologies	173	
Figure D.2 – MRP Interconnection Topologies	174	
Figure D.3 – MRP Interconnection Dual Switch Multiple Couplings Topology	174	
Table 1 – Coding of the Maintenance Association ID (MAID).....	21	
Table 2 – MRP Start MRM	38	
Table 3 – MRP Stop MRM.....	40	
Table 4 – MRP Change State.....	40	
Table 5 – MRP Start MRC.....	41	
Table 6 – MRP Stop MRC	42	
Table 7 – MRP Read MRM.....	43	
Table 8 – MRP Read MRC.....	45	
Table 9 – MRP Start MIM.....	47	
Table 10 – MRP Stop MIM	48	
Table 11 – MRP Interconnection Change State	49	
Table 12 – MRP Start MIC	50	
Table 13 – MRP Stop MIC	51	
Table 14 – MRP Read MIM	52	
Table 15 – MRP Read MIC	54	
Table 16 – MRP DLPDU syntax for ISO/IEC/IEEE 8802-3 (IEEE Std 802.3).....	55	
Table 17 – MRP OUI	56	
Table 18 – MRP MulticastMACAddress	56	
Table 19 – MRP TagControllInformation.Priority field.....	57	
Table 20 – MRP LT field	57	
Table 21 – MRP APDU syntax	57	

Table 22 – MRP Substitutions	58
Table 23 – MRP_TLVHeader.Type	59
Table 24 – MRP_SubTLVHeader.Type	59
Table 25 – MRP_Ed1Type and MRP_Ed1ManufacturerData	60
Table 26 – MRP_Ed1Type and MRP_Ed1ManufacturerData	60
Table 27 – MRP_Version	60
Table 28 – Coding of the field MRP_OtherMRMSA	61
Table 29 – MRP_Prio	61
Table 30 – Coding of the field MRP_OtherMRMPrio	61
Table 31 – MRP_PortRole	62
Table 32 – MRP_RingState	62
Table 33 – MRP_Interval	62
Table 34 – MRP_Transition	62
Table 35 – MRP_TimeStamp	63
Table 36 – MRP_Blocked	63
Table 37 – MRP_DomainUUID	63
Table 38 – MRP_InState	64
Table 39 – MRP_LinkInfo	64
Table 40 – MRP Local variables of MRM protocol machine	66
Table 41 – MRM State machine	67
Table 42 – MRP Local variables of MRC protocol machine	77
Table 43 – MRC state machine	77
Table 44 – MRP local variables of MRA protocol machine	83
Table 45 – MRA state machine	84
Table 46 – MRP functions and macros	102
Table 47 – MRP FDB clear timer	106
Table 48 – MRP topology change timer	107
Table 49 – MRP Local variables of MIM protocol machine	108
Table 50 – MIM State machine for LC-mode	109
Table 51 – MIM State machine for RC-mode	111
Table 52 – MRP Local variables of MIC protocol machine	116
Table 53 – MIC State machine for LC-mode	116
Table 54 – MIC State machine for RC-mode	120
Table 55 – MRP Interconnection functions	123
Table 56 – MRP Interconnection topology change timer	127
Table 57 – MRP Interconnection link status poll timer	128
Table 58 – MRP Network/Connection parameters	128
Table 59 – MRP MRM parameters	129
Table 60 – MRP MRC parameters	130
Table 61 – MRP MIM parameters	131
Table 62 – MRP MIC parameters	131
Table A.1 – Compatible mode MRP_Option for MRP_Test Substitutions	166
Table A.2 – Compatible mode MRP_Option frames MRP_TestMgrNAck and MRP_TestPropagate Substitutions	166

INTERNATIONAL ELECTROTECHNICAL COMMISSION**INDUSTRIAL COMMUNICATION NETWORKS –
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 2: Media Redundancy Protocol (MRP)****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62439-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This third edition cancels and replaces the second edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) improvements for the Continuity Check Protocol,
- b) introduction of further specifiers for the rings, the interconnection links, and the device roles,
- c) extensions and information on the use of baudrates smaller than 100 Mbit/s,
- d) information on using MRP together with scheduling and shaping mechanisms,
- e) introduction of an MRP Interconnection profile for a 30 ms reconfiguration time.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1118/FDIS	65C/1137/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This International Standard is to be read in conjunction with IEC 62439-1.

A list of all parts of the IEC 62439 series, published under the general title *Industrial communication networks – High availability automation networks*, can be found on the IEC website.

This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC/IEEE 8802-3 (IEEE Std 802.3™) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of the IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent. IEC takes no position concerning the evidence, validity, and scope of this patent right.

The holder of this patent right has assured IEC that s/he is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from the patent database available at <http://patents.iec.ch>.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those in the patent database. IEC shall not be held responsible for identifying any or all such patent rights.

INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

Part 2: Media Redundancy Protocol (MRP)

1 Scope

1.1 General

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC/IEEE 8802-3 (IEEE Std 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a recovery protocol based on a ring topology, designed to react deterministically on a single failure of an inter-switch link or switch in the network, under the control of a dedicated media redundancy manager node.

1.2 Code component distribution

Each Code Component is a ZIP package containing at least the electronic representation of the Code Component itself and a file describing the content of the package (IECManifest.xml).

The IECManifest contains different sections giving information on:

- the copyright notice;
- the identification of the code component;
- the publication related to the code component;
- the list of the electronic files which compose the code component;
- an optional list of history files to track changes during the evolution process of the code component.

The Code Components included in this IEC standard are a set of SNMP MIBs. The Code Component IEC-62439-2-MIB.mib is a file containing the MIB with the management and monitoring view. It will be available in a full version, which contains the MIB defined in this document with the documentation associated and access is restricted to purchaser of this document.

The Code Component (full version) is freely accessible on the IEC website for download at: https://www.iec.ch/sc65c/supportingdocuments/IEC_62439-2.MIB.{VersionStateInfo}.full.zip but the usage remains under the licensing conditions.

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). Consequently, new release(s) of the Code Component(s) may be released, which supersede(s) the previous release, and will be distributed through the IEC website at: <https://www.iec.ch/sc65c/supportingdocuments>.

The latest version/release of the document will be found by selecting the file IEC_62439-2.MIB.{VersionStateInfo}.full.zip for the code component with the highest value for VersionStateInfo.

In case of any differences between the downloadable code and the IEC pdf published content, the downloadable code(s) is(are) the valid one; it may be subject to updates. See history files.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-192, *International Electrotechnical Vocabulary – Part 192: Dependability* (available at www.electropedia.org)

IEC 61158-6-10:2019, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*

IEC 62439-1:2010/AMD1:2012

IEC 62439-1:2010/AMD2:2016¹

ISO/IEC 10164-1, *Information technology – Open Systems Interconnection – Systems Management: Object Management Function*

ISO/IEC/IEEE 8802-3, *Telecommunications and exchange between information technology systems – Requirements for local and metropolitan area networks – Part 3: Standard for Ethernet*

IEEE Std 802.1Q-2018, *IEEE Standard for Local and Metropolitan Area Networks – Bridges and Bridged Networks*

IEEE Std 802.3-2018, *IEEE Standard for Ethernet*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN