

STN	Zariadenia na meranie elektrickej energie Časť 3: Osobitné požiadavky Statické elektromery na činnú energiu striedavého prúdu (triedy A, B a C)	STN EN 50470-3 35 6134
------------	--	--

Electricity metering equipment - Part 3: Particular requirements - Static meters for AC active energy (class indexes A, B and C)

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 07/22

Obsahuje: EN 50470-3:2022

Oznámením tejto normy sa od 11.04.2025 ruší
STN EN 50470-3 (35 6134) z júna 2008

135374

EUROPEAN STANDARD

EN 50470-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2022

ICS 91.140.50

Supersedes EN 50470-3:2006 + A1:2018

English Version

**Electricity metering equipment - Part 3: Particular requirements -
Static meters for AC active energy (class indexes A, B and C)**

Equipement de comptage d'électricité - Partie 3: Exigences
particulières - Compteurs statiques d'énergie active en
courant alternatif (indices de classe A, B et C)

Elektrizitätszähler - Teil 3: Besondere Anforderungen -
Elektronische Wechselstrom Wirkverbrauchszähler der
Genauigkeitsklassen A, B und C

This European Standard was approved by CENELEC on 2022-04-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
1 Scope	5
2 Normative references	6
3 Terms and definitions	6
4 Standard electrical values	7
4.1 Voltages	7
4.2 Currents	7
4.2.1 General.....	7
4.2.2 Nominal current	8
4.2.3 Starting current.....	8
4.2.4 Minimum current.....	8
4.2.5 Maximum current.....	8
4.3 Frequencies.....	8
4.4 Power consumption	8
5 Construction requirements.....	8
6 Meter marking and documentation	9
7 Accuracy requirements.....	9
7.1 General test conditions.....	9
7.2 Methods of accuracy verification.....	9
7.3 Measurement uncertainty	9
7.4 Meter constant	9
7.5 Initial start-up of the meter	9
7.6 Test of no-load condition.....	9
7.7 Starting current test	9
7.8 Repeatability test	10
7.9 Allowable errors due to variation of the current	10
7.10 Allowable errors due to influence quantities and disturbances.....	11
7.11 Time-keeping accuracy	16
7.12 Accuracy tests at reference conditions	16
7.13 Error of measurement	16
8 Climatic conditions.....	17
8.1 General.....	17
8.2 Test of the effect of the climatic environments	17
9 The effects of external influences.....	17
10 Requirements concerning the software and protection against corruption	18
10.1 General.....	18
10.2 Identification of functions implemented in software	18
10.3 Identification and protection of software	18
10.4 Identification and protection of metrologically relevant parameters	18
10.5 Setting of parameters.....	19
10.6 Protection of measurement data.....	19
10.7 Protection against influence by metrologically non-relevant software	19
10.8 Protection against influence by connecting another device	19
11 Type test	19
12 Durability	19
13 Reliability.....	20

Annex A (informative) Calculation of the error of measurement	21
Annex B (informative) Differences between IEC and Directive 2014/32/EU	22
Annex C (informative) Accuracy classes	25
C.1 General	25
C.2 Accuracy classes	25
Annex ZZ (informative) Relationship between this European Standard and the essential requirements of Directive 2014/32/EU aimed to be covered	26
Bibliography	29

EN 50470-3:2022 (E)**European foreword**

This document (EN 50470-3:2022) has been prepared by CLC/TC 13 “Electrical energy measurement and control”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-04-11
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-04-11

This document supersedes EN 50470-3:2006 and all of its amendments and corrigenda.

EN 50470-3:2022 includes the following significant technical changes with respect to EN 50470-3:2006: it is based on EN IEC 62052-11:2021/A11:2022 instead of EN 50470-1:2006.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s) / Regulation(s).

For the relationship with EU Directive(s) / Regulation(s), see informative Annex ZZ, which is an integral part of this document.

This document is related to:

- EN IEC 62053-21:2021/A11:2021, Electricity metering equipment – Particular requirements – Part 21: Static meters for AC active energy (classes 0,5, 1 and 2)
- EN IEC 62053-22:2021/A11:2021, Electricity metering equipment – Particular requirements – Part 22: Static meters for AC active energy (classes 0,1 S, 0,2 S and 0,5 S).

NOTE Terms differences for accuracy classes in related standards (EN IEC 62053-21:2021/A11:2021 and EN IEC 62053-22:2021/A11:2021) and Directive 2014/32/EU are listed in Annex C.

The structure of the standards is similar; modifications in this document are provided in the perspective of compliance with the Essential Requirements of Directive 2014/32/EU on Measuring Instruments (MID).

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

1 Scope

This document applies only to static watt-hour meters of accuracy classes A, B and C for the measurement of alternating current electrical active energy in 50 Hz or 60 Hz networks and it applies to their type tests.

NOTE 1 For general requirements, such as construction, EMC, safety, dependability etc., see the relevant EN 62052 series or EN 62059 series.

This document applies to electricity metering equipment designed to:

- measure and control electrical energy on electrical networks (mains) with voltage up to 1 000 V AC;

NOTE 2 For AC electricity meters, the voltage mentioned above is the line-to-neutral voltage derived from nominal voltages. See EN 62052-31:2016, Table 7. EN 62052-31:2016 covers AC voltages only up to 600 V and Ed. 2 of EN IEC 62052-31 will cover AC voltages up to 1000 V.

- have all functional elements, including add-on modules, enclosed in, or forming a single meter case with exception of indicating displays;
- operate with integrated or detached indicating displays;
- be installed in specified matching sockets or racks;
- optionally, provide additional functions other than those for measurement of electrical energy.

Meters designed for operation with low power instrument transformers (LPITs as defined in the EN 61869 series) can be tested for compliance with this document only if such meters and their LPITs are tested together and meet the requirements for directly connected meters.

NOTE 3 Modern electricity meters typically contain additional functions such as measurement of voltage magnitude, current magnitude, power, frequency, power factor, etc.; measurement of power quality parameters; load control functions; delivery, time, test, accounting, recording functions; data communication interfaces and associated data security functions. The relevant standards for these functions could apply in addition to the requirements of this document. However, the requirements for such functions are outside the scope of this document.

NOTE 4 Product requirements for power metering and monitoring devices (PMDs) and measurement functions such as voltage magnitude, current magnitude, power, frequency, etc., are covered in EN 61557-12:2008. However, devices compliant with EN 61557-12:2008 are not intended to be used as billing meters unless they are also compliant with the EN IEC 62052-11:2021/A11:2022 and EN 50470-3:2022 standards.

NOTE 5 Product requirements for power quality instruments (PQIs) are covered in EN 62586-1:2017. Requirements for power quality measurement techniques (functions) are covered in EN 61000-4-30:2015. Requirements for testing of the power quality measurement functions are covered in EN 62586-2:2017.

This document does not apply to:

- meters for which the line-to-neutral voltage derived from nominal voltages exceeds 1 000 V AC;
- meters intended for connection with low power instrument transformers (LPITs as defined in the EN 61869 series) when tested without such transformers;
- metering systems comprising multiple devices (except of LPITs) physically remote from one another;
- portable meters;

NOTE 6 Portable meters are meters that are not permanently connected.

- meters used in rolling stock, vehicles, ships and airplanes;
- laboratory and meter test equipment;

EN 50470-3:2022 (E)

- reference standard meters;
- data interfaces to the register of the meter;
- matching sockets or racks used for installation of electricity metering equipment;
- any additional functions provided in electrical energy meters.

This document does not cover measures for the detection and prevention of fraudulent attempts to compromise meter's performance (tampering).

NOTE 7 Nevertheless, specific tampering detection and prevention requirements, and test methods, as relevant for a particular market are subject to the agreement between the manufacturer and the purchaser.

NOTE 8 Specifying requirements and test methods for fraud detection and prevention would be counterproductive, as such specifications would provide guidance for potential fraudsters.

NOTE 9 There are many types of meter tampering reported from various markets; therefore, designing meters to detect and prevent all types of tampering could lead to unjustified increase in costs of meter design, verification and validation.

NOTE 10 Billing systems, such as smart metering systems, are capable of detecting irregular consumption patterns and irregular network losses which enable discovery of suspected meter tampering.

NOTE 11 For transformer operated meters paired with current transformers (CTs) according to EN 61869-2: the standard CT measuring range is specified from $0,05 I_n$ to I_{max} for accuracy classes 0,1, 0,2, 0,5 and 1 and these CTs are used for meters of class C, B and A according to this document.

NOTE 12 This document does not specify emission requirements, these are specified in EN IEC 62052-11:2021/A11:2022, 9.3.14.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN IEC 62052-11:2021/A11:2022, *Electricity metering equipment – General requirements, tests and test conditions - Part 11: Metering equipment*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN