

STN	Automatizácia v budovách a riadiace systémy Riadiace aplikácie	STN EN 17609 74 7402
------------	---	--

Building automation and control systems - Control applications

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 10/22

Obsahuje: EN 17609:2022

135689

EUROPEAN STANDARD

EN 17609

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2022

ICS 35.240.67; 91.140.01

English Version

Building automation and control systems - Control applicationsSystèmes d'automatisation et de régulation des
bâtiments - Applications de régulationSysteme der Gebäudeautomation -
Steuerungsanwendung

This European Standard was approved by CEN on 13 June 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

EN 17609:2022 (E)

Contents		Page
European foreword		3
Introduction		4
1	Scope.....	10
2	Normative references.....	10
3	Terms and definitions.....	10
4	Abbreviations.....	12
5	Functional specifications having an impact on energy performance, comfort, and operational requirements of buildings.....	14
5.1	Heating control.....	14
5.2	Domestic hot water supply control.....	39
5.3	Cooling control.....	45
5.4	Ventilation and air conditioning control.....	66
5.5	Lighting control	81
5.6	Blind control.....	86
6	Functional elements	90
6.1	Sensor Functions.....	90
6.2	Actuator Functions.....	99
6.3	Display and User Operation Functions	103
6.4	Control Functions.....	110
Bibliography		157

European foreword

This document (EN 17609:2022) has been prepared by Technical Committee CEN/TC 247 “Building Automation, Controls and Building Management” the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2023, and conflicting national standards shall be withdrawn at the latest by January 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

EN 17609:2022 (E)**Introduction**

Buildings are built and operated serving a specific purpose, e.g. as an office workspace, a manufacturing floor, or a data centre. In each case, the usage of the space requires specific environmental conditions, e.g. temperature, light level or air quality, which is provided.

Increasing the efficient usage of energy to provide these environmental conditions is a key aspect of building design addressed in EN ISO 52120-1, *Energy Performance of Buildings — Energy performance of buildings — Part 1: Impact of Building Automation, Controls and Building Management*.

Energy efficiency requirements cannot be fulfilled by optimizing the primary systems of a building alone. A holistic view on the building and especially on the room control systems for lighting, solar protection and HVAC is the basis for optimizing the energy efficiency of buildings. This requires integration of the room and building controls and management systems from the design phase through installation and commissioning to the building operation.

The planning process for the technical infrastructure of a building and its spaces includes several steps starting with a rough set of requirements. With each step in the planning process the design becomes more detailed. First basic design choices or decisions allow for a budget estimate. These first design choices may be documented as depicted in Figure 1.




Figure 1 — Example for documentation of design choices for technical infrastructure of a building (Source: SN 502411:2016 / SIA 411:2016)

Figure 1 shows the equipment required for the different technical building disciplines (heating, cooling, ventilation, lighting, solar protection) in the space including energy related interconnections between the equipment of the respective disciplines. The schema depicts source/sink, conversion, storage, distribution, and emission elements and their interconnections in a simple manner. This is a high-level view on the mechanical and electrical equipment. It does not yet include the automation requirements associated with the equipment.

In a further planning step, the control functions (BAC functions) associated with the technical infrastructure equipment of a building are added as depicted in Figure 2.

EN 17609:2022 (E)




Figure 2 — Example for documentation of design choices for technical infrastructure and associated control functions of a building (Source: SN 502411:2016 / SIA 411:2016)

The column “usage/operation” contains control functions required for user interaction with the technical building infrastructure in the space and/or for super-ordinated (e.g. building-wide) functions and requirements.

Whereas the control functions are determined by the technical building equipment and the user operation interface in general, the sophistication of these control functions is determined by the desired level of energy efficiency of a building or comfort and operational requirements. Hence, both views, the desired level of energy efficiency of a building and the comfort and operational requirements, are considered and documented such that this documentation serves as a requirement specification for building control applications (heating, cooling, ventilation, lighting, solar protection) in a space.

In Figure 2, BAC functions have been added to the equipment. The labels refer to BAC functions listed in EN ISO 52120-1:2022, Table 5. These BAC functions are not specified in detail in EN ISO 52120-1.

Clause 5 of this document provides a method to transfer energy performance, comfort, and operational requirements as defined in EN ISO 52120-1:2022 into a more detailed specification of building automation functions.

Refer to EN ISO 52120-1:2022, Table 5, for a list of functions contributing to achieve the desired level of energy performance. Whereas EN ISO 52120-1:2022 only provides a very brief description of the functionality, Clause 5 contains a more detailed description.

NOTE Application of automated control improves the energy performance of buildings. Clause 5 of this document covers automated control applications only. Any manual or non-automated control listed in EN ISO 52120-1:2022, Table 5, is not covered in this document.

For the purpose of clarity, each subclause in Clause 5 contains a reference in square brackets to the corresponding entry in Table 5 of EN ISO 52120-1:2022 directly after the sub-clause heading.

The more detailed description includes information about mandatory and optional inputs as well as mandatory and optional outputs for the control function. The control function is not described in detail but rather is a “black box” as the actual implementation may be project or manufacturer specific.

Figure 3 provides an informative schematic view with the function (box), mandatory (blue) and optional (grey) inputs and mandatory (blue) and optional (grey) outputs. The informative schematic drawing also shows if inputs may be controlled, e.g. by manual operation or by a schedule and if output values are associated e.g. with an alarm or a trend.




Figure 3 — Informative depiction of control application scheme for Heating control – Emission control – Type 1: Central automatic control

EN 17609:2022 (E)

Clause 5 contains in each sub-clause a brief description of the control function itself, the target of the function, different operating modes, where applicable, and a description of the inputs and outputs of the function. Optionally, parameters and implementation equipment may be described.

For some of these functions more than one version is described, covering different technological implementations.

Building control functions may be associated with a specific zone, a room, a building segment, or the whole building.

The result of applying Clause 5 is a collection of building automation control function blocks. This does not yet depict how these blocks work in detail or how they are linked to each other. A more detailed control scheme description can be provided using the function blocks described in Clause 6.

Clause 6 of this document provides function blocks, which can be used to describe building control functions in more detail independent of a specific building control system or vendor.

Applications can be described by a combination of sensor input, actuator output, user interaction, and control and monitoring functions. Certain functions in a room (e.g. presence detection) may be shared by two or more applications. A common set of function blocks covering sensor input, actuator output, user interaction, and control functions for the different applications in a room serves as the basis for describing room automation, controls and management systems.

Using a typical example, Figure 4 shows the relationship between sensor, display/operation, control and actuator functions. Information exchanged between functions is provided from outputs to inputs. Physical inputs and outputs associated with Sensor and Actuator functions are not depicted in the figure. As some functions may require parameters these are also depicted in each function block.




Figure 4 — Relationship between Automation functions (typical example)

A sensor function typically includes a physical input (e.g. a temperature sensor, not depicted in Figure 4) and provides a logical output (OUTPUT of the Sensor function block in Figure 4) for use by other functions.

A display and operation function includes physical inputs or outputs depending on its functionality and provides logical inputs for display purposes and logical outputs for use by other functions (Display and Operation function block in Figure 4).

Control functionality as depicted in Figure 4 is assigned to specific control functions with one or more logical inputs (INPUT 1 and INPUT 2 of the Control function block in Figure 4) and at least one logical output (OUTPUT of the Control function block in Figure 4). Control functions are not directly associated with physical inputs or outputs.

Actuator functionality is assigned to specific actuator functions. An actuator function typically includes a physical output (controlling e.g. a valve) and provides a logical input (INPUT of the Actuator function in Figure 4) and logical output. This logical output could be used as a feedback status information.

The generalized description format used in Clause 6 for functions includes a brief description of the function, of the physical input(s), of the logical input(s) expected from other functions, of the logical output(s) provided to other functions, and of the physical output(s). In addition, parameters are listed that are required to more precisely define the function for a specific project.

The description of the functions blocks follows this uniform scheme:

- Short description of the function;
- Physical Input(s);
- Logical Input(s);
- Logical Output(s);
- Physical Output(s);
- Parameters (optional).

The list of functions may be extended where necessary.

EN 17609:2022 (E)**1 Scope**

This document specifies control applications and function blocks focusing on but not limited to lighting, solar protection and HVAC applications.

It describes how energy performance, comfort, and operational requirements of buildings are translated into functional specifications for integrated plant and room control.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 52120-1:2022, *Energy performance of buildings — Contribution of building automation, controls and building management — Part 1: General framework and procedures (ISO 52120-1:2021)*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN