

STN	Informačná technika Zariadenia a infraštruktúry výpočtových stredísk Časť 4-9: Efektívnosť využitia vody	STN EN 50600-4-9 36 7254
------------	---	--

Information technology - Data centre facilities and infrastructures - Part 4-9: Water Usage Effectiveness

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 03/23

Obsahuje: EN 50600-4-9:2022

136485

EUROPEAN STANDARD

EN 50600-4-9

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2022

ICS 35.020; 35.110; 35.160

English Version

**Information technology - Data centre facilities and infrastructures
- Part 4-9: Water Usage Effectiveness**

Technologie de l'information - Installation et infrastructures
de centres de traitement de données - Partie 4-9: Efficacité
de l'utilisation de l'eau

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 4-9: Effektivität der
Wasserverwendung

This European Standard was approved by CENELEC on 2022-12-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 50600-4-9:2022 (E)

Contents	Page
European foreword	4
Introduction	5
1 Scope	8
2 Normative references	8
3 Terms, definitions, abbreviations and symbols	8
3.1 Terms and definitions	8
3.2 Abbreviations	10
3.3 Symbols	10
4 Applicable area of the data centre	11
5 Determination of Water Usage Effectiveness	11
6 Measurement of Water Usage Effectiveness	12
6.1 General	12
6.2 Measuring actual water usage	12
6.2.1 Calculation, measurement period and frequency	12
6.2.2 Categories of Water Usage Effectiveness	12
7 Application of Water Usage Effectiveness	15
8 Reporting of Water Usage Effectiveness	16
8.1 Requirements.....	16
8.1.1 Standard construct for communicating WUE data	16
8.1.2 Data for public reporting of WUE.....	16
8.2 Recommendations	17
8.3 Example of reporting WUE values	17
8.4 WUE derivatives	18
8.4.1 Purpose of WUE derivatives.....	18
8.4.2 Using WUE derivatives	18
8.4.3 Interim WUE	18
8.4.4 Partial WUE	19
8.4.5 Design WUE	19
8.4.6 Quality WUE	19

8.4.7	Peak WUE	19
8.5	Water Reuse Factor (WRF).....	19
	Annex A (informative) Examples of use.....	20
A.1	Correct use of WUE.....	20
A.2	Water Usage Effectiveness Category 1.....	20
A.3	Water Usage Effectiveness Category 3.....	20
A.4	Interim Water Usage Effectiveness category 3	21
	Annex B (normative) Water significance	22
	Annex C (informative) Energy Water Intensity Factor	23
	Annex D (informative) Land consumption	24
	Bibliography	26
	Figures	
	Figure 1 — Schematic relationship between the EN 50600 series documents.....	6
	Figure 2 — WUE Category 1	13
	Figure 3 — WUE Category 2	14
	Figure 4 — WUE category 3.....	15
	Tables	
	Table 1 — WUE Categories.....	12
	Table C.1 — EWIF examples for different energy sources	23
	Table D.1 — Examples of drainage factors for different grades of sealed surfaces	24

EN 50600-4-9:2022 (E)**European foreword**

This document (EN 50600-4-9:2022) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”. It is based on the text of ISO/IEC 30134-9:2022 “Information technology - Data centres key performance indicators - Part 9: Water usage effectiveness (WUE)”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-12-12
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-12-12

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information are important in order to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TS 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

EN 50600-4-9:2022 (E)

At the time of publication of this document, the EN 50600-4 series comprises the following documents:

EN 50600-4-1, *Information technology — Data centre facilities and infrastructures — Part 4-1: Overview of and general requirements for key performance indicators*

EN 50600-4-2, *Information technology — Data centre facilities and infrastructures — Part 4-2: Power Usage Effectiveness*

EN 50600-4-3, *Information technology — Data centre facilities and infrastructures — Part 4-3: Renewable Energy Factor;*

EN 50600-4-6, *Information technology — Data centre facilities and infrastructures — Part 4-6: Energy Reuse Factor;*

EN 50600-4-7, *Information technology — Data centre facilities and infrastructures — Part 4-7: Cooling Efficiency Ratio;*

EN 50600-4-8, *Information technology — Data centre facilities and infrastructures — Part 4-8: Carbon Usage Effectiveness;*

EN 50600-4-9, *Information technology — Data centre facilities and infrastructures — Part 4-9: Water Usage Effectiveness.*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series documents

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

NOTE Within the EN 50600-4-X series, the term “resource usage effectiveness” is more generally used for KPIs in preference to “resource usage efficiency”, which is restricted to situations where the input and output parameters used to define the KPI have the same units.

EN 50600-4-9:2022 (E)

In today's digital society data centre growth, and power consumption in particular, is an inevitable consequence and that growth will demand increasing power consumption despite the most stringent energy efficiency strategies. This makes the need for key performance indicators that cover the effective use of resources (including but not limited to energy) and the reduction of CO₂ emissions essential.

In order to enable the optimum resource effectiveness of data centres a suite of effective KPIs is needed to measure and report on resources consumed in order to develop an improvement roadmap.

These standards are intended to accelerate the provision of operational infrastructures with improved resource usage effectiveness.

This document specifies the Water Usage Effectiveness (WUE) including relevant derivatives and provides a metric to report the (re-)use of water consumed in a data centre.

This document is intended for use by data centre managers. The use of the Water Usage Effectiveness as a key performance indicator provides data centre managers with greater visibility and assists them in achieving sustainability goals.

Additional standards in the EN 50600-4-X series will be developed, each describing a specific KPI for resource usage effectiveness or efficiency.

The EN 50600-4-X series does not specify limits or targets for any KPI and does not describe or imply, unless specifically stated, any form of aggregation of individual KPIs into a combined nor an overall KPI for data centre resource usage effectiveness or efficiency.

This document is intended for use by and collaboration between data centre managers, facility managers, ICT managers, and main contractors.

This series of documents does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

EN 50600-4-9:2022 (E)

1 Scope

This document specifies the Water Usage Effectiveness (WUE) as a KPI for quantifying the water consumption of a data centre during use phase of the data centre life cycle.

This document:

- a) defines the Water Usage Effectiveness (WUE) of a data centre;
- b) introduces WUE measurement categories;
- c) describes the relationship of this KPI to a data centre's infrastructure, information technology equipment and information technology operations;
- d) defines the measurement, the calculation and the reporting of the parameter;
- e) provides information on the correct interpretation of the WUE.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50600-4-1:2016, *Information technology - Data centre facilities and infrastructures - Part 4-1: Overview of and general requirements for key performance indicators*

EN 50600-4-2, *Information technology - Data centre facilities and infrastructures - Part 4-2: Power Usage Effectiveness*

ISO 8601-1, *Date and time — Representations for information interchange — Part 1: Basic rules*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN