

<b>STN</b>	<b>Manažment alarmov pre priemyselné procesy</b>	<b>STN EN IEC 62682</b>  33 4595
------------	--	--

Management of alarm systems for the process industries

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 03/23

Obsahuje: EN IEC 62682:2023, IEC 62682:2022

Oznámením tejto normy sa od 12.01.2026 ruší  
STN EN 62682 (33 4595) z júla 2015

**136550**

EUROPEAN STANDARD

**EN IEC 62682**

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2023

ICS 13.320; 25.040.40

Supersedes EN 62682:2015

English Version

**Management of alarm systems for the process industries  
(IEC 62682:2022)**

Gestion de systèmes d'alarme dans les industries de  
transformation  
(IEC 62682:2022)

Alarmmanagement in der Prozessindustrie  
(IEC 62682:2022)

This European Standard was approved by CENELEC on 2023-01-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## EN IEC 62682:2023 (E)

### European foreword

The text of document 65A/1046/FDIS, future edition 2 of IEC 62682, prepared by SC 65A "System aspects" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62682:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-10-12
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2026-01-12

This document supersedes EN 62682:2015 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

### Endorsement notice

The text of the International Standard IEC 62682:2022 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 61508-4:2010 NOTE Harmonized as EN 61508-4:2010 (not modified)

IEC 61511 (series) NOTE Harmonized as EN 61511 (series)

IEC 61511-1 NOTE Harmonized as EN 61511-1

IEC 62264-2:2013 NOTE Harmonized as EN 62264-2:2013 (not modified)

IEC 62541-9:2020 NOTE Harmonized as EN IEC 62541-9:2020 (not modified)



IEC 62682

Edition 2.0 2022-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Management of alarm systems for the process industries**

**Gestion de systèmes d'alarme dans les industries de transformation**



**THIS PUBLICATION IS COPYRIGHT PROTECTED****Copyright © 2022 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

**IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

**IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

**IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)**

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

**A propos de l'IEC**

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

**A propos des publications IEC**

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

**Recherche de publications IEC -****[webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)**

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

**Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

**IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)**

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 62682

Edition 2.0 2022-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Management of alarm systems for the process industries**

**Gestion de systèmes d'alarme dans les industries de transformation**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 13.320; 25.040.40

ISBN 978-2-8322-5885-9

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD .....	9
INTRODUCTION .....	11
1 Scope .....	12
1.1 General applicability .....	12
1.2 Exclusions and inclusions .....	13
1.2.1 Operators .....	13
1.2.2 Process sensors and final control elements .....	13
1.2.3 Annunciators .....	13
1.2.4 Human machine interface .....	13
1.2.5 Safety instrumented systems .....	14
1.2.6 Fire and gas detection and protective systems .....	14
1.2.7 Security systems .....	14
1.2.8 Packaged systems .....	14
1.2.9 Event data .....	14
1.2.10 Alarm identification methods .....	14
1.2.11 Management of change .....	14
1.2.12 Purchase specification .....	14
2 Normative references .....	14
3 Terms, definitions and abbreviated terms .....	15
3.1 Terms and definitions .....	15
3.2 Abbreviated terms .....	24
4 Conformance to this document .....	25
4.1 Conformance guidance .....	25
4.2 Existing systems .....	25
4.3 Use of required functionalities .....	25
4.4 Responsibility .....	25
4.5 Local Jurisdictions .....	25
5 Alarm system models .....	25
5.1 Alarm systems .....	25
5.2 Alarm management life cycle .....	25
5.2.1 Alarm management life cycle model .....	25
5.2.2 Alarm management life cycle stages .....	26
5.2.3 Alarm management life cycle entry points .....	29
5.2.4 Simultaneous and encompassing stages .....	29
5.2.5 Alarm management life cycle loops .....	29
5.2.6 Alarm management life cycle stage inputs and outputs .....	30
5.3 Alarm states .....	31
5.3.1 Alarm state transition diagram .....	31
5.3.2 Alarm states .....	32
5.3.3 Alarm state transition paths .....	34
5.4 Alarm response timeline .....	35
5.4.1 General .....	35
5.4.2 Normal (A) .....	36
5.4.3 Unacknowledged (B) .....	36
5.4.4 Acknowledged (C) and response .....	36
5.4.5 Return-to-normal (D) .....	37

5.4.6	Allowable response time .....	37
5.4.7	Alarm setpoint .....	37
5.4.8	Consequence threshold .....	37
5.4.9	Alarm deadband .....	37
5.5	Feedback model of operator-process interaction .....	37
5.5.1	General .....	37
5.5.2	Detect.....	38
5.5.3	Diagnose .....	38
5.5.4	Respond .....	38
5.5.5	Performance shaping factors .....	38
6	Alarm philosophy .....	39
6.1	Purpose .....	39
6.2	Alarm philosophy contents .....	39
6.2.1	General .....	39
6.2.2	Purpose of alarm system .....	40
6.2.3	Definitions .....	40
6.2.4	References .....	40
6.2.5	Roles and responsibilities for alarm management .....	40
6.2.6	Alarm design principles.....	40
6.2.7	Alarm setpoint determination .....	41
6.2.8	Prioritization method.....	41
6.2.9	Alarm class definition.....	41
6.2.10	Highly managed alarms .....	41
6.2.11	Rationalization.....	41
6.2.12	Alarm documentation .....	42
6.2.13	Alarm design guidance .....	42
6.2.14	Specific alarm design considerations .....	42
6.2.15	HMI design principles .....	42
6.2.16	Approved enhanced and advanced alarming techniques .....	43
6.2.17	Implementation guidance .....	43
6.2.18	Alarm response procedures .....	43
6.2.19	Training .....	43
6.2.20	Alarm shelving.....	43
6.2.21	Alarm system maintenance .....	43
6.2.22	Testing of alarms .....	43
6.2.23	Alarm system performance monitoring .....	44
6.2.24	Alarm history preservation .....	44
6.2.25	Management of change .....	44
6.2.26	Alarm management audit .....	44
6.2.27	Related site procedures .....	44
6.3	Alarm philosophy development and maintenance .....	45
7	Alarm system requirements specification .....	45
7.1	Purpose .....	45
7.2	Recommendations .....	45
7.3	Development.....	46
7.4	Systems evaluation.....	46
7.5	Packaged systems .....	46
7.6	Customization .....	46
7.7	Alarm system requirements verification .....	46



8	Identification.....	46
8.1	Purpose .....	46
8.2	Alarm identification methods .....	47
8.3	Identification training.....	47
8.4	Identification documentation .....	47
9	Rationalization.....	47
9.1	Purpose .....	47
9.2	Rationalization documentation .....	48
9.2.1	Rationalization documentation requirements.....	48
9.2.2	Rationalization documentation recommendations.....	48
9.2.3	Plant states .....	48
9.3	Alarm justification .....	48
9.3.1	Alarm justification process .....	48
9.3.2	Justification approach.....	49
9.3.3	Individual alarm justification.....	49
9.3.4	Impact on alarm system performance .....	49
9.4	Alarm setpoint determination.....	49
9.5	Prioritization .....	50
9.6	Classification .....	50
9.7	Review.....	50
9.8	Removal of rejected alarms.....	50
9.9	Documentation.....	50
10	Detailed design: basic alarm design .....	50
10.1	Purpose .....	50
10.2	Basic alarm design capabilities .....	51
10.3	Usage of alarm states .....	51
10.3.1	Alarm state triggering .....	51
10.3.2	Alarm states and other logic functions .....	51
10.3.3	Alarm suppression and other logic functions .....	51
10.4	Alarm types.....	51
10.5	Alarm attributes .....	52
10.5.1	General .....	52
10.5.2	Alarm description.....	52
10.5.3	Alarm setpoints.....	52
10.5.4	Alarm priority.....	52
10.5.5	Alarm deadbands.....	52
10.5.6	Alarm on-delay and off-delay .....	53
10.6	Programmatic changes to alarm attributes .....	53
10.7	Review of basic alarm design.....	53
11	Detailed design: human-machine interface design for alarm systems.....	54
11.1	Purpose .....	54
11.2	HMI functions.....	54
11.2.1	General .....	54
11.2.2	HMI information requirements.....	54
11.2.3	HMI functional requirements .....	54
11.2.4	HMI functional recommendations .....	54
11.2.5	HMI display requirements .....	54
11.2.6	Alarm records requirements.....	55

11.2.7	Alarm records recommendations.....	55
11.3	Alarm states indications .....	55
11.3.1	General .....	55
11.3.2	Required alarm state indications.....	55
11.3.3	Recommended alarm state indications.....	55
11.3.4	Audible alarm state indications .....	57
11.4	Alarm priority indications.....	57
11.4.1	General .....	57
11.4.2	Alarm priority indication requirements.....	57
11.4.3	Colour alarm priority indications requirements .....	57
11.4.4	Recommended alarm priority indications.....	57
11.5	Alarm message indications .....	58
11.5.1	General .....	58
11.5.2	Recommended alarm message indications .....	58
11.6	Alarm displays .....	58
11.6.1	General .....	58
11.6.2	Alarm summary display.....	59
11.6.3	Alarm summary status .....	60
11.6.4	Alarm log displays .....	60
11.6.5	Process displays.....	61
11.6.6	Tag detail displays.....	61
11.6.7	Other graphic elements .....	61
11.7	Alarm shelving .....	61
11.7.1	General .....	61
11.7.2	Alarm shelving functional requirements.....	61
11.7.3	Alarm shelving functional recommendations .....	62
11.7.4	Shelved alarm displays.....	62
11.8	Out-of-service alarms.....	62
11.8.1	General .....	62
11.8.2	Out-of-service alarm functional requirements.....	63
11.8.3	Out-of-service alarm displays .....	63
11.9	Alarms suppressed by design .....	63
11.9.1	General .....	63
11.9.2	Designed suppression functional requirements .....	64
11.9.3	Designed suppression functional recommendations.....	64
11.9.4	Suppressed-by-design displays .....	64
11.10	Alarm annunciator integration .....	65
11.10.1	General .....	65
11.10.2	Alarm annunciator integration recommendations.....	65
11.10.3	Alarm annunciator display integration recommendations.....	65
11.11	Safety related alarm HMI .....	65
11.11.1	General .....	65
11.11.2	Independent safety related alarm HMI .....	65
12	Detailed design: enhanced and advanced alarming .....	65
12.1	Purpose .....	65
12.2	Basis of enhanced and advanced alarming .....	66
12.2.1	General .....	66
12.2.2	Effort, manpower requirements and complexity.....	66
12.3	Information linking .....	66

12.4	Logic-based alarming .....	66
12.4.1	General .....	66
12.4.2	Alarm attribute modification .....	66
12.4.3	Externally enabled systems .....	66
12.4.4	Logical alarm suppression and attribute modification .....	66
12.4.5	State-based alarming.....	66
12.5	Model-based alarming.....	67
12.6	Additional alarming considerations.....	67
12.6.1	General .....	67
12.6.2	Remote alarm systems .....	67
12.6.3	Supplementary alarm systems .....	67
12.6.4	Batch process considerations .....	67
12.7	Training, testing, and auditing systems .....	68
12.8	Alarm attribute enforcement.....	68
13	Implementation .....	68
13.1	Purpose .....	68
13.2	Implementation planning .....	68
13.3	Implementation training.....	69
13.3.1	General .....	69
13.3.2	Implementation training requirements for new or modified alarms .....	69
13.3.3	Training documentation requirements for new or modified highly managed alarms .....	69
13.3.4	Training documentation recommendations for new or modified alarms.....	69
13.3.5	Implementation training requirements for new or modified alarm systems .....	69
13.3.6	Implementation training recommendations for new or modified alarm systems .....	69
13.4	Implementation testing and verification .....	69
13.4.1	General .....	69
13.4.2	Implementation testing requirements for highly managed alarms .....	70
13.4.3	Implementation testing recommendations for new or modified alarms .....	70
13.4.4	Implementation testing requirements for new or modified alarm systems .....	70
13.5	Implementation documentation .....	70
13.5.1	General .....	70
13.5.2	Documentation requirements .....	70
13.5.3	Implementation documentation recommendations.....	71
14	Operation .....	71
14.1	Purpose .....	71
14.2	Alarm response procedures .....	71
14.2.1	Alarm response procedures requirements.....	71
14.2.2	Alarm response procedure recommendations .....	71
14.3	Alarm shelving .....	72
14.3.1	Alarm shelving requirements.....	72
14.3.2	Alarm shelving for highly managed alarms.....	72
14.3.3	Alarm shelving recommendations .....	72
14.3.4	Alarm shelving record requirements.....	72
14.3.5	Shift change procedures and alarm review .....	72
14.4	Refresher training for operators .....	72
14.4.1	Refresher training requirements for operators.....	72

14.4.2	Refresher training documentation requirements for highly managed alarms .....	72
14.4.3	Refresher training content for highly managed alarms .....	73
14.4.4	Refresher training recommendations for alarms .....	73
15	Maintenance .....	73
15.1	Purpose .....	73
15.2	Periodic alarm testing .....	73
15.2.1	General .....	73
15.2.2	Periodic alarm testing requirements .....	73
15.2.3	Periodic alarm testing for highly managed alarms .....	73
15.2.4	Periodic alarm test procedure requirements .....	74
15.2.5	Periodic alarm test procedure recommendations .....	74
15.2.6	Periodic alarm testing recommendations .....	74
15.3	Out-of-service alarms .....	74
15.3.1	General .....	74
15.3.2	Out-of-service process requirements .....	74
15.3.3	Out-of-service highly managed alarms .....	74
15.3.4	Out-of-service process recommendations .....	75
15.3.5	Requirements for returning alarms to service .....	75
15.4	Equipment repair .....	75
15.5	Equipment replacement .....	75
15.6	Refresher training for maintenance .....	75
15.6.1	General requirements .....	75
15.6.2	Refresher training requirements for highly managed alarms .....	75
15.6.3	Refresher training recommendations for alarms .....	75
16	Monitoring and assessment .....	75
16.1	Purpose .....	75
16.2	Performance monitoring requirements .....	76
16.3	Monitoring and assessment .....	76
16.3.1	General .....	76
16.3.2	Alarm system performance metrics .....	76
16.3.3	Average alarm rate per operator console .....	76
16.3.4	Peak alarm rate per operator console .....	77
16.3.5	Alarm floods .....	77
16.3.6	Frequently occurring alarms .....	77
16.3.7	Chattering and fleeting alarms .....	77
16.3.8	Stale alarms .....	78
16.3.9	Annunciated alarm priority distribution .....	78
16.3.10	Rationalization and alarm priority distribution .....	78
16.4	Unauthorized alarm suppression .....	78
16.5	Alarm attribute monitoring .....	79
16.6	Reporting of alarm system analyses .....	79
16.7	Alarm performance metric summary .....	79
17	Management of change .....	79
17.1	Purpose .....	79
17.2	Changes subject to management of change .....	80
17.3	Change documentation requirements .....	80
17.4	Alarm removal recommendations .....	80
17.5	Alarm documentation review recommendations .....	80

18	Audit.....	80
18.1	Purpose .....	80
18.2	Benchmark.....	80
18.3	Audit requirements.....	81
18.4	Audit interviews .....	81
18.5	Audit process recommendations .....	81
18.6	Action plans .....	81
	Bibliography.....	82
	Figure 1 – Alarm system dataflow .....	13
	Figure 2 – Alarm management life cycle .....	26
	Figure 3 – Alarm state transition diagram.....	32
	Figure 4 – Alarm response timeline.....	36
	Figure 5 – Feedback model of operator-process interaction .....	38
	Table 1 – Alarm management life cycle stage inputs and outputs.....	31
	Table 2 – Summary of alarm states.....	34
	Table 3 – Required and recommended alarm philosophy contents .....	39
	Table 4 – Recommended alarm state indications .....	57
	Table 5 – Average alarm rates .....	77
	Table 6 – Example annunciated alarm priority distribution.....	78
	Table 7 – Recommended alarm performance metrics summary.....	79

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**MANAGEMENT OF ALARM SYSTEMS  
FOR THE PROCESS INDUSTRIES****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62682 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

This edition includes minor technical changes with respect to the previous edition, based on changes to ANSI/ISA-18.2:2016. These include the inclusion of packaged systems in the scope (Clause 1), definitions (Clause 3) and alarm system requirements specification (Clause 7). There are changes to improve clarity in wording throughout the document.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65A/1046/FDIS	65A/1064/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INTRODUCTION

This International Standard addresses the development, design, installation, and management of alarm systems in the process industries. Alarm management includes multiple work processes throughout the alarm management life cycle. This document defines the terminology and models to develop an alarm system, and it defines the work processes recommended to effectively maintain the alarm throughout the life cycle. Ineffective alarm systems have often been cited as contributing factors in the investigation reports following major process incidents. This document is intended to provide a methodology that will result in the improved safety, quality, and operation in the process industries.

The first edition of this document was adapted from ANSI/ISA-18.2-2009, *Management of Alarm Systems for the Process Industries*, an International Society of Automation (ISA) standard, and with due consideration of other guidance documents that have been developed throughout industry. This second edition has incorporated some changes made in ANSI/ISA-18.2-2016.

This document is not the first effort to define terminology and practices for effective alarm systems. In 1999 the Engineering Equipment and Materials Users' Association (EEMUA) issued Publication 191, *Alarm Systems: A Guide to Design, Management and Procurement*, with the 2<sup>nd</sup> edition published in 2007 and the 3<sup>rd</sup> edition published in 2013. In 2003 the User Association of Process Control Technology in Chemical and Pharmaceutical Industries (NAMUR) issued worksheet NA 102, *Alarm Management*, which was updated in 2008. During the development and maintenance of this document, every effort was made to keep terminology and practices consistent with the previous work of these respected organizations and committees.

This document provides requirements for alarm management and alarm systems. It is intended for those individuals and organizations that

- a) manufacture or implement embedded alarm systems,
- b) manufacture or install third-party alarm system software,
- c) design or install alarm systems,
- d) operate and maintain alarm systems, and
- e) audit or assess alarm system performance.

This document is organized in parts. The first part (Clause 1 to Clause 3) are normative without any mandatory requirements. Clause 4 contains mandatory requirements. Clause 5 is normative without any mandatory requirements. The main body of the standard (Clause 6 to Clause 18), describes mandatory requirements and non-mandatory recommendations.

Within this document, mandatory requirements are stated with "shall", non-mandatory recommendations are stated with "should", and permissible requirements are stated with "may". The phrase "is required" indicates the requirement has been stated previously in the document.



# MANAGEMENT OF ALARM SYSTEMS FOR THE PROCESS INDUSTRIES

## 1 Scope


### 1.1 General applicability

This document specifies general principles and processes for the management of alarm systems based on controls system and human-machine interfaces (HMI) for facilities in the process industries. It covers all alarms to be presented to the operator through the control system, which includes alarms from basic process control systems, annunciators, packaged systems, and safety instrumented systems.

The practices in this document are applicable to continuous, batch, and discrete processes. There can be differences in implementation to meet the specific needs based on process type.

The primary function within the alarm system is to notify operators of abnormal process conditions or equipment malfunctions and support the response. The alarm systems can include both the basic process control system (BPCS) and the safety instrumented system (SIS), each of which uses measurements of process conditions and logic to generate alarms. Figure 1 illustrates the concepts of alarm and response dataflow through the alarm system. The alarm system also includes a mechanism for communicating the alarm information to the operator via an HMI, usually a computer screen or an annunciator. Additional functions of the alarm system are an alarm and event log, an alarm historian, and the generation of performance metrics for the alarm system. There are external systems that can use the data from the alarm system.

Figure 1 is not intended to represent physical wiring.



IEC

NOTE 1 Packaged systems (e.g., refrigeration machines) can be included in the control system.

NOTE 2 Panel can refer to annunciator panel or other panel types.

NOTE 3 The lines are intended to represent data flow and not physical wiring.

**Figure 1 – Alarm system dataflow**

## 1.2 Exclusions and inclusions

### 1.2.1 Operators

The functions of the operator receiving and responding to alarms are included in the scope of this document. Management of operators is excluded from the scope of this document.

### 1.2.2 Process sensors and final control elements

The alarms implemented in sensors and final control elements are included in the scope of this document. The design and management of process sensors and final control elements are excluded from the scope of this document.

### 1.2.3 Annunciators

The integration of annunciators into an alarm system is included in the scope of this document. The specification and design of annunciators is excluded from the scope of this document.

### 1.2.4 Human machine interface

The appearance of alarms in the HMI and functions of alarm related displays are included in the scope of this document. The design and maintenance of the HMI are excluded from this document.

NOTE ANSI/ISA-101.01-2015 provides information on HMI design and maintenance.

### **1.2.5 Safety instrumented systems**

The alarms implemented in a safety instrumented system are included in the scope of this document. The design and management of safety instrumented systems are excluded from this document.

NOTE IEC 61511-1 provides information on safety instrumented systems.

### **1.2.6 Fire and gas detection and protective systems**

The alarms from fire and gas detection and protective systems presented to the operator through the control system are included in the scope of this document. The design and management of fire and gas detection and protective systems is excluded from the scope of this document.

### **1.2.7 Security systems**

The alarms from security systems presented to the operator through the control system are included in the scope of this document. The design and management of security systems is excluded from the scope of this document.

### **1.2.8 Packaged systems**

The alarms from packaged systems presented to the operator through the control system are included in the scope of this document. The design and management of packaged systems is excluded from the scope of this document.

### **1.2.9 Event data**

The indication and processing of analog, discrete, and event data other than alarm indications are excluded from the scope of this document. The analysis techniques using both alarm and event data are excluded from the scope of this document.

### **1.2.10 Alarm identification methods**

Required methods of alarm identification are not specified in this document. Examples of alarm identification methods are listed.

### **1.2.11 Management of change**

A specific management of change (MOC) procedure is not included in this document. Some requirements and recommendations for an MOC procedure are included.

### **1.2.12 Purchase specification**

This document is not intended to be used as an alarm system purchase specification.

## **2 Normative references**

There are no normative references in this document.

### 3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions, and acronyms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**