

STN	Pokyny a odporúčania na projektovanie, výber a inštalovanie prieduchov na zabezpečenie štruktúrálnej celistvosti uzatvorených priestorov chránených plynovými hasiacimi zariadeniami (ISO 21805: 2023)	STN EN ISO 21805 92 0433
------------	---	--

Guidance and recommendations on design, selection and installation of vents to safeguard the structural integrity of enclosures protected by gaseous fire-extinguishing systems (ISO 21805:2023)

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 05/23

Obsahuje: EN ISO 21805:2023, ISO 21805:2023

Oznámením tejto normy sa ruší
STN P CEN ISO/TS 21805 (92 0433) z júna 2019

136764

EUROPEAN STANDARD

EN ISO 21805

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2023

ICS 13.220.10; 91.140.30

Supersedes CEN ISO/TS 21805:2019

English Version

**Guidance and recommendations on design, selection and
installation of vents to safeguard the structural integrity of
enclosures protected by gaseous fire-extinguishing
systems (ISO 21805:2023)**

Lignes directrices et recommandations relatives à la conception, à la sélection et à l'installation d'évents pour préserver l'intégrité structurelle des enceintes protégées par des systèmes d'extinction d'incendie à gaz (ISO 21805:2023)

Anleitung für die Konstruktion, Auswahl und Installation von Entlüftungen zur Gewährleistung der strukturellen Integrität von Gehäusen, die durch ortsfeste Gaslöschanlagen geschützt sind (ISO 21805:2023)

This European Standard was approved by CEN on 7 August 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN ISO 21805:2023 (E)

Contents	Page
European foreword.....	3

European foreword

This document (EN ISO 21805:2023) has been prepared by Technical Committee ISO/TC 21 "Equipment for fire protection and fire fighting" in collaboration with Technical Committee CEN/TC 191 "Fixed firefighting systems" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2023, and conflicting national standards shall be withdrawn at the latest by September 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN ISO/TS 21805:2019.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Endorsement notice

The text of ISO 21805:2023 has been approved by CEN as EN ISO 21805:2023 without any modification.

INTERNATIONAL STANDARD

ISO 21805

First edition
2023-02

Guidance and recommendations on design, selection and installation of vents to safeguard the structural integrity of enclosures protected by gaseous fire-extinguishing systems

*Lignes directrices et recommandations relatives à la conception,
à la sélection et à l'installation d'évents pour préserver l'intégrité
structurelle des enceintes protégées par des systèmes d'extinction
d'incendie à gaz*



Reference number
ISO 21805:2023(E)

© ISO 2023

ISO 21805:2023(E)**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and abbreviated terms	2
5 Use and limitations	3
6 Safety	4
6.1 Structural safety.....	4
6.2 Personnel safety.....	4
7 System design — Pressure-relief venting	4
7.1 General.....	4
7.2 Extinguishant characteristics.....	5
7.2.1 Positive and negative pressurization.....	5
7.2.2 Pressure graphs.....	5
7.3 Enclosure characteristics.....	6
7.4 Pressure-relief vent paths.....	6
7.5 Types of pressure-relief vents.....	7
7.5.1 General.....	7
7.5.2 Gravity vents.....	7
7.5.3 Counterweighted flap vent.....	7
7.5.4 Electrically-operated vents.....	8
7.5.5 Pneumatically-operated vent.....	8
7.5.6 Vent accessories.....	8
7.6 Pressure-relief vent characteristics.....	9
7.6.1 Vent efficiency.....	9
7.6.2 Minimum opening pressure.....	10
7.6.3 Minimum closing pressure.....	10
7.6.4 Fire rating.....	10
7.7 Vent location and mounting.....	10
7.7.1 Vent location.....	10
7.7.2 Vent mounting.....	11
7.8 Pressure-relief vent area calculations.....	12
7.8.1 Use of agent-specific formulae.....	12
7.8.2 Vent area requirement (non-liquefiable gases).....	13
7.8.3 Vent area requirement carbon dioxide.....	16
7.8.4 Vent area requirements (liquefiable gases).....	16
7.8.5 Leakage.....	22
7.9 Cascade venting calculations.....	22
7.9.1 Example calculation 3: Cascade venting calculations for IG-541 (peak discharge).....	23
7.9.2 Cascade vent arrangements.....	24
7.9.3 Venting into adjacent enclosures.....	25
8 System design — Post-discharge venting	27
9 Acceptance	27
10 Service and maintenance	27
Annex A (informative) Development of agent-specific formulae for liquefiable gases	29
Annex B (informative) Method for development of agent-specific formulae for liquefiable gases	34

ISO 21805:2023(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and firefighting*, Subcommittee SC 8, *Gaseous media and firefighting systems using gas*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 191, *Fixed firefighting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This first edition cancels and replaces the first edition (ISO/TS 21805:2018), which has been technically revised.

The main changes are as follows:

- subclause [7.8.3](#) has been amended to cross-reference ISO 6183 for vent area calculations for CO₂;
- [Annex A](#) has been added, providing guidance on how testing in order to derive the agent-specific formulae;
- [Annex B](#) has been added, providing guidance on the procedure for developing coefficients for any new agents in the ISO 14520 series.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

The guidance presented in this document is based on the results of a joint research programme conducted in 2006 and 2007 by several fire protection system manufacturers and interested parties. The programme of work consisted of several series of tests to evaluate the peak pressure response and pressure-relief vent area effects for each agent addressed in this document. The key data used in the development of this document were the values of peak enclosure pressure response (P_{MAX}) at each value of the volume-normalized pressure-relief vent area of the test enclosure, hereinafter referred to as the “leakage-to-volume ratio” or LVR. Other test parameters (enclosure temperature, agent quantity, discharge time and humidity) were held constant or varied in a specified manner. For each test series employing a single agent, the several pairs of LVR and resultant P_{MAX} values were graphically analysed, and a best-fit correlation curve was determined.

The LVR vs. P_{MAX} correlation curve for each agent or system forms the basis of the associated formulae in cases where the discharge of the agent results in cooling the air temperature below its dew point. Only halocarbon agents cause sufficient cooling to cause humidity-related effects on the peak enclosure pressure. Thus, a correction for humidity effects is included in the formulae for estimating vent area and maximum pressure on the discharge of the following agents:

- FK-5-1-12
- HFC-23
- HFC-125
- HFC-227ea

The humidity corrections used in this document are based on the results of tests conducted with HFC-227ea at different conditions of humidity.

The resulting values for humidity correction will be assumed to be equally applicable to the agents FK-5-1-12, HFC-125 and HFC-23 until further data or analyses indicate otherwise.

The correlations of LVR to maximum negative pressure and maximum positive pressure were based on test work performed in a test chamber at a relative humidity (RH) of approximately 38 %. If the RH in a protected enclosure differs from 38 % then a correction to the estimated maximum negative and positive pressures can be required. See [7.8](#) and [7.9](#) for further information on the effect of humidity. The temperature of the test enclosure was 21°C (nominal) for all tests that form the basis of the estimating methods given in this document.

In conducting the research programme described above, a large number of different venting arrangements were created in the test enclosure. The equivalent leakage area (ELA) for each test was determined by a “door fan test” and data analysis. The average enclosure pressure in effect during the many door fan tests varied from test to test. All values of ELA were normalized to an equivalent enclosure differential pressure of 125 Pa. The resulting enclosure correlations of peak pressure vs. LVR, and any resulting estimate of enclosure pressure-relief vent area, reflect a pressure-relief vent area calculated at an effective enclosure pressure of 125 Pa for a vent with a discharge coefficient of 0,61.

The effectiveness of a gaseous total flooding firefighting system depends, in part, on retention of the air-extinguishant mixture within the protected volume for a period of time. Retention of the extinguishant-air mixture requires that gas exchange (“leakage”) between the enclosure and the ambient environment be restricted. To limit the rate of gas exchange, the enclosure boundary should have a high degree of integrity. To put it another way, the total of the areas of the various penetrations in an enclosure’s bounding surfaces should be low, at least during the gas-retention period (hold time) after the end of the extinguishant discharge.

The addition of a gaseous firefighting extinguishant to an enclosure having a limited pressure-relief vent area will naturally result in a change of pressure therein. If the enclosure is sealed too tightly during the extinguishant discharge, i.e. too little pressure-relief vent area, the pressure change could exceed the structural strength of one or more of its bounding surfaces — windows, doors, walls,

ISO 21805:2023(E)

ceiling. Conversely, if the enclosure has too much pressure-relief vent area then gas exchange with the ambient atmosphere will occur rapidly, leading to a short retention time of the extinguishant within the protected volume.

Thus, the use of gaseous firefighting systems should address two performance considerations:

- a) pressure management within the protected volume during the period of extinguishant discharge, and;
- b) retention of the extinguishant-air mixture within the enclosure for a specified period of time after the completion of the discharge.

This document provides guidance for limiting pressure extremes in an enclosure during the discharge of a clean agent fire extinguishing system. This document does not provide the information necessary to determine all of the requirements related to the design, installation, service, maintenance, inspection, test and/or requalification of fire suppression systems.

Some limitations and restrictions apply to the use of the formulae contained in this document. Please refer to the text and notes that follow them.

The information in this document does not supersede the manufacturer's guidance. The information contained in this document is presented as being supplementary to the guidance provided by the respective system manufacturers. Guidance from the system manufacturer should always be followed and used for purposes of system design, installation, operation and maintenance.

It has been assumed in the preparation of this document that the execution of its provisions is entrusted to people appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid unnecessary release of extinguishant.

Guidance and recommendations on design, selection and installation of vents to safeguard the structural integrity of enclosures protected by gaseous fire-extinguishing systems

1 Scope

This document gives guidelines for fulfilling the requirements contained in ISO 6183:2022, 6.4.1 and 7.4.1 and ISO 14520-1:2023, 5.2.1 h) and 5.3 h), in respect to over- and under-pressurization venting and post-discharge extract.

It considers the design, selection and installation of vents to safeguard the structural integrity of enclosures protected by fixed gaseous extinguishing systems and the post-discharge venting provisions where used.

2 Normative references

There are no normative references in this document.

koniec náhľadu – text ďalej pokračuje v platenej verzii STN