

STN	Informačná technika Zariadenia a infraštruktúry výpočtových stredísk Časť 2-4: Infraštruktúra kabeláže telekomunikácií	STN EN 50600-2-4 36 7254
------------	---	--

Information technology - Data centre facilities and infrastructures - Part 2-4: Telecommunications cabling infrastructure

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 05/23

Obsahuje: EN 50600-2-4:2023

Oznámením tejto normy sa od 20.03.2026 ruší
STN EN 50600-2-4 (36 7254) zo septembra 2015

136889

EUROPEAN STANDARD

EN 50600-2-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2023

ICS 35.110; 35.020; 35.160

Supersedes EN 50600-2-4:2015

English Version

**Information technology - Data centre facilities and infrastructures
- Part 2-4: Telecommunications cabling infrastructure**

Technologies de l'information - Installation et infrastructures
de centres de traitement de données - Partie 2-4:
Infrastructure du câblage dédié aux télécommunications

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 2-4: Infrastruktur der
Telekommunikationsverkabelung

This European Standard was approved by CENELEC on 2023-03-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 50600-2-4:2023 (E)

Contents	Page
European foreword	5
Introduction	6
1 Scope	9
2 Normative references	9
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions	10
3.2 Abbreviations	14
4 Conformance	15
5 Telecommunications cabling within the data centre	15
5.1 General	15
5.2 Requirements for cabling supporting the IT operations in all data centre spaces.....	16
5.3 Requirements for cabling providing distributed building services in all data centre spaces	16
5.4 Requirements for cabling for IT and network telecommunications to and within the computer room space.....	17
5.4.1 General	17
5.4.2 Point-to-point cabling	17
5.4.3 Requirements for fixed cabling	19
6 Implementation of cabling in accordance with EN 50173-5	20
6.1 General	20
6.2 Functional elements.....	20
6.3 Distribution areas and spaces	21
6.3.1 General	21
6.3.2 Distribution areas.....	23
6.3.3 Building entrance facility	24
6.3.4 Entrance rooms	25
6.4 Infrastructures supporting the functional elements of EN 50173-5	25
6.4.1 General	25
6.4.2 Pathways and pathway systems for telecommunications cabling.....	25
6.4.3 Cabinets, frames and racks for the computer room space.....	26
7 Physical Security	27
7.1 General	27
7.2 Protection against unauthorized access	27
7.2.1 Pathways and spaces.....	27
7.2.2 Entrance room	28
7.3 Protection against internal events	28

8	Availability classification for the telecommunications cabling infrastructure, infrastructure elements, facilities and spaces	28
8.1	General	28
8.2	Availability design principles for telecommunications cabling infrastructure	29
8.3	Overview about the availability classes for telecommunications cabling	30
8.4	Availability Class design requirements and recommendations	30
8.4.1	Transmission channel design for the network distribution cabling	30
8.4.2	Availability Class 1	31
8.4.3	Availability Class 2	32
8.4.4	Availability Class 3	35
8.4.5	Availability Class 4	38
9	Management and operation of the telecommunications cabling infrastructure	40
9.1	General	40
9.2	Automated infrastructure management systems	40
	Annex A (informative) Design concepts for network distribution cabling	41
	Annex B (informative) Energy efficiency considerations for the telecommunications cabling infrastructure	50
	Annex C (informative) Summary of requirements	51
	Annex D (informative) Examples of telecommunications cabling infrastructures including active equipment	53
	Annex E (informative) Availability description	56
	Annex F (normative) Availability Classes for cabling infrastructures in colocation data centres ..	57
	Bibliography	61

Figures

Figure 1	— Schematic relationship between the EN 50600 series of documents	7
Figure 2	— Schematic relationship between the EN 50600-2-4 and other European cabling design and installation standards	8
Figure 3	— Impact of growth in an unstructured point-to-point cabling infrastructure	18
Figure 4	— Structured cabling infrastructure: setup and growth	19
Figure 5	— Functional elements and cabling subsystems of EN 50173-5	21
Figure 6	— Facilities and spaces relevant for cabling according EN 50173-5	22
Figure 7	— Areas providing accommodation for distributors of EN 50173-5 and connected active equipment	23
Figure 8	— Principle of supply and distribution	29
Figure 9	— Transmission channels (interconnect and cross-connect)	31
Figure 10	— Telecommunication cabling Class 1 using direct attached cords	32
Figure 11	— Telecommunication cabling Class 1	32
Figure 12	— Telecommunication cabling Class 2	33
Figure 13	— Managing moves, adds and changes	34
Figure 14	— Telecommunication cabling Class 3 with one entrance room	36

EN 50600-2-4:2023 (E)

Figure 15 — Telecommunication cabling Class 3 with two entrance rooms.....	36
Figure 16 — Telecommunication cabling Class 4.....	39
Figure A.1 — Symbols of network elements	41
Figure A.2 — Example of a Class 1 cabling implementation	42
Figure A.3 — Example for Class 2 EoR cabling implementation	43
Figure A.4 — Example for Class 2 MoR cabling implementation	44
Figure A.5 — Example for Class 2 ToR cabling implementation	45
Figure A.6 — Example for Class 3 EoR cabling implementation	46
Figure A.7 — Example for Class 3 ToR cabling implementation	47
Figure A.8 — Example for Class 4 EoR cabling implementation	48
Figure A.9 — Example for Class 4 ToR cabling implementation	49
Figure D.1 — Example of Availability Class 3 cabling and active equipment with one entrance room	53
Figure D.2 — Example of Availability Class 3 cabling and active equipment with two entrance rooms.....	54
Figure D.3 — Example of Availability Class 4 cabling and active equipment.....	54
Figure D.4 — Example of Availability Class 3 cabling and active equipment implemented across multiple floors.....	55
Figure D.5 — Example of Availability Class 3 cabling and active equipment implemented across multiple floors.....	55
Figure F.1 — Telecommunications supply cabling for a single building colocation (AC 3)	59
Figure F.2 — Telecommunications supply cabling for a single building colocation (AC 4)	59
Figure F.3 — Telecommunications supply cabling for a multi building colocation (AC 4)	60

Tables

Table 1 — Telecommunication cabling Availability Classes per space and overall data centre Availability Class.....	30
Table C.1 — Telecommunications cabling infrastructure requirements per Availability Class	51
Table E.1 — Summary of availability classification.....	56

European foreword

This document (EN 50600-2-4:2023) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-03-20
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2026-03-20

This document supersedes EN 50600-2-4:2015.

The following major modifications have been made compared to EN 50600-2-4:2015:

- a) the document structure has been completely revised;
- b) the availability classes have been revised;
- c) a clause on physical security has been added (Clause 7);
- d) Annex C summarizing the requirements and recommendations of the document has been added;
- e) Annex D with examples for cabling infrastructures including the location of active equipment has been added;
- f) Annex E with an availability description has been added;
- g) Annex F with specific requirements for colocation data centres has been added.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

EN 50600-2-4:2023 (E)**Introduction**

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of carbon footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is required to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TS 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this document, the EN 50600-2 series comprises the following documents:

- EN 50600-2-1, *Information technology - Data centre facilities and infrastructures - Part 2-1: Building construction*
- CLC/TS 50600-2-10, *Information technology - Data centre facilities and infrastructures - Part 2-10: Earthquake risk and impact analysis*
- EN 50600-2-2, *Information technology - Data centre facilities and infrastructures - Part 2-2: Power supply and distribution*
- EN 50600-2-3, *Information technology - Data centre facilities and infrastructures - Part 2-3: Environmental control*
- EN 50600-2-4, *Information technology - Data centre facilities and infrastructures - Part 2-4: Telecommunications cabling infrastructure*
- EN 50600-2-5, *Information technology - Data centre facilities and infrastructures - Part 2-5: Security systems*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series of documents

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

This document addresses the specific requirements for the telecommunications cabling infrastructure in data centres used for the purpose of IT networking and building services (in accordance with the requirements of EN 50600-1).

EN 50600-2-4:2023 (E)

This document is intended for use by and collaboration between architects, building designers and builders, system and installation designers.

This series of documents does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

Figure 2 shows the schematic and contextual relationships of the EN 50600-2-4 with other cabling and cabling installation related European standards.




Figure 2 — Schematic relationship between the EN 50600-2-4 and other European cabling design and installation standards

The importance of the information technology and network telecommunications cabling infrastructure is similar to that of other infrastructures such as environmental control, power distribution and security systems. As with other utilities, interruptions to service can have a serious impact. Poor quality of service due to lack of planning, use of inappropriate components, incorrect installation, poor administration or inadequate support can threaten an organization's effectiveness.

1 Scope

This document specifies design principles for information technology and network telecommunications cabling (e.g. SAN and LAN) in accordance with EN 50173-5, based upon the criteria and classifications for “availability” and “physical security” within EN 50600-1.

This document addresses the telecommunications cabling infrastructures used in data centres. It describes:

- a) for design, the application of generic cabling standards in the EN 50173 series;
- b) for installation specification, planning and practices and quality assurance, the application of standards in the EN 50174 series (and related standards).

In addition, this document specifies requirements and recommendations for the following:

- 1) general information technology cabling to support the IT operation of the data centre;
- 2) telecommunications cabling to monitor and control, as appropriate, power distribution, environmental control and physical security of the data centre;
- 3) other building automation cabling;
- 4) pathways, pathway systems, spaces and enclosures for the telecommunications cabling infrastructures.

Safety and electromagnetic compatibility (EMC) requirements are outside the scope of this document and are covered by other standards and regulations. However, information given in this document can be of assistance in meeting these standards and regulations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50173-2, *Information technology - Generic cabling systems - Part 2: Office spaces*

EN 50173-5, *Information technology - Generic cabling systems - Part 5: Data centre spaces*

EN 50173-6, *Information technology - Generic cabling systems - Part 6: Distributed building services*

EN 50174-1:2018,¹ *Information technology — Cabling installation — Part 1: Installation specification and quality assurance*

EN 50174-2:2018, *Information technology - Cabling installation - Part 2: Installation planning and practices inside buildings*

EN 50174-3, *Information technology - Cabling installation - Part 3: Installation planning and practices outside buildings*

EN 50310, *Telecommunications bonding networks for buildings and other structures*

EN 50600-1:2019, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*

¹ As amended by EN 50174-1:2018/A1:2020.

EN 50600-2-4:2023 (E)

EN 50600-2-2, *Information technology - Data centre facilities and infrastructures - Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology - Data centre facilities and infrastructures - Part 2-3: Environmental control*

EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN