

STN	Zariadenia na meranie elektrickej energie Časť 4: Osobitné požiadavky Statické elektromery na činnú energiu jednosmerného prúdu (trieda A, B a C)	STN EN 50470-4 35 6134
------------	--	--

Electricity metering equipment - Part 4: Particular requirements - Static meters for DC active energy (class indexes A, B and C)

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 10/23

Obsahuje: EN 50470-4:2023

137628

EUROPEAN STANDARD

EN 50470-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2023

ICS 91.140.50

English Version

**Electricity metering equipment - Part 4: Particular requirements -
Static meters for DC active energy (class indexes A, B and C)**

Équipement de comptage de l'électricité - Partie 4:
Exigences particulières - Compteurs statiques d'énergie
active en courant continu (indices de classe A, B et C)

Elektrizitätszähler - Teil 4: Besondere Anforderungen -
Elektronische Wirkverbrauchszähler für Gleichstrom der
Genauigkeitsklassen A, B und C

This European Standard was approved by CENELEC on 2023-07-24. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 50470-4:2023 (E)

Contents	Page
European foreword.....	4
1 Scope	5
2 Normative references	6
3 Terms and definitions	7
4 Standard electrical values	9
4.1 Voltages	9
4.2 Currents	9
4.2.1 General.....	9
4.2.2 Nominal current	10
4.2.3 Starting current.....	10
4.2.4 Minimum current.....	10
4.2.5 Maximum current.....	10
4.3 Power consumption	10
4.4 MMQ	11
4.5 Integration (averaging) time	11
5 Construction requirements.....	11
5.1 General.....	11
5.2 Meters with reduced overvoltage category (OVC) or reduced measurement category (CAT)	12
6 Meter marking and documentation	12
6.1 General.....	12
6.2 MMQ	12
7 Accuracy requirements	12
7.1 General test conditions	12
7.2 Methods of accuracy verification.....	13
7.3 Measurement uncertainty	13
7.4 Meter constant	13
7.5 Initial start-up of the meter	13
7.6 Test of no-load condition.....	13
7.7 Starting current test	13
7.8 Repeatability test	13
7.9 Allowable errors due to variation of the current	13
7.10 Allowable errors due to influence quantities and disturbances.....	14
7.11 Time-keeping accuracy	17
7.12 Accuracy tests at reference conditions and when affected by influence quantities	17
7.13 Error of measurement	17
7.14 Error of measurement for small amounts of energy.....	18
8 Climatic conditions.....	18
8.1 General.....	18
8.2 Test of the effect of the climatic environments	19
8.3 Meters specified for temperature ranges exceeding those of Table 14.....	19
9 The effects of external influences.....	19
9.1 General.....	19
9.2 Conducted differential mode current disturbances for DC meters	19
9.3 Voltage unbalance	20
10 Requirements concerning the software and protection against corruption	20
10.1 General.....	20
10.2 Identification of functions implemented in software	21

10.3	Identification and protection of software	21
10.4	Identification and protection of metrologically relevant parameters	21
10.5	Setting of parameters	21
10.6	Protection of measurement data	22
10.7	Protection against influence by metrologically non-relevant software	22
10.8	Protection against influence by connecting another device	22
10.9	Meters intended for transmission of transaction data	22
11	Type test	22
12	Durability	22
13	Reliability	23
Annex A (informative) Calculation of the error of measurement		24
Annex B (informative) Differential mode current disturbance test		25
Annex C (informative) Differences between IEC and Directive 2014/32/EU		26
Annex D (informative) Accuracy classes and class indexes		28
D.1	General	28
D.2	Class indexes	28
Annex ZZ (informative) Relationship between this European standard and the essential requirements of Directive 2014/32/EU aimed to be covered		29
Bibliography		32

EN 50470-4:2023 (E)**European foreword**

This document (EN 50470-4:2023) has been prepared by CLC/TC 13 “Electrical energy measurement and control”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-07-24
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2026-07-24

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is used in conjunction with EN IEC 62052-11:2021¹.

This document is related to EN IEC 62053-41:2021², *Electricity metering equipment - Particular requirements - Part 41: Static meters for DC energy (classes 0,5 and 1)*.

NOTE Terms differences for accuracy classes in related standard (EN IEC 62053-41:2021²) and Directive 2014/32/EU are listed in Annex D.

The structure of the standards is similar; modifications in this document are provided in the perspective of compliance with the Essential Requirements of Directive 2014/32/EU on Measuring Instruments (MID).

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annex ZZ, which is an integral part of this document.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

¹ As impacted by EN IEC 62052-11:2021/A11:2022.

² To be published. Stage at the time of publication: FprEN IEC 62053-41:2021.

1 Scope

This document applies only to static watt-hour meters of accuracy classes A, B and C for the measurement of direct current electrical active energy in DC systems and it applies to their type tests.

NOTE 1 For general requirements, such as construction, EMC, safety, dependability etc., see the relevant EN 62052 series or EN 62059 series.

This document applies to electricity metering equipment designed to:

- measure and control electrical energy on DC electrical networks with voltages up to 1 500 V;

NOTE 2 Meters for unearthed DC supplies and meters for three-wire DC networks are within the scope of this document.

- form a complete meter including the legally relevant display of measured values;

NOTE 3 Electrical energy meters constructed from separate parts as described in WELMEC Guide 11.7:2017 are included.

- operate with integrated or detached legally relevant displays;
- optionally, provide additional functions other than those for measurement of electrical energy.

They can be used for measuring DC electrical energy, amongst others, in the following application areas:

- in EV (electrical vehicle) charging stations or in EV charging infrastructure (also called EVSE, electric vehicle supply equipment), if energy is measured on the DC side;
- in solar PV (photovoltaic) systems where DC power generation is measured;
- in low voltage DC networks for residential or commercial areas, if energy is measured on the DC side, including similar applications like information technology (IT) server farms or DC supply points for communication equipment;
- in DC supply points for public transport networks (e.g. for trolleybuses);
- in mobile applications on vehicles for e-road (electric road) systems.

Meters designed for operation with external DC instrument transformers, transducers or shunts can be tested for compliance with this document only if such meters and their transformers, transducers or shunts are tested together and meet the requirements for directly connected meters. Requirements in this document and in EN IEC 62052-11:2021¹ applying to meters designed for operation with DC LPITs also apply to meters designed for operation with external instrument transformers, transducers or shunts.

NOTE 4 Modern electricity meters typically contain additional functions such as measurement of voltage magnitude, current magnitude, power, etc.; measurement of power quality parameters; load control functions; delivery, time, test, accounting, recording functions; data communication interfaces and associated data security functions. The relevant standards for these functions could apply in addition to the requirements of this document. However, the requirements for such functions are outside the scope of this document.

NOTE 5 Product requirements for power metering and monitoring devices (PMDs) and measurement functions such as voltage magnitude, current magnitude, power, etc., are covered in EN IEC 61557-12:2022⁷. However, devices compliant with EN IEC 61557-12:2022⁷ are not intended to be used as billing meters unless they are also compliant with EN IEC 62052-11:2021¹ and this document.

NOTE 6 Requirements for DC power quality (PQ) instruments, DC PQ measuring techniques, and DC PQ instrument testing are under discussion and will be specified in other standards.

EN 50470-4:2023 (E)

This document does not apply to:

- portable meters;

NOTE 7 Portable meters are meters that are not permanently connected.

- meters used in rolling stock (railway applications), ships and airplanes;

NOTE 8 DC meters for rolling stock are covered by other standards, e.g. by the EN 50463 series.

- laboratory and meter test equipment;
- reference standard meters;
- data interfaces to the register of the meter;
- matching sockets or racks used for installation of electricity metering equipment;
- any additional functions provided in electrical energy meters.

This document does not cover measures for the detection and prevention of fraudulent attempts to compromise meter's performance (tampering).

NOTE 9 Nevertheless, specific tampering detection and prevention requirements, and test methods, as relevant for a particular market are subject to the agreement between the manufacturer and the purchaser.

NOTE 10 Specifying requirements and test methods for fraud detection and prevention would be counterproductive, as such specifications would provide guidance for potential fraudsters.

NOTE 11 There are many types of meter tampering reported from various markets; therefore, designing meters to detect and prevent all types of tampering could lead to unjustified increase in costs of meter design, verification, and validation.

NOTE 12 Billing systems, such as smart metering systems, are capable of detecting irregular consumption patterns and irregular network losses which enable discovery of suspected meter tampering.

NOTE 13 This document does not specify emission requirements. These are specified in EN IEC 62052-11:2021¹, 9.3.14.

NOTE 14 Some aspects of meters for EVSE included in this document are expected to be covered by future documents being worked on in WG 03 of CLC/TC 13 (EN 50732), so they may be removed in future editions of this standard.

2 Normative references

The following documents are referred to in the text in such a way that some of or all their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 61000-4-19:2014, *Electromagnetic compatibility (EMC) - Part 4-19: Testing and measurement techniques - Test for immunity to conducted, differential mode disturbances and signalling in the frequency range 2 kHz to 150 kHz at a.c. power ports (IEC 61000-4-19:2014)*

EN 61010-1:2010³, *Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements (IEC 61010-1:2010)*

³ As impacted by EN 61010-1:2010/A1:2019 and EN 61010-1:2010/A1:2019/AC:2019-04.

EN IEC 61010-2-030:2021⁴, *Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-030: Particular requirements for equipment having testing or measuring circuits (IEC 61010-2-030:2017)*

EN IEC 62052-11:2021¹, *Electricity metering equipment - General requirements, tests and test conditions - Part 11: Metering equipment (IEC 62052-11:2020)*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN

⁴ As impacted by EN IEC 61010-2-030:2021/A11:2021.