

|            |   |  |
|------------|---|--|
| <b>STN</b> | <b>Stavebné výrobky</b><br><b>Posudzovanie uvoľňovania nebezpečných látok</b><br><b>Časť 3: Všeobecná skúška s vylúhovaním</b><br><b>smerom nahor</b> | <b>STN</b><br><b>EN 16637-3</b><br><br>72 0018 |
|------------|---|--|

Construction products: Assessment of release of dangerous substances - Part 3: Horizontal up-flow percolation test

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 02/24

Obsahuje: EN 16637-3:2023

Oznámením tejto normy sa ruší  
STN P CEN/TS 16637-3 (72 0018) z februára 2017

**137987**

EUROPEAN STANDARD

**EN 16637-3**

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2023

ICS 91.100.01

Supersedes CEN/TS 16637-3:2016

English Version

## Construction products: Assessment of release of dangerous substances - Part 3: Horizontal up-flow percolation test

Produits de construction - Évaluation du relargage de substances dangereuses - Partie 3 : Essai horizontal de percolation à écoulement ascendant

Bauprodukte - Bewertung der Freisetzung von gefährlichen Stoffen - Teil 3: Horizontale Perkolationsprüfung im Aufwärtsstrom

This European Standard was approved by CEN on 30 July 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## EN 16637-3:2023 (E)

| <b>Contents</b>                |   | <b>Page</b> |
|--------------------------------|---|-------------|
| <b>European foreword .....</b> |   | <b>4</b>    |
| <b>Introduction .....</b>      |   | <b>6</b>    |
| <b>1</b>                       | <b>Scope.....</b>   | <b>7</b>    |
| <b>2</b>                       | <b>Normative references.....</b>                                    | <b>7</b>    |
| <b>3</b>                       | <b>Terms and definitions .....</b>                                  | <b>8</b>    |
| <b>4</b>                       | <b>Symbols and abbreviations .....</b>                              | <b>11</b>   |
| <b>4.1</b>                     | <b>Symbols .....</b>  | <b>11</b>   |
| <b>4.2</b>                     | <b>Abbreviations.....</b>   | <b>11</b>   |
| <b>5</b>                       | <b>Principle.....</b>   | <b>12</b>   |
| <b>5.1</b>                     | <b>General principles .....</b>                                     | <b>12</b>   |
| <b>5.2</b>                     | <b>Number of eluates.....</b>                                       | <b>12</b>   |
| <b>6</b>                       | <b>Reagents.....</b>  | <b>13</b>   |
| <b>7</b>                       | <b>Equipment.....</b>   | <b>14</b>   |
| <b>8</b>                       | <b>Sample preparation .....</b>                                     | <b>16</b>   |
| <b>8.1</b>                     | <b>General.....</b>   | <b>16</b>   |
| <b>8.2</b>                     | <b>Preparation of the test sample.....</b>                          | <b>16</b>   |
| <b>8.2.1</b>                   | <b>Principles.....</b>  | <b>16</b>   |
| <b>8.2.2</b>                   | <b>Rules of application.....</b>                                    | <b>16</b>   |
| <b>8.3</b>                     | <b>Test portion .....</b>   | <b>17</b>   |
| <b>8.4</b>                     | <b>Drying.....</b>  | <b>17</b>   |
| <b>8.5</b>                     | <b>Subsampling .....</b>  | <b>17</b>   |
| <b>8.6</b>                     | <b>Sieving of samples into fractions.....</b>                       | <b>18</b>   |
| <b>8.7</b>                     | <b>Size reduction of particles .....</b>                            | <b>18</b>   |
| <b>9</b>                       | <b>Test procedure.....</b>  | <b>18</b>   |
| <b>9.1</b>                     | <b>Temperature.....</b>   | <b>18</b>   |
| <b>9.2</b>                     | <b>Determination of dry residue.....</b>                            | <b>18</b>   |
| <b>9.3</b>                     | <b>Pre-treatment of the column .....</b>                            | <b>18</b>   |
| <b>9.4</b>                     | <b>Packing of the column .....</b>                                  | <b>19</b>   |
| <b>9.4.1</b>                   | <b>General.....</b>   | <b>19</b>   |
| <b>9.4.2</b>                   | <b>Equilibration.....</b>   | <b>19</b>   |
| <b>9.4.3</b>                   | <b>Calculation of the flow rate .....</b>                           | <b>19</b>   |
| <b>9.5</b>                     | <b>Collection of eluates.....</b>                                   | <b>19</b>   |
| <b>9.6</b>                     | <b>Further preparation of the eluates for analysis .....</b>        | <b>22</b>   |
| <b>9.7</b>                     | <b>Blank test .....</b>   | <b>22</b>   |
| <b>10</b>                      | <b>Evaluation of measurement results .....</b>                      | <b>22</b>   |
| <b>10.1</b>                    | <b>Expression of results in concentrations .....</b>                | <b>22</b>   |
| <b>10.2</b>                    | <b>Expression of results in terms of mass related release .....</b> | <b>22</b>   |
| <b>11</b>                      | <b>Documentation and test report .....</b>                          | <b>23</b>   |
| <b>12</b>                      | <b>Test performance.....</b>  | <b>25</b>   |
| <b>13</b>                      | <b>Indirect methods.....</b>  | <b>25</b>   |
| <b>13.1</b>                    | <b>Definition .....</b>   | <b>25</b>   |

|   |           |
|---|-----------|
| <b>13.2 Provisions</b> .....  | <b>25</b> |
| <b>13.3 Examples of indirect methods</b> .....  | <b>25</b> |
| <b>Annex A (informative) Examples of sample preparation procedures</b> .....  | <b>26</b> |
| <b>Annex B (informative) Illustration of the column and accompanying equipment</b> .....                            | <b>29</b> |
| <b>Annex C (informative) Procedures for packing and saturation of the column</b> .....                              | <b>30</b> |
| <b>Annex D (informative) Assessment of release mechanism(s)</b> .....   | <b>33</b> |
| <b>Annex E (informative) Summary of cumulative results for <math>L/S = 2</math> and <math>L/S = 10</math></b> ..... | <b>53</b> |
| <b>Bibliography</b> .....   | <b>69</b> |

**EN 16637-3:2023 (E)****European foreword**

This document (EN 16637-3:2023) has been prepared by Technical Committee CEN/TC 351 "Construction products: Assessment of release of dangerous substances", the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2024 and conflicting national standards shall be withdrawn at the latest by May 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN/TS 16637-3:2016.

The main changes compared to the previous edition are as follows:

- transfer of technical specification into a European Standard;
- addition of validation data from interlaboratory validation on repeatability and reproducibility (see Clause 12 and Annex E);
- addition of requirements on the number of eluates (see 5.2);
- alignment of the test conditions with the test conditions which are specified in EN 17516;
- updating of normative and informative cross-references.

This document has been prepared under a standardization request addressed to CEN by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

This document was elaborated on the basis of CEN/TS 14405 [1].

This document specifies an up-flow percolation test to determine the leaching behaviour of granular construction products under standardized percolation conditions.

EN 16637, *Construction products: Assessment of release of dangerous substances*, consists of the following parts:

- *Part 1: Guidance for the determination of leaching tests and additional testing steps;*
- *Part 2: Horizontal dynamic surface leaching test;*
- *Part 3: Horizontal up-flow percolation test.*

EN 16637-1 deals with the determination and use of test methods for leaching of construction products taking specific situations into account. EN 16637-2 specifies a dynamic surface leaching test for determination of surface dependent release of substances from monolithic or plate-like or sheet-like construction products or granular construction products with low hydraulic conductivity under standardized conditions.

Background information on characterization of leaching behaviour of construction products can be found in Technical Reports provided by CEN/TC 351 (i.e. CEN/TR 16098 [2], CEN/TR 16496 [3]).

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

## EN 16637-3:2023 (E)

### Introduction

The European Standards EN 16637-1, EN 16637-2 and EN 16637-3 are developed to assess the release of regulated dangerous substances (RDS) from construction products into soil, surface water and groundwater in the framework of Mandate M/366. The horizontal test methods developed under the Mandate M/366 are intended to be used to show compliance with notified regulations. The tests cover the release of substances from construction products and in particular, those that are regulated in notified regulations in one or more EU Member States.

EN 16637-1 specifies how the CEN Technical Product Committees and EOTA experts should determine the appropriate leaching test for the determination of the release of RDS from a construction product into soil, surface water and groundwater. EN 16637-1 gives background information for CEN Technical Product Committees on the following aspects:

- a) description of the intended conditions of use of the construction product (e.g. above ground exposed to the precipitation, or shielded from direct infiltration, in surface or groundwater) with respect to the release of RDS into soil, surface water and groundwater;
- b) identification of main release mechanisms, and the appropriate leaching test for a given construction product.

EN 16637-2 specifies a horizontal test to assess surface dependent release from monolithic, plate-like or sheet-like construction products (tank test).

EN 16637-3 specifies a horizontal test to assess release from granular construction products.

The test methods can be used for both steps in the hierarchy (type testing (TT) and factory production control (FPC)) and form the reference tests for the intended uses and conditions specified in EN 16637-1. In this hierarchy of testing conditionally “indirect tests” can be used, but are not specified.

The release of substances upon contact with water results in a potential risk to the environment during the intended use of construction products. The intent of these tests is to identify the leaching behaviour of construction products and thereby allow assessments of the release of RDS from such products to soil, surface water and groundwater under intended conditions of use in relation to CE marking and assessment and verification of constancy of performance.

This document does not address impact assessment. However, since the test methods described in the document may be used in the context of impact assessments and regulation based on impact assessments, some guidance on this issue is provided in EN 16637-1:2023, Annex A (informative).

In addition to existing validation results, in 2011 CEN/TC 351 began an extensive research program on robustness validation of the existing tank leaching and percolation tests. This was carried out by a consortium of European experts on 20 construction products to unify differences from the protocols of the different CEN Members and to check the influence of testing conditions on the test result (e.g. temperature, flow rate, renewal scheme). The results ([4], [22]) of the research program confirmed the robustness of the horizontal tests known from former works. Conclusions from the program have been implemented into the Technical Specifications for the test methods. The performance of the leaching tests regarding repeatability and reproducibility was deduced from a second validation step and respective data ([5], [6]) are included in EN 16637-2 and in this document.

## 1 Scope

This document specifies an up-flow percolation test (PT) which is applicable to determine the leaching behaviour of inorganic and non-volatile organic substances from granular construction products. The test is not suitable for substances that are volatile under ambient conditions. The construction products are subjected to percolation with water as a function of liquid to solid ratio under specified percolation conditions. The method is a once-through column leaching test.

NOTE 1 Volatile organic substances include the low molecular weight substances in mixtures such as mineral oil.

This up-flow percolation test is performed under specified test conditions for construction products and does not necessarily produce results that mimic specific intended use conditions. This test method produces eluates, which can subsequently be characterized by physical, chemical and ecotoxicological methods according to existing standard methods. The results of eluate analysis are presented as a function of the liquid/solid ratio. The test results enable the distinction between different leaching behaviour.

NOTE 2 It is not always possible to adjust test conditions simultaneously for inorganic and organic substances. Test conditions can also vary between different groups of organic substances. Test conditions for organic substances are generally more stringent than those for inorganic substances. The test conditions are generally described in a way that they fit testing organic substances and are also applicable to inorganic substances depending on the set-up.

NOTE 3 For ecotoxicity testing, eluates representing the release of both inorganic and organic substances are needed. In this document, ecotoxicological testing is meant to include also genotoxicological testing.

NOTE 4 Construction products with a low hydraulic conductivity that can cause detrimental pressure build-up are not supposed to be subjected to this test.

NOTE 5 This procedure is generally not applicable to products that are easily biologically degradable and products reacting with the leachant, leading, for example, to excessive gas emission or excessive heat release, impermeable hydraulically bound products or products that swell in contact with water.

In this document the same test conditions as for EN 17516 (CEN/TC 444/WG 1) are applied in order to allow full comparability of testing construction products and waste derived construction products to avoid double testing. The EN 17516 test results are eligible in the context of testing construction products as well.

NOTE 6 If a leaching test according to EN 17516 has been performed, additional EN 16637-3 testing does not need to be carried out.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 933-1, *Tests for geometrical properties of aggregates — Part 1: Determination of particle size distribution — Sieving method*

EN 15934, *Sludge, treated biowaste, soil and waste — Calculation of dry matter fraction after determination of dry residue or water content*

EN 16637-1, *Construction products: Assessment of release of dangerous substances — Part 1: Guidance for the determination of leaching tests and additional testing steps (under development)*

EN 16687:2023, *Construction products: Assessment of release of dangerous substances — Terminology*

**EN 16637-3:2023 (E)**

EN 17195, *Construction products: Assessment of release of dangerous substances — Analysis of inorganic substances in eluates*

EN ISO 5667-3, *Water quality — Sampling — Part 3: Preservation and handling of water samples (ISO 5667-3)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**