

<b>TNI</b>	<b>Plynárenská infraštruktúra</b> <b>Definície tlakov v CEN/TC 234</b> <b>Návod</b>	<b>TNI</b> <b>CEN/TR 16395</b>  38 6404
------------	---	--

Gas Infrastructure - CEN/TC 234 Pressure Definitions - Guideline Document

Táto technická normalizačná informácia obsahuje anglickú verziu CEN/TR 16395:2023.  
This Technical standard information includes the English version of CEN/TR 16395:2023.

Táto technická normalizačná informácia bola oznámená vo Vestníku ÚNMS SR č. 02/24

Oznámením tohto dokumentu sa ruší  
TNI CEN/TR 16395 (38 6404) z augusta 2013

TECHNICAL REPORT

CEN/TR 16395

RAPPORT TECHNIQUE

TECHNISCHER REPORT

November 2023

ICS 91.140.40

Supersedes CEN/TR 16395:2012

English Version

## Gas Infrastructure - CEN/TC 234 Pressure Definitions - Guideline Document

Infrastructures gazières - Définitions des pressions du  
CEN/TC 234 - Lignes directrices

Gasinfrastruktur - CEN/TC 234 Druckdefinitionen -  
Leitliniendokument

This Technical Report was approved by CEN on 13 November 2023. It has been drawn up by the Technical Committee CEN/TC 234.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

**CEN/TR 16395:2023 (E)**

<b>Contents</b>	<b>Page</b>
<b>European foreword .....</b>	<b>3</b>
<b>Introduction .....</b>	<b>4</b>
<b>1 Scope.....</b>	<b>6</b>
<b>2 Normative references.....</b>	<b>6</b>
<b>3 Terms and definitions .....</b>	<b>6</b>
<b>3.1 Key pressure definitions used in CEN/TC 234 standards .....</b>	<b>6</b>
<b>3.2 Derived pressure definitions used in CEN/TC 234 standards .....</b>	<b>7</b>
<b>3.3 Commonly used pressure definitions in European product standards .....</b>	<b>7</b>
<b>4 Explanation of Gas pressure definitions for gas transport and distribution systems. 8</b>	
<b>4.1 General.....</b>	<b>8</b>
<b>4.2 Pressure demarcation.....</b>	<b>8</b>
<b>4.3 Operating conditions.....</b>	<b>9</b>
<b>4.3.1 Normal operating conditions.....</b>	<b>9</b>
<b>4.3.2 Gas pressure under incidental operating conditions .....</b>	<b>9</b>
<b>4.4 Design pressure.....</b>	<b>10</b>
<b>4.5 Test pressures.....</b>	<b>10</b>
<b>4.6 Equipment in the scope of the European Pressure Equipment Directive .....</b>	<b>10</b>
<b>5 Relationships between MOP, TOP and MIP and test pressures .....</b>	<b>11</b>
<b>6 Pressure units in CEN/TC 234 European Standards .....</b>	<b>11</b>
<b>Annex A (informative) Examples of relationships between pressure designations .....</b>	<b>12</b>
<b>Annex B (informative) Industrial installations according to EN 15001 [16], [18] .....</b>	<b>14</b>
<b>Bibliography .....</b>	<b>15</b>

## **European foreword**

This document (CEN/TR 16395:2023) has been prepared by Technical Committee CEN/TC 234 “Gas Infrastructure”, the secretariat of which is held by DIN.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN/TR 16395:2012.

In comparison with the previous edition, the following modifications have been made:

- updating the scope for the alignment with the current scope of CEN/TC 234;
- updating of titles of the documents in the bibliography;
- addition of new documents published by CEN/TC 234 in the bibliography;
- updating of the reference to PED in term 3.3.1;
- introduction of a new clause on pressure units in CEN/TC 234 European Standards;
- editorial alignment of the wording to the current CEN drafting rules for Technical Reports.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

**CEN/TR 16395:2023 (E)****Introduction****Background**

The standards issued by CEN/TC 234 “Gas Infrastructure” contain a large number of definitions used for the design, testing and operation of the different parts of the gas infrastructure.

This document clarifies the CEN/TC 234 concept behind the pressure definitions and advises how to use the pressure definitions correctly and consistently. In order to further that goal an inventory of existing definitions is made and the primary definitions are identified.

This document also gives guidance for the selection of components falling into the scope of the European Pressure Equipment Directive (PED) [1] and used in the gas infrastructure.

Apart from the issue of the consistency of the pressure definition in the standards there is also the issue of the pressure rating of equipment and systems. Other classifications (e.g. PN or class) do not necessarily completely coincide with the classification as defined in the CEN/TC 234 standards.

Operating pressures levels of the gas infrastructure are different from one country to another in EU, because of many different factors such as history of gas systems, technologies and materials used or technical constraints.

When starting drafting the functional standards on gas infrastructure, CEN/TC 234 recognized various pressure levels and ranges in the European member countries, which are to some extent laid down in national laws.

To form a consensus for the standardization work, all pressure levels used in Europe have been brought together and classified in ranges. This subdivision in pressure levels also permits the manufacturers of components to focus on a limited number of designs in order to reduce the costs.

**Concept of pressure conditions**

On one hand three different sets of pressure conditions are to be considered:

- conditions during testing and commissioning ( $P_1$ );
- conditions during exceptional operating circumstances ( $P_2$ );
- conditions during normal operation ( $P_3$ ).

where:

$$P_1 > P_2 > P_3$$

The maximum pressure levels related to these conditions are the topic of the primary definitions.

On the other hand two other pressure conditions are used for specifying the system:

- pressure on which design calculations are based ( $p_A$ );
- pressure rating of the system ( $p_B$ ).

where

$$p_A > p_B.$$

The relationship between  $p_A$  and  $P_2$  or  $P_3$  is not uniform in the different CEN/TC 234 standards. This situation is confusing and undesirable. The recommended practice is stated in 4.4 and 4.5.

**Piping versus pressure regulating installations**

Only two out of the three aforementioned conditions apply when specifying piping:

- conditions during testing and commissioning;
- operating conditions.

Normally for piping no distinction is made between normal operating conditions and exceptional operating conditions, as piping is a passive component. However, in gas infrastructure piping and pressure regulating installations both are present. This necessitates identification of the “normal operating conditions” and “exceptional operating conditions” of the pressure regulating installations and the “operating conditions” of the piping.

**CEN/TR 16395:2023 (E)****1 Scope**

This document gives explanation on the pressure definitions and pressure units used by the gas network operators with regard to the standards of CEN/TC 234 “Gas Infrastructure”.

The European Standards of CEN/TC 234 cover the field of gas pipeline infrastructure for gaseous energy carriers and blends thereof from the input into the on-shore transmission network up to the inlet connection of gas appliances; This includes related functional requirements for injection, transmission, compression, pressure control, storage, blending, gas treatment, odorisation, distribution, measuring, and associated installation pipework, as well as related requirements such as safety, gas quality, sustainability, environment and emissions.

Within the scope of CEN/TC 234, gaseous energy carriers and blends describe gases which are in the gaseous state when conveyed in the gas pipeline infrastructure such as hydrogen, hydrogen rich, and methane rich gases, dimethyl ether (DME) and propane and butanes used for combustion and/or as feedstock, excluding steam and compressed air.

**2 Normative references**

There are no normative references in this document.

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**