

STN	Stabilné hasiace zariadenia Systémy na vodnú hmlu Časť 5: Protokol o skúške systémov s automatickými dýzami pre garáže na autá	STN EN 14972-5 92 0440
------------	---	--

Fixed firefighting systems - Water mist systems - Part 5: Test protocol for car garages for automatic nozzle systems

Táto norma obsahuje anglickú verziu európskej normy.

This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 01/25

Obsahuje: EN 14972-5:2024

139781

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2025

Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii v znení neskorších predpisov.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 14972-5

November 2024

ICS 13.220.20

English Version

**Fixed firefighting systems - Water mist systems - Part 5:
Test protocol for car garages for automatic nozzle systems**

Installations fixes de lutte contre l'incendie - Systèmes
à brouillard d'eau - Partie 5 : Protocole d'essai des
systèmes à buses automatiques pour parcs de
stationnement

Ortsfeste Brandbekämpfungsanlagen -
Wassernebelsysteme - Teil 5: Prüfprotokoll für Kfz-
Garagen für automatische Düsensysteme

This European Standard was approved by CEN on 2 September 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 14972-5:2024 (E)

Contents	Page
European foreword	3
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 General requirements.....	5
5 Car park garages fuel package	6
5.1 General.....	6
5.2 Vehicles.....	7
5.3 Conditioning of the fuel load.....	7
6 Reference sprinkler requirements.....	15
6.1 General.....	15
6.2 Reference sprinkler tests.....	15
7 Water mist system tests requirements.....	15
8 Test equipment requirements	16
9 Instrumentation requirements	16
9.1 General.....	16
9.2 Temperature.....	17
9.3 Pressure	17
9.4 Time	17
10 Testing criteria	17
10.1 General.....	17
10.2 Fire tests.....	17
10.3 Evaluation of test results.....	18
11 Test report.....	20

European foreword

This document (EN 14972-5:2024) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2025, and conflicting national standards shall be withdrawn at the latest by May 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

EN 14972, *Fixed firefighting systems — Water mist systems*, consists of the following parts:

- *Part 1: Design, installation, inspection and maintenance;*
- *Part 2: Test protocol for shopping areas for automatic nozzle systems;*
- *Part 3: Test protocol for office, school class rooms and hotel for automatic nozzle systems;*
- *Part 4: Test protocol for non-storage occupancies for automatic nozzle systems;*
- *Part 5: Test protocol for car garages for automatic nozzle systems;*
- *Part 6: Test protocol for false floors and false ceilings for automatic nozzle systems;*
- *Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems;*
- *Part 8: Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems;*
- *Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 10: Test protocol for atrium protection with sidewall nozzles for open nozzle systems;*
- *Part 11: Test protocol for cable tunnels for open nozzle systems;*
- *Part 12: Test protocol for commercial deep fat cooking fryers for open nozzle systems;*
- *Part 13: Test protocol for wet benches and other similar processing equipment for open nozzle systems;*
- *Part 14: Test protocol for combustion turbines in enclosures exceeding 260 m³ for open nozzle systems;*
- *Part 15: Test protocol for combustion turbines in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 16: Test protocol for industrial oil cookers for open nozzle systems*
- *Part 17: Test protocol for residential occupancies for automatic nozzle systems.*

NOTE This list includes standards that are in preparation and other standards might be added. For current status of published standards refer to www.cencenelec.eu.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

EN 14972-5:2024 (E)

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

1 Scope

This document specifies the evaluation of the fire performance of water mist systems for non-stacking garages, fully enclosed garages and underground garages.

This document is applicable for horizontal, solid, flat ceilings with heights of 2 m and above.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12259-1, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 1: Sprinklers*

EN 12845, *Fixed firefighting systems — Automatic sprinkler systems — Design, installation and maintenance*

EN 14972-1, *Fixed firefighting systems — Water mist systems — Part 1: Design, installation, inspection and maintenance*

EN ISO/IEC 17025:2017, *General requirements for the competence of testing and calibration laboratories*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN