

<b>STN</b>	<b>Stabilné hasiace zariadenia Plynové hasiace zariadenia Časť 1: Projektovanie, inštalovanie a údržba (mod ISO 14520-1: 2023)</b>	<b>STN EN 15004-1</b>  92 0430
------------	--	--

Fixed firefighting systems - Gas extinguishing systems - Part 1: Design, installation and maintenance (ISO 14520-1:2023, modified)

Táto norma obsahuje anglickú verziu európskej normy.  
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 03/25

Obsahuje: EN 15004-1:2024

Oznámením tejto normy sa ruší  
STN EN 15004-1 (92 0430) z marca 2021

**140186**

---

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2025  
Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii v znení neskorších predpisov.



EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 15004-1**

December 2024

ICS 13.220.20

Supersedes EN 15004-1:2019

English Version

**Fixed firefighting systems - Gas extinguishing systems -  
Part 1: Design, installation and maintenance (ISO 14520-  
1:2023, modified)**

Installations fixes de lutte contre l'incendie -  
Installations d'extinction à gaz - Partie 1 : Calcul,  
installation et maintenance (ISO 14520-1:2023,  
modifiée)

Ortsfeste Brandbekämpfungsanlagen - Löschanlagen  
mit gasförmigen Löschmitteln - Teil 1: Planung,  
Installation und Instandhaltung (ISO 14520-1:2023,  
modifiziert)

This European Standard was approved by CEN on 4 November 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

**EN 15004-1:2024 (E)**

<b>Contents</b>	<b>Page</b>
European foreword .....	9
Introduction .....	11
1 Scope.....	12
2 Normative references.....	13
3 Terms and definitions .....	13
4 Use and limitations.....	17
4.1 General.....	17
4.2 Extinguishants .....	18
4.2.1 General.....	18
4.2.2 Environmental properties.....	18
4.3 Electrostatic discharge.....	18
4.4 Compatibility with other extinguishants .....	18
4.5 Temperature limitations.....	19
5 Safety .....	19
5.1 Hazard to personnel .....	19
5.2 Safety precautions .....	20
5.2.1 General.....	20
5.2.2 For normally occupied areas .....	20
5.2.3 For normally unoccupied areas.....	22
5.2.4 For unoccupiable areas.....	22
5.3 Occupiable areas .....	22
5.4 Electrical hazards .....	23
5.5 Electrical earthing .....	24
5.6 Electrostatic discharge.....	24
6 System design.....	24
6.1 General.....	24
6.2 Extinguishant supply .....	24
6.2.1 Quantity.....	24
6.2.2 Quality.....	25
6.2.3 Container arrangement .....	25
6.2.4 Storage containers.....	25
6.3 Distribution.....	26
6.3.1 General.....	26
6.3.2 Piping .....	27
6.3.3 Fittings .....	28
6.3.4 Pipe and valve supports .....	28
6.3.5 Valves .....	29
6.3.6 Nozzles .....	29
6.3.7 Pressure reducing orifice assembly.....	30
6.4 Detection, actuation and control systems.....	30
6.4.1 General.....	30
6.4.2 Automatic detection.....	30
6.4.3 Operating devices .....	31
6.4.4 Control equipment .....	31

6.4.5	Operating alarms and indicators .....	32
6.4.6	Stop / hold off devices .....	32
7	Extinguishant system design .....	32
7.1	General .....	32
7.2	Specifications, plans and approvals .....	33
7.2.1	Specifications .....	33
7.2.2	Working documents .....	33
7.3	System flow calculations .....	33
7.3.1	General .....	33
7.3.2	Balanced and unbalanced system .....	33
7.3.3	Friction losses .....	35
7.3.4	Pressure drop .....	35
7.3.5	Elevation change .....	36
7.3.6	Valves and fittings .....	36
7.3.7	Piping length .....	36
7.3.8	Drawings .....	36
7.3.9	Liquefied gases — Specific requirements .....	36
7.4	Enclosures .....	36
7.5	Effects of noise .....	37
7.6	Extinguishant concentration requirements .....	37
7.6.1	Flame extinguishment .....	37
7.6.2	Inerting .....	39
7.7	Total flooding quantity .....	39
7.7.1	General .....	39
7.7.2	Liquefied gases .....	39
7.7.3	Non-liquefied gas .....	39
7.8	Altitude adjustment .....	40
7.9	Duration of protection .....	41
7.10	System performance .....	41
7.10.1	Discharge time .....	41
7.10.2	Extended discharge .....	41
8	Commissioning and acceptance .....	42
8.1	General .....	42
8.2	Tests .....	42
8.2.1	General .....	42
8.2.2	Enclosure check .....	42
8.2.3	Review of mechanical components .....	42
8.2.4	Review of enclosure integrity .....	43
8.2.5	Review of electrical components .....	43
8.2.6	Preliminary functional tests .....	45
8.2.7	System functional operational test .....	45
8.2.8	Remote monitoring operations (if applicable) .....	45
8.2.9	Control panel primary power source .....	46
8.2.10	Completion of functional tests .....	46
8.3	Completion certificate and documentation .....	46
9	Inspection, maintenance, testing and training .....	46
9.1	General .....	46
9.2	Inspection .....	46
9.2.1	General .....	46
9.2.2	Container .....	47
9.2.3	Hose .....	47
9.2.4	Enclosures .....	47

**EN 15004-1:2024 (E)**

<b>9.3</b>	<b>Maintenance .....</b>	<b>47</b>
<b>9.3.1</b>	<b>General.....</b>	<b>47</b>
<b>9.3.2</b>	<b>User's programme of inspection .....</b>	<b>47</b>
<b>9.3.3</b>	<b>Service schedule.....</b>	<b>48</b>
<b>9.4</b>	<b>Training.....</b>	<b>48</b>
<b>Annex A</b>	<b>(normative) Working documents.....</b>	<b>49</b>
<b>A.1</b>	<b>General.....</b>	<b>49</b>
<b>A.2</b>	<b>Working documents.....</b>	<b>49</b>
<b>A.3</b>	<b>Specific details .....</b>	<b>50</b>
<b>A.3.1</b>	<b>Pre-engineered systems.....</b>	<b>50</b>
<b>A.3.2</b>	<b>Engineered systems .....</b>	<b>50</b>
<b>Annex B</b>	<b>(normative) Determination of flame-extinguishing concentration of gaseous extinguishants by the cup burner method.....</b>	<b>51</b>
<b>B.1</b>	<b>General.....</b>	<b>51</b>
<b>B.2</b>	<b>Principle .....</b>	<b>51</b>
<b>B.3</b>	<b>Requirements for apparatus.....</b>	<b>51</b>
<b>B.3.1</b>	<b>General.....</b>	<b>51</b>
<b>B.3.2</b>	<b>Cup.....</b>	<b>52</b>
<b>B.3.3</b>	<b>Chimney.....</b>	<b>52</b>
<b>B.3.4</b>	<b>Diffuser .....</b>	<b>52</b>
<b>B.3.5</b>	<b>Fuel supply .....</b>	<b>53</b>
<b>B.3.6</b>	<b>Manifold .....</b>	<b>53</b>
<b>B.3.7</b>	<b>Air supply.....</b>	<b>53</b>
<b>B.3.8</b>	<b>Extinguishant supply .....</b>	<b>53</b>
<b>B.3.9</b>	<b>Delivery system .....</b>	<b>53</b>
<b>B.4</b>	<b>Requirements for materials.....</b>	<b>53</b>
<b>B.4.1</b>	<b>Air .....</b>	<b>53</b>
<b>B.4.2</b>	<b>Fuel.....</b>	<b>53</b>
<b>B.4.3</b>	<b>Extinguishant .....</b>	<b>53</b>
<b>B.5</b>	<b>Procedure for flammable liquids .....</b>	<b>53</b>
<b>B.6</b>	<b>Procedure for flammable gases .....</b>	<b>54</b>
<b>B.7</b>	<b>Extinguishant extinguishing concentration .....</b>	<b>55</b>
<b>B.7.1</b>	<b>Preferred method .....</b>	<b>55</b>
<b>B.7.2</b>	<b>Alternative method .....</b>	<b>55</b>
<b>B.8</b>	<b>Reporting of results .....</b>	<b>56</b>
<b>Annex C</b>	<b>(normative) Fire extinguishment/area coverage fire test procedure for engineered and pre-engineered extinguishing units .....</b>	<b>58</b>
<b>C.1</b>	<b>Requirements.....</b>	<b>58</b>

<b>C.2</b>	<b>Type of test and report of test results .....</b>	<b>58</b>
<b>C.2.1</b>	<b>Type of test.....</b>	<b>58</b>
<b>C.2.2</b>	<b>Reporting of test results.....</b>	<b>59</b>
<b>C.3</b>	<b>Extinguishing system .....</b>	<b>61</b>
<b>C.4</b>	<b>Extinguishing concentration .....</b>	<b>62</b>
<b>C.4.1</b>	<b>Extinguishing agent concentration .....</b>	<b>62</b>
<b>C.4.2</b>	<b>Cold discharge test .....</b>	<b>63</b>
<b>C.5</b>	<b>Nozzle distribution verification tests.....</b>	<b>64</b>
<b>C.5.1</b>	<b>Nozzle minimum height/maximum area coverage test.....</b>	<b>64</b>
<b>C.5.1.1</b>	<b>Test facility.....</b>	<b>64</b>
<b>C.5.1.2</b>	<b>Fuel specification.....</b>	<b>69</b>
<b>C.5.1.3</b>	<b>Test procedure .....</b>	<b>70</b>
<b>C.5.1.4</b>	<b>Determination of distribution performance of the nozzle .....</b>	<b>71</b>
<b>C.5.1.5</b>	<b>Reporting of test results.....</b>	<b>71</b>
<b>C.5.2</b>	<b>Nozzle maximum height test .....</b>	<b>71</b>
<b>C.5.2.1</b>	<b>Test facility.....</b>	<b>71</b>
<b>C.5.2.2</b>	<b>Fuel specification.....</b>	<b>72</b>
<b>C.5.2.3</b>	<b>Test procedure .....</b>	<b>72</b>
<b>C.5.2.4</b>	<b>Determination of distribution performance of the nozzle .....</b>	<b>72</b>
<b>C.5.2.5</b>	<b>Reporting of test results.....</b>	<b>72</b>
<b>C.6</b>	<b>Extinguishing concentration tests.....</b>	<b>73</b>
<b>C.6.1</b>	<b>Wood crib test.....</b>	<b>73</b>
<b>C.6.1.1</b>	<b>Test facility.....</b>	<b>73</b>
<b>C.6.1.2</b>	<b>Fuel specification.....</b>	<b>76</b>
<b>C.6.1.3</b>	<b>Test procedure .....</b>	<b>78</b>
<b>C.6.1.4</b>	<b>Determination of design extinguishant concentration.....</b>	<b>79</b>
<b>C.6.1.5</b>	<b>Reporting of test results.....</b>	<b>79</b>
<b>C.6.2</b>	<b>Heptane pan test.....</b>	<b>80</b>
<b>C.6.2.1</b>	<b>Test facility.....</b>	<b>80</b>
<b>C.6.2.2</b>	<b>Fuel specification.....</b>	<b>80</b>
<b>C.6.2.3</b>	<b>Test procedure .....</b>	<b>80</b>
<b>C.6.2.4</b>	<b>Determination of design extinguishant concentration.....</b>	<b>80</b>
<b>C.6.2.5</b>	<b>Reporting of test results.....</b>	<b>81</b>
<b>C.6.3</b>	<b>Polymeric sheet fire test .....</b>	<b>81</b>
<b>C.6.3.1</b>	<b>Test facility.....</b>	<b>81</b>
<b>C.6.3.2</b>	<b>Fuel specification.....</b>	<b>81</b>

**EN 15004-1:2024 (E)**

<b>C.6.3.3 Test procedure.....</b>	<b>85</b>
<b>C.6.3.4 Determination of design extinguishant concentration.....</b>	<b>87</b>
<b>C.6.3.5 Reporting of test results.....</b>	<b>87</b>
<b>Annex D (normative) Method of evaluating inerting concentration of a fire extinguishant..</b>	<b>88</b>
<b>D.1 General.....</b>	<b>88</b>
<b>D.2 Principle.....</b>	<b>88</b>
<b>D.3 Apparatus .....</b>	<b>88</b>
<b>D.4 Procedure .....</b>	<b>88</b>
<b>D.5 Inerting concentration.....</b>	<b>89</b>
<b>Annex E (normative) Door fan test for determining of minimum hold time .....</b>	<b>90</b>
<b>E.1 General.....</b>	<b>90</b>
<b>E.2 Test for determination of predicted hold time .....</b>	<b>90</b>
<b>E.2.1 Principle.....</b>	<b>90</b>
<b>E.2.2 Apparatus .....</b>	<b>91</b>
<b>E.2.3 Calibration and accuracy of apparatus .....</b>	<b>91</b>
<b>E.2.3.1 Fan unit.....</b>	<b>91</b>
<b>E.2.3.2 Pressure measuring devices .....</b>	<b>91</b>
<b>E.2.3.3 Temperature measuring devices .....</b>	<b>91</b>
<b>E.2.4 Preliminary preparation.....</b>	<b>91</b>
<b>E.2.5 Evaluation of enclosure .....</b>	<b>92</b>
<b>E.2.5.1 General.....</b>	<b>92</b>
<b>E.2.5.2 Mixing during hold time .....</b>	<b>92</b>
<b>E.2.6 Measurement of enclosure .....</b>	<b>92</b>
<b>E.2.6.1 Standard enclosures without continuous mixing .....</b>	<b>92</b>
<b>E.2.6.2 Non-standard enclosures without continuous mixing.....</b>	<b>93</b>
<b>E.2.6.3 Enclosures of any shape with continuous mixing .....</b>	<b>93</b>
<b>E.2.6.4 Opening for mounting the fan unit .....</b>	<b>93</b>
<b>E.2.7 Test procedure.....</b>	<b>93</b>
<b>E.2.7.1 Preparation.....</b>	<b>93</b>
<b>E.2.7.2 Setting up the door fan unit.....</b>	<b>94</b>
<b>E.2.7.3 Measurement of bias pressure during fan testing (<math>P_{bt}</math>).....</b>	<b>94</b>
<b>E.2.7.4 Measurement of leakage rate .....</b>	<b>95</b>
<b>E.2.7.5 Field calibration check.....</b>	<b>95</b>
<b>E.2.7.6 Measurement of bias pressure under hold time conditions (<math>P_{bh}</math>).....</b>	<b>96</b>
<b>E.2.8 Calculation.....</b>	<b>97</b>
<b>E.2.8.1 Selection of appropriate hold time equation.....</b>	<b>97</b>



E.2.8.2 Symbols .....	97
E.2.8.3 Depressurisation and pressurisation leakage characteristics .....	99
E.2.8.4 Column pressures.....	100
E.2.8.5 Average leakage characteristics.....	102
E.2.8.6 Correlation and simplifying constants.....	102
E.2.8.7 Predicted hold time: standard enclosures without continuous mixing .....	103
E.2.8.8 Predicted hold time: enclosures of any shape with continuous mixing .....	104
E.2.8.9 Predicted hold time for non-standard enclosures without continuous mixing.....	104
E.3 Treatment of enclosures with predicted hold times less than the recommended value .....	105
E.3.1 General .....	105
E.3.2 Leakage areas.....	105
E.3.3 Improved sealing of the enclosure .....	106
E.3.4 Quantification and location of leaks .....	106
E.3.4.1 General .....	106
E.3.4.2 Second calculation of hold time.....	106
E.3.4.3 Method of estimating $F$ .....	106
E.3.4.4 Final calculation of hold time.....	107
E.4 Report .....	107
Annex F (informative) System performance verification.....	109
Annex G (informative) Safe personnel exposure guidelines.....	110
G.1 General .....	110
G.2 Safety.....	110
G.3 Hazards to personnel — Potential hazards.....	110
G.3.1 Agent itself .....	110
G.3.2 Noise .....	110
G.3.3 Turbulence.....	110
G.3.4 Low temperature .....	110
G.4 Halocarbon agents.....	111
G.4.1 Toxicity of halocarbons (liquefied gases).....	111
G.4.2 PBPK model .....	112
G.4.3 Safe exposure guidelines for halocarbons.....	113
G.4.3.1 Any unnecessary exposure to halocarbon clean agents, even at NOAEL concentrations, and to halocarbon decomposition products shall be avoided. The requirements for pre-discharge alarms and time delays are intended to prevent human exposure to agents.....	113
G.4.4 Effects of impurities on safe use.....	115
G.5 Inert gas (non-liquefied gas) .....	116

**EN 15004-1:2024 (E)**

<b>G.5.1</b>	<b>Physiological effects of inert gas agents .....</b>	<b>116</b>
<b>G.5.2</b>	<b>Safe exposure guidelines for inert gas agents .....</b>	<b>116</b>
<b>Annex H</b>	<b>(informative) Flow calculation implementation method and flow calculation verification and testing for approvals .....</b>	<b>118</b>
<b>H.1</b>	<b>General.....</b>	<b>118</b>
<b>H.2</b>	<b>Calculation method implementation.....</b>	<b>118</b>
<b>H.3</b>	<b>Minimum accuracy recommendations.....</b>	<b>119</b>
<b>H.4</b>	<b>Recommended testing procedure for system flow calculation method (software) validation .....</b>	<b>119</b>
<b>H.4.1</b>	<b>General.....</b>	<b>119</b>
<b>H.4.1.1</b>	<b>Method 1 .....</b>	<b>119</b>
<b>H.4.1.2</b>	<b>Method 2 — Modular validation process for calculation software.....</b>	<b>120</b>
<b>H.4.2</b>	<b>System design for testing.....</b>	<b>120</b>
<b>H.5</b>	<b>Pass/fail criteria.....</b>	<b>121</b>
<b>Annex I</b>	<b>(informative) Scaling factors for Class B fuels other than heptane .....</b>	<b>122</b>
<b>I.1</b>	<b>Scope.....</b>	<b>122</b>
<b>I.2</b>	<b>Requirements in accordance with Annex C.....</b>	<b>122</b>
<b>I.3</b>	<b>Proposed scaling factor method.....</b>	<b>122</b>
<b>I.4</b>	<b>Procedure .....</b>	<b>122</b>
<b>Annex J</b>	<b>(normative) Criteria for assessment of new extinguishants for inclusion in the EN 15004 series .....</b>	<b>123</b>
<b>J.1</b>	<b>Scope.....</b>	<b>123</b>
<b>J.2</b>	<b>Checklist.....</b>	<b>123</b>
	<b>Bibliography .....</b>	<b>126</b>

## European foreword

This document (EN 15004-1:2024) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2025, and conflicting national standards shall be withdrawn at the latest by June 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15004-1:2019.

In comparison with the previous edition, the following technical modifications have been made:

- the Scope has been extended to cover an additional agent, halocarbon blend 55;
- the extinguishants from EN 15004-3 (HCFC Blend A, HCFC 123, HCFC 22 and HCFC 124) has been deleted from the Scope, Table 1 as EN 15004-3 was withdrawn;
- subclause 5.2.1 has been amended to require upper limit threshold concentrations to be established or any impurity that could result in acute toxicity at concentrations below the cardiac sensitization NOAEL of the agent. Subclause G.4.4 has also been added to provide further information on these requirements;
- a new subclause (6.4.4.2) has been added requiring that in the event of an electrical actuator being removed from a container valve or selector valve, an audible and visual alarm is to be provided at the control panel;
- a new subclause 7.3.5 on elevation change has been added;
- subclause 7.4.1 has been amended to draw attention to EN ISO 21805;
- a new subclause (7.5) has been added providing guidance regarding the effects of noise that can be caused by the alarm devices or the discharge of the agent;
- subclause 7.6.1.3, (previously 7.5.1.3) has been amended to give several scenarios to explain the recommended selection of regular and high hazard design concentrations;
- Annex I has been added to reflect the content of the withdrawn document ISO/TR 12854;
- Annex J has been added to reflect the content of ISO/TR 23107 (to be withdrawn).

The text of the International Standard ISO 14520-1:2023 from Technical Committee ISO/TC 21 “Equipment for fire protection and firefighting” of the International Organization for Standardization (ISO) has been taken over as a European Standard by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI, with common modifications which are indicated by a straight line in the margin of the text.

This European Standard will consist of the following parts, under the general title *Fixed firefighting systems – Gas extinguishing systems*:

**EN 15004-1:2024 (E)**

- *Part 1: Design, installation and maintenance;*
- *Part 2: Physical properties and system design of gas extinguishing systems for FK-5-1-12 extinguishant;*
- *Part 4: Physical properties and system design of gas extinguishing systems for HFC 125 extinguishant;*
- *Part 5: Physical properties and system design of gas extinguishing systems for HFC 227ea extinguishant;*
- *Part 6: Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant;*
- *Part 7: Physical properties and system design of gas extinguishing systems for IG-01 extinguishant;*
- *Part 8: Physical properties and system design of gas extinguishing systems for IG-100 extinguishant;*
- *Part 9: Physical properties and system design of gas extinguishing systems for IG-55 extinguishant;*
- *Part 10: Physical properties and system design of gas extinguishing systems for IG-541 extinguishant;*
- *Part 11: Physical properties and system design of gas extinguishing systems for Halocarbon Blend 55 extinguishant.*

The International Standards ISO 14520-2 and ISO 14520-11, which dealt with CF<sub>3</sub>I and HFC 236fa extinguishants, respectively, have not been implemented by CEN, as CF<sub>3</sub>I is only valid for local application and HFC 236fa extinguishant is only applicable for portable fire extinguishers and local application, respectively, which is not covered by the scope.

The international Standard ISO 14520-6 and therefor also EN 15004-3, which dealt with HCFC Blend A extinguishant were withdrawn.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

## Introduction

Extinguishing systems covered in this document are designed to provide a supply of gaseous extinguishing medium for the extinction of fire.

Several different methods of supplying extinguishant to, and applying it at, the required point of discharge for fire extinction have been developed in recent years, and there is a need for dissemination of information on established systems and methods. This document has been prepared to meet this need.

The requirements of this document are made in the light of the best technical data known to the working group at the time of writing but, since a wide field is covered, it has been impracticable to consider every possible factor or circumstance that might affect implementation of the recommendations.

It has been assumed in the preparation of this document that the execution of its provisions is entrusted to people appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid unnecessary release of extinguishant.

Attention is drawn to the Montreal Protocol on substances that deplete the ozone layer and those that contribute towards climate change.

It is important that the fire protection of a building or plant be considered as a whole. Gaseous extinguishant systems form only a part of the available facilities. It should not be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid, emergency use or to deal with special hazards.

Gaseous extinguishants have been a recognized effective medium for the extinction of flammable liquid fires and fires in the presence of electrical and ordinary Class A hazards for many years. However, in the planning of comprehensive schemes, it should be remembered, that these media are not suitable for all hazards. Additionally in certain circumstances or situations there can be dangers related to their use requiring special precautions.

Advice on these matters can be obtained from the appropriate manufacturer of the extinguishant or the extinguishing system. Information may also be sought from the appropriate fire authority, the health and safety authorities and insurers. Also, reference should be made as necessary to other national standards and statutory regulations of the particular country.

It is essential that extinguishing systems be carefully maintained to ensure instant readiness when required. Maintenance measures is liable to be overlooked or given insufficient attention by the owner of the system. It is, however, neglected at peril to the lives of occupants of the premises and the risk of crippling financial loss. The importance of maintenance cannot be too highly emphasized. Installation and maintenance should only be done by qualified personnel.

Inspection preferably by a third party, should include an evaluation that the extinguishing system continues to provide adequate protection for the risk (protected zones, as well as state of the art can change over time).

**EN 15004-1:2024 (E)****1 Scope**

This document specifies requirements and gives recommendations for the design, installation, testing, maintenance and safety of gas extinguishing systems in buildings, plants or other structures, and the characteristics of the various extinguishants and types of fire for which they are a suitable extinguishing medium.

This document describes total flooding systems primarily related to buildings, plants and other specific applications, utilizing electrically non-conducting gaseous fire extinguishants that do not leave a residue after discharge and for which there are sufficient data currently available to enable validation of performance and safety characteristics by an appropriate independent authority. This document is not applicable to explosion suppression.

This document is not intended to indicate approval of the extinguishants listed therein by the appropriate authorities, as other extinguishants may be equally acceptable. CO<sub>2</sub> is not included as it is covered by its own European standard.

This document is applicable to the extinguishants listed in Table 1. This document is intended to be used in conjunction with the given parts of EN 15004 for fire extinguishing agents in Table 1.

**Table 1 — Listed extinguishant**

Extinguishant	Chemical	Formula	CAS No.	European Standard
FK-5-1-12	Dodecafluoro-2-methylpentan-3-one	CF <sub>3</sub> CF <sub>2</sub> C(O)CF(CF <sub>3</sub> ) <sub>2</sub>	756-13-8	EN 15004-2
HFC 125	Pentafluoroethane	CHF <sub>2</sub> CF <sub>3</sub>	354-33-6	EN 15004-4
HFC 227ea	Heptafluoropropane	CF <sub>3</sub> CHFCF <sub>3</sub>	2252-84-8	EN 15004-5
HFC 23	Trifluoromethane	CHF <sub>3</sub>	75-46-7	EN 15004-6
IG-01	Argon	Ar	74040-37-1	EN 15004-7
IG-100	Nitrogen	N <sub>2</sub>	7727-37-9	EN 15004-8
IG-55	Nitrogen (50 %)	N <sub>2</sub>	7727-37-9	EN 15004-9
	Argon (50 %)	Ar	74040-37-1	
IG-541	Nitrogen (52 %)	N <sub>2</sub>	7727-37-9	EN 15004-10
	Argon (40 %)	Ar	74040-37-1	
	Carbon dioxide (8 %)	CO <sub>2</sub>	124-38-9	
Halocarbon Blend 55	E-1-chloro-3,3,3-trifluoropropene (50 % by mass)	CF <sub>3</sub> CHCHCl	102687-65-0	EN 15004-11
	Dodecafluoro-2-methylpentan-3-one (50% by mass)	CF <sub>3</sub> CF <sub>2</sub> C(O)CF(CF <sub>3</sub> ) <sub>2</sub>	756-13-8	

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54 (all parts), *Fire detection and fire alarm systems*

EN 12094 (all parts), *Fixed firefighting systems — Components for gas extinguishing systems*

EN 15004-2, *Fixed firefighting systems — Gas extinguishing systems — Part 2: Physical properties and system design of gas extinguishing systems for FK-5-1-12 extinguishant (ISO 14520-5, modified)*

EN 15004-4, *Fixed firefighting systems — Gas extinguishing systems — Part 4: Physical properties and system design of gas extinguishing systems for HFC 125 extinguishant (ISO 14520-8, modified)*

EN 15004-5, *Fixed firefighting systems — Gas extinguishing systems — Part 5: Physical properties and system design of gas extinguishing systems for HFC 227ea extinguishant (ISO 14520-9, modified)*

EN 15004-6, *Fixed firefighting systems — Gas extinguishing systems — Part 6: Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant (ISO 14520-10, modified)*

EN 15004-7, *Fixed firefighting systems — Gas extinguishing systems — Part 7: Physical properties and system design of gas extinguishing systems for IG-01 extinguishant (ISO 14520-12, modified)*

EN 15004-8, *Fixed firefighting systems — Gas extinguishing systems — Part 8: Physical properties and system design of gas extinguishing systems for IG-100 extinguishant (ISO 14520-13, modified)*

EN 15004-9, *Fixed firefighting systems — Gas extinguishing systems — Part 9: Physical properties and system design of gas extinguishing systems for IG-55 extinguishant (ISO 14520-14, modified)*

EN 15004-10, *Fixed firefighting systems — Gas extinguishing systems — Part 10: Physical properties and system design of gas extinguishing systems for IG-541 extinguishant (ISO 14520-15, modified)*

EN 15004-11, *Fixed firefighting systems — Gas extinguishing systems — Part 11: Physical properties and system design of gas extinguishing systems for Halocarbon Blend 55 extinguishant (ISO 14520-17, modified)*

**koniec náhľadu – text ďalej pokračuje v platenej verzii STN**