

STN	Komunikačné systémy pre meradlá Časť 3: Aplikačné protokoly	STN EN 13757-3 36 5711
------------	--	--

Communication systems for meters - Part 3: Application protocols

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 06/25

Obsahuje: EN 13757-3:2025

Oznámením tejto normy sa ruší
STN EN 13757-3 (36 5711) z novembra 2018

140594

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2025
Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii
v znení neskorších predpisov.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 13757-3

April 2025

ICS 33.200; 35.100.70; 35.240.99; 91.140.50

Supersedes EN 13757-3:2018

English Version

**Communication systems for meters - Part 3: Application
protocols**

Systèmes de communication pour compteurs - Partie 3
: Protocoles d'application

Kommunikationssysteme für Zähler - Teil 3:
Anwendungsprotokolle

This European Standard was approved by CEN on 24 February 2025.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 13757-3:2025 (E)**Contents**

Page

European foreword.....	5
Introduction	7
1 Scope	9
2 Normative references	9
3 Terms and definitions	9
4 Abbreviations and symbols	10
4.1 Abbreviations	10
4.2 Symbols.....	11
5 Selection of an application protocol.....	11
6 M-Bus protocol.....	12
6.1 General.....	12
6.2 M-Bus data record.....	12
6.3 Data Information Block (DIB).....	12
6.3.1 General.....	12
6.3.2 Data Information Field (DIF)	13
6.3.3 Data field	13
6.3.4 Function Field.....	14
6.3.5 Storage number	15
6.3.6 Extension bit (E)	15
6.3.7 Data Information Field Extension (DIFE)	15
6.3.8 Tariff information	15
6.3.9 Subunit information.....	16
6.4 Value Information Block (VIB)	16
6.4.1 General.....	16
6.4.2 Primary VIFs (main table)	17
6.4.3 VIF-codes for special purposes.....	18
6.4.4 VIFE-code extension tables.....	19
6.4.5 Alternate VIFE-code extension table (following VIF = FB _h for primary VIF).....	25
6.4.6 Combinable (orthogonal) VIFE-Code extension table	26
6.4.7 Generalized object layer	30
6.4.8 Record errors	31
6.5 Sensor specific information.....	32
6.5.1 General.....	32
6.5.2 Sub device type for Sensors.....	32
6.5.3 Status bits of specific sensors	34
6.5.4 Type or class of approval.....	38
6.6 Manufacturer specific unstructured data block	38
7 Application reset and application select	39
7.1 Application reset	39
7.2 Application select with subcode	39
7.3 Overview about CI-fields for application reset and application select.....	42
7.4 Rules for application selection.....	42
7.4.1 Reset of current slave response.....	42
7.4.2 Erroneous application select	43
7.5 Rules for block selection.....	43

7.6	Selected application block in M-Bus application protocol	43
8	Clock synchronization.....	43
9	Report of alarm status (slave to master)	44
10	Report of application error	44
10.1	General	44
10.2	Status field.....	44
10.3	General application layer errors.....	44
11	Switching baud rate for M-Bus link layer according to EN 13757-2	46
12	Synchronize action	46
13	Manufacturer specific protocols	46
14	Other application protocols.....	46
15	Image Transfer	47
Annex A (normative) Coding of data records		48
Annex B (normative) Interpretation of hex-codes A_h – F_h in BCD-data fields		56
B.1	General description standard reference.....	56
B.2	Definition.....	56
Annex C (normative) VIF coding for special units.....		57
C.1	Non-metric units	57
C.2	Plain text units.....	57
C.3	Remote enablement/disablement of valve/breaker.....	58
Annex D (informative) Alarm protocol		59
D.1	M-Bus according to EN 13757-2	59
D.2	Wireless M-Bus according to EN 13757-4.....	59
Annex E (informative) Special sequences for M-Bus devices.....		60
E.1	VIF/VIFE/VIFE = FD_h 97_h $1D_h$ (error flag).....	60
E.2	VIF/VIFE/VIFE = FD_h $9F_h$ $1D_h$ for passing remote control on a node	62
E.3	Clock synchronization.....	63
Annex F (normative) Transmission of profiles.....		66
F.1	The standard load profile	66
F.2	The M-Bus compact profile	67
Annex G (normative) Compact M-Bus frame		72
G.1	General	72
G.2	CI-fields of the Full and the Compact M-Bus frame.....	72
G.3	Calculation of the Full-Frame-CRC.....	74
G.4	Calculation of the Format Signature	74
G.5	Frame examples	75

EN 13757-3:2025 (E)

Annex H (normative) Translating M-Bus type record descriptors to OBIS-type record descriptors.....	77
H.1 General.....	77
H.2 Translation of predefined data record types.....	77
H.3 Online addition of an entry for the M-Bus to OBIS conversion table.....	95
Annex I (normative) Image Transfer	96
I.1 Image Transfer phases.....	96
I.2 Commands for Image Transfer.....	99
I.3 Overview Image Transfer.....	116
Annex J (informative) Example for electrical phase angles.....	118
J.1 Phase angle between UL1 and UL2, UL3	118
J.2 Phase angle between UL1 and IL1.....	118
Bibliography.....	120

European foreword

This document (EN 13757-3:2025) has been prepared by Technical Committee CEN/TC 294 “Communication systems for meters”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2025, and conflicting national standards shall be withdrawn at the latest by October 2025.

This document supersedes EN 13757-3:2018.

EN 13757-3:2025 includes the following significant technical changes with respect to EN 13757-3:2018:

- support of sensor devices and alarm devices in new subclause 6.5 and Table 13;
- change of device type codes for thermal energy meters (heat and cooling);
- addition of a new Table 14 - Bit field definition of “Installation conditions”;
- marking of unused VIF/VIFE in Table 10 and Table 12 as deprecated;
- extension of the coding of message application in Table 26;
- addition of alternative non-metric units in Annex C;
- revision of the clock synchronisation protocol in Clause E.3.

EN 13757 is currently composed with the following parts:

- *Communication systems for meters — Part 1: Data exchange;*
- *Communication systems for meters — Part 2: Wired M-Bus communication;*
- *Communication systems for meters — Part 3: Application protocols;*
- *Communication systems for meters — Part 4: Wireless M-Bus communication;*
- *Communication systems for meters — Part 5: Wireless M-Bus relaying;*
- *Communication systems for meters — Part 7: Transport and security services;*
- *Communication systems for meters — Part 8: Adaptation Layer;*
- *CEN/TR 17167, Communication systems for meters — Accompanying TR to EN 13757-2, -3 and -7, Examples and supplementary information.*

This document has been prepared under a standardization request addressed to CEN by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

This document falls under Mandate EU M/441 “Standardisation mandate to CEN, CENELEC and ETSI in the field of measuring instruments for the development of an open architecture for utility meters involving communication protocols enabling interoperability” by providing the relevant definitions and

EN 13757-3:2025 (E)

methods for meter data transmission on application layer level. The M/441 Mandate is driving significant development of standards in smart metering.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Introduction

This document belongs to the EN 13757 series, which covers communication systems for meters. EN 13757-1 contains generic descriptions and a communication protocol. EN 13757-2 contains a physical and a link layer for twisted pair based Meter-Bus (M-Bus). EN 13757-4 specifies wireless communication (often called wireless M-Bus or wM-Bus). EN 13757-5 specifies the wireless network used for repeating, relaying and routing for the different modes of EN 13757-4. EN 13757-7 specifies transport mechanism and security methods for data. The Technical Report CEN/TR 17167 contains informative annexes for EN 13757-2, EN 13757-3 and EN 13757-7.

These upper M-Bus protocol layers can be used with various Physical Layers and with Data Link Layers and Network Layers, which support the transmission of variable length binary transparent messages. Frequently, the Physical and Link Layers of EN 13757-2 (twisted pair) and EN 13757-4 (wireless) as well as EN 13757-5 (wireless with routing function) or the alternatives specified in EN 13757-1 are used. These upper M-Bus protocol layers have been optimized for minimum battery consumption of meters, especially for the case of wireless communication, to ensure long battery lifetimes of the meters. Secondly, it is optimized for minimum message length to minimize the wireless channel occupancy and hence the collision rate. Thirdly, it is optimized for minimum requirements towards the meter processor regarding requirements of RAM size, code length and computational power.

An overview of communication systems for meters is given in EN 13757-1, which also contains further definitions.

This document concentrates on the meter communication. The meter communicates with one (or occasionally several) fixed or mobile communication partners which again might be part of a private or public network. These further communication systems might use the same or other application layer protocols, security, privacy, authentication, and management methods.

To facilitate common communication systems for CEN meters (e.g. gas, water, thermal energy and heat cost allocators) and for electricity meters, in this document occasionally electricity meters are mentioned. All these references are for information only and are not standard requirements. The specification of communication standards for electricity meters (possibly by a reference to CEN standards) remains solely in the responsibility of CENELEC.

NOTE 1 CEN/TR 17167:2023, Annex C specifies how parts of this document and of EN 13757-2 and EN 13757-4 can be used to implement smart meter functionalities. Similar functionalities could also be implemented using other physical and link layers.

NOTE 2 For information on installation procedures and their integration in meter management systems, see CEN/TR 17167:2023, Annex D.

The European Committee for Standardization (CEN) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning Image Transfer given in Annex I and which is claimed to be relevant for the following clause(s) of this document: Clause 15.

CEN takes no position concerning the evidence, validity and scope of this patent right. The holder of this patent right has ensured CEN that they are willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with CEN. Information may be obtained from:

EN 13757-3:2025 (E)

ITRON, INC

Shig Furukawa, Associate General Counsel IP, Legal Department

2111 N. Molter Road

Liberty Lake, Washington 99019

USA

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. CEN shall not be held responsible for identifying any or all such patent rights.

1 Scope

This document specifies application services for communication systems for meters, sensors, and actuators, used to provide metering services.

This document specifies application protocols, especially the M-Bus application protocol.

This document is intended to be used with the lower layer specifications determined in the relevant parts of the EN 13757 series.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13757-2, *Communication systems for meters — Part 2: Wired M-Bus communication*

EN 13757-7:2025, *Communication systems for meters — Part 7: Transport and security services*

ISO/IEC 8859-1, *Information technology — 8-bit single-byte coded graphic character sets — Part 1: Latin alphabet No. 1*

ISO/IEC 60559:2020, *Information technology — Microprocessor Systems — Floating-Point arithmetic*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN