

STN	Stabilné hasiace zariadenia Systémy na vodnú hmlu Časť 1: Projektovanie, inštalovanie, kontrola a údržba	STN EN 14972-1+A1 92 0440
------------	---	---

Fixed firefighting systems - Water mist systems - Part 1: Design, installation, inspection and maintenance

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 07/25

Obsahuje: EN 14972-1:2020+A1:2025

Oznámením tejto normy sa ruší
STN EN 14972-1 (92 0440) z júla 2022

140870

Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2025
Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii
v znení neskorších predpisov.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 14972-1:2020+A1

May 2025

ICS 13.220.20

Supersedes EN 14972-1:2020

English Version

**Fixed firefighting systems - Water mist systems - Part 1:
Design, installation, inspection and maintenance**

Installations fixes de lutte contre l'incendie - Systèmes
à brouillard d'eau - Partie 1 : Conception, installation,
inspection et maintenance

Ortsfeste Brandbekämpfungsanlagen -
Wassernebelsysteme - Teil 1: Planung, Einbau,
Inspektion und Wartung

This European Standard was approved by CEN on 11 October 2020 and includes Amendment 1 approved by CEN on 7 April 2025.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 14972-1:2020+A1:2025 (E)**Contents**

Page

European foreword.....	9
Introduction	11
1 Scope	12
2 Normative references.....	12
3 Terms, definitions and abbreviations	13
3.1 Terms and definitions	13
3.2 Abbreviations	20
4 Design	20
4.1 Design principal.....	20
4.1.1 General.....	20
4.1.2 General requirement	20
4.1.3 Full scale fire testing procedures	20
4.2 Design, installation, operation and maintenance manual	21
4.2.1 General	21
4.2.2 Content of the DIOM manual	21
4.3 Water mist systems using gas for their operation	23
4.4 Use of additives.....	23
4.5 Design parameters.....	23
4.6 Water and gas supply.....	23
4.6.1 Pumped systems requirements	23
4.6.2 Self-contained systems requirements	23
4.7 Compartment protection.....	23
4.7.1 General.....	23
4.7.2 Compartment.....	23
4.7.3 Fire hazard.....	24
4.7.4 Design requirements	24
4.8 Requirements for different types of water mist deluge systems.....	24
4.8.1 Local application systems	24
4.8.2 Local application systems with multiple hazards	24
4.8.3 Volume protection water mist systems	24
4.8.4 Zoned protection systems.....	24
4.8.5 Activation and control.....	24
4.9 Design of water mist automatic nozzle systems	25
4.9.1 Extent of protection.....	25
4.9.2 Permitted exceptions within a building.....	25
4.9.3 Material reaction.....	25
4.9.4 System design	25
4.9.5 Nozzle selection and positioning.....	30
4.9.6 Alarm device	30
4.9.7 Test connection.....	30
4.9.8 Air velocity and openings.....	30
4.10 Design of water mist deluge system	31
4.10.1 Nozzle selection and positioning.....	31
4.10.2 Air velocity and openings.....	31
4.10.3 Automatic shut-down	31
4.11 Fire detection and fire alarm systems activating the water mist system	31

4.11.1	General requirements.....	31
4.11.2	Fire detection and fire alarm systems continuity.....	31
4.11.3	Avoiding false alarms by water mist discharge.....	32
4.11.4	Manual activation	32
4.11.5	Electrical detection and activation.....	32
4.11.6	Non-electrical detection.....	33
4.12	Hydraulic and pneumatic calculations	33
4.13	Water, propellant and atomizing gas supply design.....	33
4.13.1	General	33
4.13.2	Connection to public or town mains	33
4.13.3	Flow requirement.....	34
4.13.4	Maximum and minimum water pressure	34
4.13.5	Discharge operating time	34
4.13.6	Type of water supply	36
4.13.7	Availability	36
4.13.8	Housing of equipment for water supplies	40
5	Installation.....	40
5.1	General	40
5.1.1	DIOM manual.....	40
5.1.2	Electrical safety	40
5.1.3	High Voltage live electrical equipment.....	41
5.1.4	Electrical clearances.....	41
5.2	Nozzle.....	41
5.2.1	General	41
5.2.2	Automatic nozzle	42
5.2.3	Open nozzle.....	42
5.3	Pipe	43
5.3.1	General	43
5.3.2	Protection against mechanical damages.....	43
5.3.3	Protection against corrosion	43
5.3.4	Protection in seismic areas	43
5.3.5	Protection against freezing for wet pipes.....	43
5.3.6	Accessibility of the pipe work	43
5.3.7	Pipe bending.....	43
5.3.8	Water supply pipes	44
5.3.9	Pipe support	44
5.3.10	Drainage.....	45
5.4	Gas and water containers (where provided).....	45
5.4.1	General	45
5.4.2	Location.....	45
5.4.3	Accessibility.....	45
5.4.4	Fixing.....	45
5.4.5	Manifolds	45
5.4.6	Temperature	45
5.5	Strainers and filters	46
5.5.1	Strainers.....	46
5.5.2	Nozzle filter.....	46
5.5.3	System filters.....	46
5.6	Valves.....	46
5.6.1	General	46
5.6.2	Identifications.....	46
5.6.3	Accessibility.....	46

EN 14972-1:2020+A1:2025 (E)

5.6.4	Securing and monitoring valves	46
5.6.5	Shut-off valves	46
5.6.6	Control valves.....	46
5.6.7	Check and non-return valves	47
5.7	Pressure gauges.....	47
5.8	Test connection.....	47
5.8.1	Test connection for automatic water mist systems.....	47
5.8.2	Test connection for water mist deluge system.....	47
5.9	Electrical installation.....	47
5.9.1	Electrical power supply	47
5.9.2	Fire detection and fire alarm system	47
5.10	System monitoring and alarms	47
5.10.1	General.....	47
5.10.2	Alarms	47
5.10.3	Remote signalling.....	48
5.11	Water mist system supply, including additives	48
5.11.1	General.....	48
5.11.2	Water quality	48
5.11.3	Additives.....	49
5.11.4	Water supply.....	49
5.11.5	Test devices.....	51
6	Water mist system components.....	52
6.1	General.....	52
6.1.1	Requirements for components.....	52
6.1.2	Pressure rating	52
6.2	Nozzle	52
6.3	Piping and fittings.....	52
6.3.1	Pipework.....	52
6.3.2	Fittings	53
6.4	Flexible hoses	53
6.4.1	Hose length.....	53
6.4.2	Hoses to be used in areas exposed to fire class B fires	54
6.4.3	Hose rating	54
6.5	Pipe supports.....	54
6.6	Valves.....	54
6.6.1	Shut-off valves	54
6.6.2	Pressure regulating valves	54
6.6.3	Check and non-return valves	54
6.6.4	Drain/fill valves.....	54
6.6.5	Safety valves.....	55
6.7	Control valves.....	55
6.7.1	General.....	55
6.7.2	Strainers and filters.....	55
6.8	Flow switches and flow transmitters.....	55
6.9	Pressure switches and pressure transmitters.....	55
6.10	Supply components for self-contained systems.....	55
6.10.1	General.....	55
6.10.2	Excess pressure.....	56
6.10.3	Pressure container marking	56
6.10.4	Design temperature	56
6.10.5	Gas cylinders and actuation valve.....	56
6.10.6	Cylinders and storage containers for water	56

7	Main pumps for water mist systems.....	56
7.1	General	56
7.2	Pump set	56
7.2.1	Operation.....	56
7.2.2	Overpressure.....	56
7.2.3	Centrifugal pumps.....	57
7.2.4	Positive displacement pumps	57
7.2.5	Pump driver.....	57
7.2.6	Pump Cooling	57
7.2.7	Pump set anchoring	57
7.2.8	Positive displacement pump filters	57
7.2.9	Pump set coupling	57
7.2.10	Valves and accessories.....	57
7.2.11	Suction pipe	58
7.2.12	Discharge pipe	58
7.2.13	Pump set rating	58
7.2.14	Pump set operation.....	59
7.2.15	Electrically driven pump sets.....	60
7.2.16	Diesel engine driven pump sets	62
8	Testing, acceptance and commissioning.....	66
8.1	Acceptance test for water mist systems	66
8.2	Test criteria	66
8.3	Site commissioning test.....	67
8.4	Completion certificate and documents.....	67
9	Inspection and maintenance	67
9.1	Inspection.....	67
9.1.1	Inspection schedule	67
9.1.2	User's program of inspection	67
9.2	Inspection and maintenance routines	68
9.2.1	Weekly routine	68
9.2.2	Monthly routine	68
9.2.3	Quarterly routine.....	69
9.2.4	Half-yearly routine.....	69
9.2.5	Annual inspection.....	70
9.2.6	Three-yearly routine	71
9.2.7	Five-yearly routine.....	71
9.2.8	Ten-yearly routine	71
9.2.9	Maintenance schedule	72
9.2.10	User's program of monitoring.....	72
9.2.11	Training.....	72
10	Documentation	72
10.1	Installation documentation	72
10.2	Documentation for acceptance of design, installation and commissioning.....	72
Annex A (informative)	Guideline for developing representative fire test protocols for water mist systems	74
A.1	General	74
A.2	Evaluation of the fire hazard	74
A.3	Evaluation of the compartment conditions.....	75
A.4	Determining the performance objective.....	76
A.5	Setting up the fire test procedure	76
A.6	Carrying out the test.....	78

EN 14972-1:2020+A1:2025 (E)

A.7	Documentation and interpretation of test results	78
A.8	Example for fire test report.....	78
Annex B (informative)	Area of operation for typical automatic nozzle water mist systems.....	80
B.1	General.....	80
B.2	Typical system component layouts	80
B.2.1	System components gridded layout	80
B.2.2	System components terminal layout	81
B.2.3	System components looped layout	81
B.3	AOs to be determined by full hydraulic calculation	82
B.4	Most unfavourable and most favourable AO demands and the pump supply curve	84
B.5	Calculating the number of nozzles and actual area of AO.....	85
B.6	Method of calculating the area per nozzle	88
B.6.1	Regular spacing.....	88
B.6.2	Irregular spacing.....	88
B.7	Shape of the AO	91
B.7.1	General.....	91
B.7.2	Shape of the hydraulically most unfavourable location	91
B.7.3	Shape of the hydraulically most favourable location.....	94
B.8	Length of the AO.....	96
B.9	Relocation of section valves	97
B.10	Calculating the nozzles operating in the most unfavourable AO	97
Annex C (normative)	Limits of applicability for water mist systems tested in accordance with EN 14972-2	99
C.1	General.....	99
C.2	Regarding the scope of the water mist system.....	99
C.2.1	General.....	99
C.2.2	Storage areas	99
C.3	Storage requirements.....	100
Annex D (normative)	Limits of applicability for water mist systems tested in accordance with EN 14972-3	102
D.1	General.....	102
D.2	Regarding the scope of the water mist system.....	102
D.3	Additional design and installation parameters	103
Annex E (normative)	Limits of applicability for water mist systems tested in accordance with EN 14972-4	104
E.1	General.....	104
E.2	Regarding the scope of the water mist system.....	104
E.3	Additional information on testing methodology.....	105

Annex F (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-5.....	106
F.1 General	106
F.2 Regarding the scope of the water mist system.....	106
Annex G (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-6.....	107
G.1 General	107
G.2 Regarding the scope of the water mist system.....	107
Annex H (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-7	108
H.1 General	108
H.2 Regarding the scope of the water mist system.....	108
Annex I (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-8.....	109
I.1 General	109
I.2 Regarding the scope of the water mist system.....	109
Annex J (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-9.....	111
J.1 General	111
J.2 Regarding the scope of the water mist system.....	111
J.3 Additional design and installation parameters.....	112
Annex K (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-10	113
K.1 General	113
K.2 Regarding the scope of the water mist system.....	113
K.3 Additional design and installation parameters.....	113
Annex L (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-11	114
L.1 General	114
L.2 Regarding the scope of the water mist system.....	114
L.3 Additional design and installation parameters.....	114
Annex M (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-12	115
M.1 Regarding the scope of the water mist system.....	115
M.2 Additional design and installation parameters.....	115
Annex N (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-13	116
N.1 Additional design and installation parameters.....	116

EN 14972-1:2020+A1:2025 (E)

Annex O (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-14.....	117
0.1 General.....	117
0.2 Regarding the scope of the water mist system.....	117
0.3 Additional design and installation parameters	117
Annex P (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-15.....	118
P.1 General.....	118
P.2 Regarding the scope of the water mist system.....	118
P.3 Additional design and installation parameters	118
Annex Q (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-16.....	119
Q.1 Regarding the scope of the water mist system.....	119
Q.2 Additional design and installation parameters	119
Annex R (normative) Limits of applicability for water mist systems tested in accordance with EN 14972-17	120
R.1 General.....	120
R.2 Regarding the scope of the water mist system.....	120
R.3 Additional design and installation parameters	120
R.3.1 Consultation	120
R.3.2 System Enhancements.....	120
Annex S (normative) Measurement tolerances.....	121
Bibliography	122

European foreword

This document (EN 14972-1:2020+A1:2025) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2025, and conflicting national standards shall be withdrawn at the latest by November 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1, approved by CEN on 7 April 2025.

This document supersedes A1 EN 14972-1:2020 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

The former CEN/TS 14972:2011 was reviewed and replaced with this new European Standard.

EN 14972, *Fixed firefighting systems — Water mist systems*, consists of the following parts:

- *Part 1: Design, installation, inspection and maintenance;*
- *Part 2: Test protocol for shopping areas for automatic nozzle systems;*
- *Part 3: Test protocol for office, school class rooms and hotel for automatic nozzle systems;*
- *Part 4: Test protocol for non-storage occupancies for automatic nozzle systems;*
- *Part 5: Test protocol for car garages for automatic nozzle systems;*
- *Part 6: Test protocol for false floors and false ceilings for automatic nozzle systems;*
- *Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems;*
- *Part 8: Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems;*
- *Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 10: Test protocol for atrium protection with sidewall nozzles for open nozzle systems;*
- *Part 11: Test protocol for cable tunnels for open nozzle systems;*
- *Part 12: Test protocol for commercial deep fat cooking fryers for open nozzle systems;*
- *Part 13: Test protocol for wet benches and other similar processing equipment for open nozzle systems;*
- *Part 14: Test protocol for combustion turbines in enclosures exceeding 260 m³ for open nozzle systems;*

EN 14972-1:2020+A1:2025 (E)

- *Part 15: Test protocol for combustion turbines in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 16: Test protocol for industrial oil cookers for open nozzle systems;*
- *Part 17: Test protocol for residential occupancies for automatic nozzle systems.*

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards, refer to www.cen.eu.

This document converts CEN/TS 14972:2011 into a full EN standard. It is a full revision of the Technical Specification, and incorporates the following principal changes:

- guidance on areas of operation;
- guidance on effective capacity of tanks;
- extension of scope of application to cover more areas in buildings when supported by test standards produced by other organizations.

Any user claiming compliance with this document is expected to be able to justify any course of action that deviates from its recommendations.

This document is intended for use by manufacturers, designers and installers of water mist systems, and for authorities having jurisdiction.

It has been assumed in the preparation of this document that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Introduction

Water mist systems

Fixed water mist systems for the fire protection of industrial, commercial and residential hazards comprise specially designed nozzles mounted in pipework, and connected via control valves to a dedicated water supply.

Specific areas within buildings can be protected by water mist where relevant fire test protocols exist.

Water mist systems deliver a mist of small droplets which control, suppress or extinguish fire by:

- absorbing heat from the fire and its surroundings;
- smothering the flames by localized oxygen depletion through evaporation to steam;
- blocking some of the radiant heat transfer to adjacent combustible materials;
- wetting and cooling of the fuel surface.

Fires such as those involving flammable liquids (class B fires) can be extinguished using water mist. Fires such as those involving ordinary combustible materials (class A fires) can be controlled and suppressed using water mist and may also be extinguished. Water mist can also prevent flash-over.

With the high surface area of the droplets produced, water mist is able to absorb relatively large amounts of heat and thus provide efficient cooling.

Currently, the majority of applications for water mist relate to property and asset protection. However, under certain circumstances, water mist can improve conditions within the protected space and thus increase the chances of survival for personnel inside the protected areas. It can also enhance personnel protection in more general applications by protecting facilities thereby enhancing the safety of individuals.

Water mist is a specific application solution which needs to be proven for each individual application and/or occupancy.

EN 14972-1:2020+A1:2025 (E)

1 Scope

This document specifies requirements and gives recommendations for the design, installation, inspection and maintenance of all types of fixed land based water mist systems.

This document is intended to apply to water mist automatic nozzle systems and water mist deluge systems supplied by stand alone or pumped systems.

The document covers only applications and occupancies which are covered by the fire test protocols of the EN 14972 series.

Aspects of water mist associated with explosion protection and/or use within vehicles are not covered by this document.

This document does not cover all legislative requirements. In certain countries specific national regulations apply and take precedence over this document. Users of this document are advised to inform themselves of the applicability or non-applicability for this document by their national responsible authorities.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 3-7:2004+A1:2007, *Portable fire extinguishers — Part 7: Characteristics, performance requirements and test methods*

EN 54 (all parts), *Fire detection and fire alarm systems*

CEN/TS 54-14, *Fire detection and fire alarm systems — Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance*

EN 12094-1, *Fixed firefighting systems — Components for gas extinguishing systems — Part 1: Requirements and test methods for electrical automatic control and delay devices*

EN 12094-2, *Fixed firefighting systems — Components for gas extinguishing systems — Part 2: Requirements and test methods for non-electrical automatic control and delay devices*

EN 12094-4, *Fixed firefighting systems — Components for gas extinguishing systems — Part 4: Requirements and test methods for container valve assemblies and their actuators*

EN 12094-8, *Fixed firefighting systems — Components for gas extinguishing systems — Part 8: Requirements and test methods for connectors*

EN 12094-10, *Fixed firefighting systems — Components for gas extinguishing systems — Part 10: Requirements and test methods for pressure gauges and pressure switches*

EN 12259-1, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 1: Sprinklers*

EN 12259-2, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 2: Wet alarm valve assemblies*

EN 12259-3, *Fixed firefighting systems — Components for automatic sprinkler and water spray systems — Part 3: Dry alarm valve assemblies*

EN 12259-12, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 12: Pumps*

EN 12845:2015+A1:2019, *Fixed firefighting systems — Automatic sprinkler systems — Design, installation and maintenance*

EN 14972 (all parts), *Fixed firefighting systems — Water mist systems*

EN 15004-1:2019, *Fixed firefighting systems — Gas extinguishing systems — Part 1: Design, installation and maintenance (ISO 14520-1:2015, modified)*

EN 17450-1, *Fixed firefighting systems — Water mist components — Part 1: Product characteristics and test methods for strainer and filter components*

EN 17451, *Fixed firefighting systems — Automatic sprinkler systems — Design, assembly, installation and commissioning of pump sets*

EN 50342 (all parts), *Lead-acid starter batteries*

EN 60529, *Degrees of protection provided by enclosures (IP Code)*

EN 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes - Vented nickel-cadmium prismatic rechargeable single cells (IEC 60623)*

ISO 3046-1, *Reciprocating internal combustion engines — Performance — Part 1: Declarations of power, fuel and lubricating oil consumptions, and test methods — Additional requirements for engines for general use*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN