

STN	Plynárenská infraštruktúra Regulačné stanice plynu na prepravu a distribúciu Požiadavky na prevádzku	STN EN 12186 38 6418
------------	---	--

Gas infrastructure - Gas pressure control stations for transmission and distribution - Functional requirements

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 03/26

Obsahuje: EN 12186:2025

Oznámením tejto normy sa ruší
STN EN 12186 (38 6418) z januára 2016

142331

EUROPEAN STANDARD

EN 12186

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2025

ICS 23.060.40; 27.060.20; 75.200

Supersedes EN 12186:2014

English Version

Gas infrastructure - Gas pressure control stations for transmission and distribution - Functional requirements

Infrastructures gazières - Postes de détente-régulation de pression de gaz pour le transport et la distribution - Prescriptions fonctionnelles

Gasinfrastruktur - Gas-Druckregelanlagen für Transport und Verteilung - Funktionale Anforderungen

This European Standard was approved by CEN on 10 November 2025.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 12186:2025 (E)

Contents		Page
European foreword		5
Introduction		6
1	Scope	7
2	Normative references	7
3	Terms, definitions, symbols and abbreviations	8
3.1	General	9
3.2	Station	9
3.3	Pressure, design and testing	12
3.4	Pressure control	13
3.5	Smart technologies	15
4	Quality and safety management system	15
5	Environmental interaction	15
5.1	General requirements	15
5.2	Waste	15
5.3	Greenhouse gas emissions	16
5.4	Adaptation to the effects of climate change	17
5.4.1	General	17
5.4.2	Design phase	17
5.4.3	Construction, commissioning and decommissioning	17
5.4.4	Operation and maintenance	17
5.5	Mitigation of the impact of earthquakes	18
6	Layout of the gas pressure control station	18
6.1	General	18
6.2	Layout of the site	18
6.3	Site security	18
7	Housings	19
7.1	General	19
7.2	Requirements for housings	19
7.3	Underground stations	20
7.3.1	General	20
7.3.2	Stations in a pit	20
7.3.3	Buried vessel type stations	21
8	Design of the station and its systems	21
8.1	General	21
8.2	Continuity of supply	22
8.3	Filters, separators	22
8.4	Gas pre-heating system	22
8.5	Noise control	23
8.5.1	General	23
8.5.2	Environmental acceptance	23
8.5.3	Work area noise	23
8.6	Apertures and vent lines	23
8.6.1	Apertures in pressure control equipment	23
8.6.2	Vent lines	24
8.7	Connections for purging, recompression or flaring	24
8.8	Hazardous areas	24

8.9	Cathodic protection and electrical isolation system	24
8.10	Lightning protection, electric continuity and earthing	25
8.11	Pressure control system	25
8.12	Flow-rate control system	25
8.13	Pipework system	26
8.14	Welding	26
8.15	Instrumentation pipework	26
8.16	Stress analysis	27
8.16.1	Design pressure	27
8.16.2	Design factor	27
8.16.3	Supports	27
8.16.4	Flexibility	28
8.16.5	Temperature	28
8.16.6	Gas velocity	28
8.17	Standard pressure equipment strength	28
8.18	Isolating valves	28
8.19	Smart systems and equipment	29
8.19.1	General	29
8.19.2	Fail safe conditions (safety and continuity of supply)	29
8.20	Electromagnetic compatibility, electrostatic phenomena and personal protection	29
8.21	Information security	29
9	Pressure control requirements	30
9.1	General	30
9.2	Pressure regulating system	31
9.3	Pressure safety system	31
9.3.1	General	31
9.3.2	Operating principles of pressure safety systems	31
9.3.3	Applications	31
9.3.4	Safety shut-off devices	32
9.3.5	Monitors	33
9.3.6	Safety-related electrical/electronic solutions	33
9.3.7	Venting devices	34
9.4	Pressure alarm system	34
9.5	Instrumentation	34
9.6	Bypasses	35
9.6.1	Bypasses for equalization or testing of components	35
9.6.2	Bypasses of the pressure control system	35
10	Testing	35
10.1	General	35
10.2	Pressure testing	35
10.2.1	General	35
10.2.2	Strength test	35
10.2.3	Tightness test	36
10.3	Reporting	36
11	Commissioning	37
12	Operation and maintenance	37
12.1	General	37
12.2	Documentation	38
12.3	Maintenance requirements	38
12.4	Training	39
12.5	Work undertaken	39

EN 12186:2025 (E)

12.6	Fire fighting	40
12.7	Cyber security	40
13	Decommissioning and disposal	40
13.1	Decommissioning	40
13.2	Disposal	40
	Annex A (informative) Glossary	41
	Annex B (informative) Categories of greenhouse gas emissions in the scope of this document	43
	Annex C (informative) Mitigation of the impact of earthquakes	44
	Annex D (informative) Stations in operation - Changing of the type of gas	45
	Annex E (informative) Significant technical changes from the last edition of this document, EN 12186:2014	46
	Bibliography	48

European foreword

This document (EN 12186:2025) has been prepared by Technical Committee CEN/TC 234 “Gas infrastructure”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2026, and conflicting national standards shall be withdrawn at the latest by June 2026.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12186:2014.

EN 12186:2025 includes the following significant technical changes with respect to EN 12186:2014:

- the scope of the standard is expanded and now covers natural gas, blends of natural gas with hydrogen and hydrogen, as mentioned in CEN/TR 17797;
- measures to avoid greenhouse gas emissions were further detailed throughout the document;
- measures for adapting to climate change were included;
- as part of comprehensive automation, regulators, valves and safety devices are increasingly being equipped with communication interfaces so that they can be integrated into the overall information management of a pressure control station. The relevant requirements for these smart systems and equipment are defined in this document;
- gas pressure control stations are increasingly being integrated into operators' communication infrastructures. This has been taken into account in this edition of EN 12186 by including basic requirements for information security and safety-related electrical/electronic solutions.

Annex E provides the details of significant technical changes between this document and the previous edition.

This document has been prepared under a standardization request addressed to CEN by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

EN 12186:2025 (E)**Introduction**

The gas infrastructure is complex and the importance on safety of its construction and use has led to the development of very detailed codes of practice and operating manuals in the member countries. These detailed statements embrace recognized standards of gas engineering and the specific requirements imposed by the legal structures of the member countries.

There is a complete suite of functional standards prepared by CEN/TC 234 “Gas Infrastructure” to cover all parts of the gas infrastructure from the input of gas into the on-shore transmission network up to the inlet connection of gas appliances, including injection, transmission, compression, pressure control, storage, blending, gas treatment, odorization, distribution, measuring, and associated installation pipework, as well as related requirements such as safety, gas quality, sustainability, environment and emissions. Within the scope of CEN/TC 234, gaseous energy carriers and blends describe gases which are in the gaseous state when conveyed in the gas pipeline infrastructure such as hydrogen, hydrogen rich, and methane rich gases, dimethyl ether (DME) and propane and butanes used for combustion and/or as feedstock, excluding steam and compressed air.

In preparing this document, a basic understanding of gas infrastructure by the user has been assumed. CEN/TC 234 standards are maintained to provide the state of the art and especially to facilitate the use of green gases in the gas infrastructure.

As gas pressure control stations for transmission and distribution are specifically designed for pipelines, they are considered as annexed equipment, and as such are excluded from the scope of the Directive 2014/68/EU (Pressure Equipment Directive – PED [3]). However, standard pressure equipment installed in these stations, e.g. gas pressure regulators, safety valves, valves, filters, heat exchangers, vessels, is covered by the directive [4].

Directive (EU) 2024/1788 [9] on common rules for the internal markets for renewable gas, natural gas and hydrogen and the related Regulation (EU) 2024/1789 [10] on the internal markets for renewable gas, natural gas and hydrogen also aim at technical safety (security) including technical reliability of the European gas and hydrogen system. These aspects and Directive (EU) 2018/2001 on the promotion of the use of energy from renewable sources [5] are also in the focus of CEN/TC 234 standardization. In this respect CEN/TC 234 evaluated the indicated EU legislation and amended this technical standard accordingly, where required and appropriate.

This document has been adapted to the requirements of the Regulation (EU) 2024/1787 on the reduction of methane emissions in the energy sector [8].

In this edition of EN 12186 environmental aspects relevant to the design, construction and testing, operation and maintenance, decommissioning and disposal of pressure control stations in the scope of this document are covered in accordance with CEN Guide 4 and CEN/TR 16388.

This document supports the mainstreaming climate adaptation into European standards according to the European Climate Law ((EU) 2021/1119 [6]) and the 2021 EU Adaptation Strategy for adaptation to climate change.

This document specifies common basic principles for the gas infrastructure. Users of this document are expected be aware that more detailed national standards and/or codes of practice can exist in the CEN member countries.

This document is intended to be applied in association with these national standards and/or codes of practice setting out the basic principles as outlined in Clause 1 of this document.

1 Scope

This document specifies the functional requirements relevant for design, materials, construction, testing, operation and maintenance of gas pressure control stations to ensure their reliability in terms of safety of the station itself and the downstream system and continuity of service.

This document is applicable for gas pressure control stations which are part of gas transmission or distribution systems for hydrogen, and hydrogen rich, and methane rich gases. Additional requirements in the case of gases heavier than air and/or toxic or corrosive gases are not covered by this document.

This document does not apply to gas pressure control stations in operation prior to the publication of this document. However, Annex D of this document can be used as guidance for the evaluation of stations in operation prior to the publication of this document, regarding the change of the type of gas, e.g. repurposing for the use with hydrogen.

The stations covered by this document have a maximum upstream operating pressure, which does not exceed 100 bar. For higher maximum upstream operating pressures, this document can be used as a guideline.

If the inlet pipework of the station is a service line and the maximum upstream operating pressure does not exceed 16 bar and the design flow rate is equal to 2000 kW based on the gross calorific value or less, EN 12279 applies.

This document contains the basic system requirements for gas pressure control stations. Requirements for individual components (valves, regulators, safety devices, pipes, etc.) or installation of the components are contained in the appropriate European Standards.

NOTE For combined control and measuring stations, the additional requirements of EN 1776 can apply.

The requirements in this document do not apply to the design and construction of auxiliary facilities such as sampling, calorimetry, odorization systems and density measuring. These facilities are covered by the appropriate European Standards, where existing, or applicable national standards.

The requirements of this document are based on good gas engineering practice under conditions normally encountered in the gas industry. Requirements for unusual conditions cannot be specifically provided for, nor are all engineering and construction details prescribed.

The objective of this document is to ensure the safe operation of such stations. This does not, however, relieve all concerned of the responsibility for taking the necessary care and applying effective quality and safety management during the design, construction, operation and maintenance.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 334, *Gas pressure regulators for inlet pressures up to 10 MPa (100 bar)*

EN 1127-1, *Explosive atmospheres — Explosion prevention and protection — Part 1: Basic concepts and methodology*

EN 1594, *Gas infrastructure — Pipelines for maximum operating pressure over 16 bar — Functional requirements*

EN 10204, *Metallic products — Types of inspection documents*

EN 12186:2025 (E)

EN 12007-1, *Gas infrastructure — Pipelines for maximum operating pressure up to and including 16 bar — Part 1: General functional requirements*

EN 12007-3, *Gas infrastructure — Pipelines for maximum operating pressure up to and including 16 bar — Part 3: Specific functional requirements for steel*

EN 12327, *Gas infrastructure — Pressure testing, commissioning and decommissioning procedures — Functional requirements*

EN 12732, *Gas infrastructure — Welding steel pipework — Functional requirements*

EN 14382, *Gas safety shut-off devices for inlet pressures up to 10 MPa (100 bar)*

EN 17649, *Gas infrastructure — Safety Management System (SMS) and Pipeline Integrity Management System (PIMS) — Functional requirements*

EN ISO 4126-1, *Safety devices for protection against excessive pressure — Part 1: Safety valves (ISO 4126-1)*

EN ISO 4126-4, *Safety devices for protection against excessive pressure — Part 4: Pilot-operated safety valves (ISO 4126-4)*

EN ISO 4126-5, *Safety devices for protection against excessive pressure — Part 5: Controlled safety pressure relief systems (CSPRS) (ISO 4126-5)*

EN ISO 80079-36, *Explosive atmospheres — Part 36: Non-electrical equipment for explosive atmospheres — Basic method and requirements (ISO 80079-36)*

EN IEC 60079-10-1, *Explosive atmospheres — Part 10-1: Classification of areas — Explosive gas atmospheres*

EN IEC 60079-14, *Explosive atmospheres — Part 14: Electrical installation design, selection and installation of equipment, including initial inspection*

EN IEC 61000-6-4, *Electromagnetic compatibility (EMC) — Part 6-4: Generic standards — Emission standard for industrial environments*

EN IEC 61340-5-1, *Electrostatics — Part 5-1: Protection of electronic devices from electrostatic phenomena — General requirements*

EN IEC 62443 (all parts), *Security for industrial automation and control systems*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN