

STN	Vysokonapäťové spínacie a riadiace zariadenia Časť 208: Metódy kvantifikovania ustáleného elektromagnetického poľa siet'ovej frekvencie generovaného vysokonapäťovými rozvádzačmi a blokovými transformačnými stanicami vysokého napätia/nízkeho napätia pre menovité napätia nad 1 kV až do 52 kV vrátane	STN EN IEC 62271-208 35 4220
------------	---	--

High-voltage switchgear and controlgear - Part 208: Methods to quantify the steady state, power-frequency electromagnetic fields generated by HV switchgear assemblies and HV/LV prefabricated substations, both for rated voltages above 1 kV and up to and including 52 kV

Táto norma obsahuje anglickú verziu európskej normy.
This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 04/26

Obsahuje: EN IEC 62271-208:2026, IEC 62271-208:2025

Oznámením tejto normy sa od 28.02.2029 ruší
TNI CLC/TR 62271-208 (35 4220) z júla 2010

142412



Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2026
Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii v znení neskorších predpisov.

EUROPEAN STANDARD

EN IEC 62271-208

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2026

ICS 29.130.10

Supersedes CLC/TR 62271-208:2010

English Version

**High-voltage switchgear and controlgear - Part 208: Methods to quantify the steady state, power-frequency electromagnetic fields generated by HV switchgear assemblies and HV/LV prefabricated substations, both for rated voltages above 1 kV and up to and including 52 kV
(IEC 62271-208:2025)**

Appareillage à haute tension - Partie 208: Méthodes de quantification des champs électromagnétiques à fréquence industrielle en régime établi générés par les ensembles d'appareillages HT et les postes préfabriqués HT/BT, à la fois pour les tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV
(IEC 62271-208:2025)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 208: Methoden zur Bestimmung der stationären, betriebsfrequenten elektromagnetischen Felder von HS-Schaltanlagen und fabrikfertigen HS-/ NS-Stationen, beides für Bemessungsspannungen über 1 kV und bis einschließlich 52 kV
(IEC 62271-208:2025)

This European Standard was approved by CENELEC on 2026-01-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 62271-208:2026 (E)**European foreword**

The text of document 17C/977/FDIS, future edition 1 of IEC 62271-208, prepared by SC 17C "Assemblies" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-208:2026.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2027-02-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2029-02-28

This document supersedes CLC/TR 62271-208:2010 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62271-208:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 62110 NOTE Approved as EN 62110

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-6-2	-	Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity standard for industrial environments	EN IEC 61000-6-2	-
IEC 61786-1	-	Measurement of DC magnetic, AC magnetic and AC electric fields from 1 Hz to 100 kHz with regard to exposure of human beings - Part 1: Requirements for measuring instruments	EN 61786-1	-
IEC 61786-2	-	Measurement of DC magnetic, AC magnetic and AC electric fields from 1 Hz to 100 kHz with regard to exposure of human beings - Part 2: Basic standard for measurements	-	-
IEC 62271-200	-	High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN IEC 62271-200	-
IEC 62271-201	-	High-voltage switchgear and controlgear - Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-201	-
IEC 62271-202	-	High-voltage switchgear and controlgear - Part 202: AC prefabricated substations for rated voltages above 1 kV and up to and including 52 kV	EN IEC 62271-202	-



IEC 62271-208

Edition 1.0 2025-12

INTERNATIONAL STANDARD

**High-voltage switchgear and controlgear -
Part 208: Methods to quantify the steady state, power-frequency electromagnetic
fields generated by HV switchgear assemblies and HV/LV prefabricated
substations, both for rated voltages above 1 kV and up to and including 52 kV**

**THIS PUBLICATION IS COPYRIGHT PROTECTED****Copyright © 2025 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

IEC 62271-208:2025 © IEC 2025

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Evaluation requirements	8
4.1 General	8
4.2 Methods of evaluation	9
4.3 Evaluation of electric fields	9
4.3.1 HV assemblies	9
4.3.2 HV/LV prefabricated substations	9
4.4 Evaluation of magnetic fields	9
4.4.1 HV assemblies	9
4.4.2 HV/LV prefabricated substations	10
5 Measurements	11
5.1 General	11
5.2 Measuring instruments	11
5.3 Measurement procedures	12
5.3.1 General	12
5.3.2 General	12
5.3.3 Hot spot measurement procedure	13
5.3.4 Isoline measurement procedure	17
5.4 Measurement set-up	18
5.4.1 General	18
5.4.2 Hot spot measurement set-up	18
5.4.3 Isoline measurement set-up	20
5.4.4 External connections	21
5.4.5 Additional provisions for HV/LV prefabricated substations	22
6 Calculations	22
6.1 General	22
6.2 Software	22
6.3 Calculation procedures	23
6.4 Results	23
6.5 Validation	23
7 Documentation	24
7.1 General	24
7.2 Characteristics of the HV assembly or prefabricated substation	24
7.3 Evaluation method	24
7.4 Presentation of the measurement results	24
7.5 Presentation of the calculation results	25
Annex A (informative) Presentation of E- or B-field measurement data – Examples for a typical HV/LV prefabricated substation	26
A.1 Presentation of hot spot B-field measurement results	26
A.1.1 General	26
A.1.2 Hot spot locations	27
A.1.3 Hot spot locations with its E- or B-field values	27

IEC 62271-208:2025 © IEC 2025

A.1.4	Field variation around substation at hot spot locations	28
A.1.5	Variation of the E- or B-field as a function of the distance	28
A.1.6	Background fields	29
A.2	Presentation of isoline E- or B-field measurement results	29
A.2.1	Location of measurement points on isoline	29
A.2.2	Background fields	30
A.2.3	Example of an isoline measurement on a 1 600 kVA power transformer substation	31
Annex B (informative)	Examples of analytical solutions to benchmark EMF calculations	32
B.1	Magnetic field.....	32
B.2	Electric field	41
Bibliography	51
Figure 1	– Example of test circuits configuration to obtain the maximum external magnetic field of a HV assembly or a prefabricated substation	10
Figure 2	– Reference surface (RS) and measurement surface (MS) for equipment of irregular shape.....	13
Figure 3	– Scanning areas to find the hot spots	14
Figure 4	– Determination of the field variation as a function of the distance from the hot spot locations (perpendicular to the reference surface).....	15
Figure 5	– Height of measurement plane.....	17
Figure 6	– Example of test circuit for electric and magnetic field measurement	19
Figure 7	– Example of hot spot test set-up with measurement results.....	20
Figure 8	– Example of isoline test set-up with measurement results.....	21
Figure A.1	– Hot spot locations representing the field maxima.....	27
Figure A.2	– Example diagram for the field variation at hot spots.....	28
Figure A.3	– Graphical presentation of the field variation	29
Figure A.4	– Graphical presentation of measurement points on isoline	30
Figure A.5	– Isoline of 10 μ T for a 1 600 kVA substation.....	31
Figure B.1	– Schematic for 3-phase magnetic field calculation	32
Figure B.2	– Variation of resultant magnetic field around 3-phase cable	35
Figure B.3	– Maximum resultant magnetic field around 3-phase cable.....	36
Figure B.4	– Schematic for 3-phase electric field calculation	41
Figure B.5	– Variation of resultant electric field around 3-phase cable.....	44
Figure B.6	– Maximum resultant electric field around 3-phase cable	46
Table A.1	– Listing of the hot spot coordinates	28
Table A.2	– Variation of field values for one hot spot.....	29
Table A.3	– Background fields	29
Table A.4	– Listing of the location (coordinates) of the measurement points	30
Table A.5	– Background fields	31
Table B.1	– Values of H_{res} [A/m] for spatial angles θ and time angles ωt	35
Table B.2	– Values of maximum H_{res} [A/m] for spatial angles θ	37
Table B.3	– Values of E_{res} [V/m] for spatial angles θ and time angles ωt	45
Table B.4	– Values of maximum E for spatial angles θ	46

IEC 62271-208:2025 © IEC 2025

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**High-voltage switchgear and controlgear -
Part 208: Methods to quantify the steady state, power-frequency
electromagnetic fields generated by HV switchgear assemblies and HV/LV
prefabricated substations, both for rated voltages above 1 kV and up to
and including 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-208 document has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This first edition cancels and replaces the first edition of IEC TR 62271-208, published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the isoline measurement procedure is introduced and compared to the hot spot one when it is required as a measurement for the characterization of a generated electromagnetic field.

IEC 62271-208:2025 © IEC 2025

The text of this International Standard is based on the following documents:

Draft	Report on voting
17C/977/FDIS	17C/983/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all the parts in the IEC 62271 series, under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IEC 62271-208:2025 © IEC 2025

INTRODUCTION

Manufacturers of electricity supply equipment can be asked to provide information about the electromagnetic field characteristics to enable the user to

- assess the electromagnetic field conditions to assist with planning, installation, operating instructions and service,
- take measures to meet requirements or regulations on electromagnetic fields,
- compare different products as far as their level of electromagnetic fields is concerned.

The purpose of this document is to describe a methodology for the evaluation (measurement or calculation) of generated electromagnetic fields. In particular, if a measurement is required, hot spot and isolines procedures are introduced and described.

The electromagnetic field characteristic of the equipment comprises the values of the electric and the magnetic fields around its accessible surfaces.

The electromagnetic field characteristic defined in this document refers to a single product as defined in the scope. In real installations, several field sources can superimpose, so the resulting electromagnetic fields on site can differ significantly from the single product characteristics.

This document does not define a mandatory test for the products mentioned in the scope.

Neither the establishment of limits for the electromagnetic fields generated by equipment, nor the establishment of assessment methods for the human exposure to electromagnetic fields are within the content or intent of this document.

IEC 62271-208:2025 © IEC 2025

1 Scope

This part of IEC 62271 gives practical guidance for the evaluation and documentation of the external steady state power-frequency electromagnetic fields which are generated by HV switchgear and controlgear assemblies and prefabricated substations. Basic requirements to measure or calculate the electric and magnetic fields are summarised for assemblies covered by IEC 62271-200 and IEC 62271-201, and for prefabricated substations covered by IEC 62271-202.

NOTE 1 The methods described in this document refer to three-phase equipment. However, the methodology can be used correspondingly for any single- or multi-phase equipment covered by this document.

This document applies to equipment rated for voltages above 1 kV up to and including 52 kV and power-frequencies from 15 Hz to 60 Hz. The electromagnetic fields which are generated by harmonics or transients are not considered in this document. However, the methods described are equally applicable to the harmonic fields of the power-frequency.

Detailed generic information on requirements and measurements of low-frequency electromagnetic fields is given in IEC 61786-1 and IEC 61786-2.

This document covers evaluation under factory or laboratory conditions before installation. The electric and the magnetic fields can be evaluated either by measurements or by calculations.

NOTE 2 Where practicable, the methods described in this document can also be used for installations on site.

It is not within the scope of this document to specify limit values of electromagnetic fields or methods for the assessment of human exposure.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-6-2, *Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments*

IEC 61786-1, *Measurement of DC magnetic, AC magnetic and AC electric fields from 1 Hz to 100 kHz with regard to exposure of human beings - Part 1: Requirements for measuring instruments*

IEC 61786-2, *Measurement of DC magnetic, AC magnetic and AC electric fields from 1 Hz to 100 kHz with regard to exposure of human beings - Part 2: Basic standard for measurements*

IEC 62271-200, *High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-201, *High-voltage switchgear and controlgear - Part 201: AC solid-insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-202, *High-voltage switchgear and controlgear - Part 202: AC prefabricated substations for rated voltages above 1 kV and up to and including 52 kV*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN