

STN	Nízkonapäťové spínacie a riadiace zariadenia Časť 6-1: Spínače s viacerými funkciami Prepínacie zariadenia	STN EN IEC 60947-6-1 35 4101
------------	---	--

Low-voltage switchgear and controlgear - Part 6-1: Multiple function equipment - Transfer switching equipment

Táto norma obsahuje anglickú verziu európskej normy.

This standard includes the English version of the European Standard.

Táto norma bola oznámená vo Vestníku ÚNMS SR č. 08/26

Obsahuje: EN IEC 60947-6-1:2026, IEC 60947-6-1:2026

Oznámením tejto normy sa od 31.05.2029 ruší

STN EN IEC 60947-6-1 (35 4101) zo septembra 2023

142848



Úrad pre normalizáciu, metrológiu a skúšobníctvo Slovenskej republiky, 2026

Slovenská technická norma a technická normalizačná informácia je chránená zákonom č. 60/2018 Z. z. o technickej normalizácii v znení neskorších predpisov.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 60947-6-1

May 2026

ICS 29.120.40; 29.130.20

Supersedes EN IEC 60947-6-1:2023

English Version

**Low-voltage switchgear and controlgear - Part 6-1: Multiple
function equipment - Transfer switching equipment
(IEC 60947-6-1:2026)**

Appareillage à basse tension - Partie 6-1: Matériels à
fonctions multiples - Équipement de transfert de source
(IEC 60947-6-1:2026)

Niederspannungsschaltgeräte - Teil 6-1:
Mehrfunktionsschaltgeräte - Netzumschalter
(IEC 60947-6-1:2026)

This European Standard was approved by CENELEC on 2026-05-07. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 60947-6-1:2026 (E)**European foreword**

The text of document 121A/711/FDIS, future edition 4 of IEC 60947-6-1, prepared by SC 121A "Low-voltage switchgear and controlgear" of IEC/TC 121 "Switchgear and controlgear and their assemblies for low voltage" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60947-6-1:2026.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2027-05-31 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2029-05-31 document have to be withdrawn

This document supersedes EN IEC 60947-6-1:2023 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60947-1:2021.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 60947-6-1:2026 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60034-12:2024	NOTE	Approved as EN IEC 60034-12:2024 (not modified)
IEC 60079 (series)	NOTE	Approved as EN IEC 60079-7:2015/A1 (series)
IEC 60364-5-56:2018	NOTE	Approved as HD 60364-5-56:2018 (not modified)
IEC 60947-3:2020	NOTE	Approved as EN IEC 60947-3:2021 (not modified)
IEC 60947-6-2:2020	NOTE	Approved as EN IEC 60947-6-2:2023 (not modified)
IEC 61010-2-201:2024	NOTE	Approved as EN IEC 61010-2-201:2024 (not modified)
IEC 61439 (series)	NOTE	Approved as EN IEC 61439 (series)
IEC 62310 (series)	NOTE	Approved as EN 62310 (series)
IEC 62443 (series)	NOTE	Approved as EN IEC 62443-4-2:2019/AC:2022-09 (series)
IEC/TR 63201:2019	NOTE	Approved as CLC IEC/TR 63201:2020 (not modified)

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-2	2007	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	2007
IEC 60417	2025	Graphical symbols for use on equipment - 12-month subscription to regularly updated online database comprising all graphical symbols published in IEC 60417	-	-
IEC 60715	2017	Dimensions of low-voltage switchgear and controlgear - Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories	EN 60715	2017
IEC 60812	2018	Failure modes and effects analysis (FMEA and FMECA)	EN IEC 60812	2018
IEC 60947-1	2020	Low-voltage switchgear and controlgear - Part 1: General rules	EN IEC 60947-1	2021
IEC 60947-2	2024	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	EN IEC 60947-2	2025
IEC 60947-4-1	2023	Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters	EN IEC 60947-4-1	2025
IEC 60947-5-1	2024	Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN IEC 60947-5-1	2025
IEC 61000-4-13	2002	Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests	EN 61000-4-13	2002
+ A1	2009		+ A1	2009
+ A2	2015		+ A2	2016

EN IEC 60947-6-1:2026 (E)

IEC 61439-1	2020	Low-voltage switchgear and controlgear assemblies - Part 1: General rules	EN IEC 61439-1	2021
IEC 61439-2	2020	Low-voltage switchgear and controlgear assemblies - Part 2: Power switchgear and controlgear assemblies	EN IEC 61439-2	2021
IEC 61557-12	2018	Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC - Equipment for testing, measuring or monitoring of protective measures - Part 12: Power metering and monitoring devices (PMD)	EN IEC 61557-12	2022
+ A1	2021		+ A1	2022
IEC 61812-1	2023	Time relays and coupling relays for industrial and residential use - Part 1: Requirements and tests	EN IEC 61812-1	2024
IEC 63208	2025	Low-voltage switchgear and controlgear and their assemblies - Security requirements	EN IEC 63208	2025
CISPR 11	2024	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN IEC 55011	2025



IEC 60947-6-1

Edition 4.0 2026-04

INTERNATIONAL STANDARD

**Low-voltage switchgear and controlgear -
Part 6-1: Multiple function equipment - Transfer switching equipment**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -
webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

IEC 60947-6-1:2026 © IEC 2026

CONTENTS

FOREWORD	6
INTRODUCTION	8
1 Scope	9
2 Normative references	10
3 Terms and definitions	11
3.1 Alphabetical index of terms	11
3.2 Transfer switching devices	13
3.3 Operation of TSE	15
3.4 Main contact positions	17
3.5 Symbols and abbreviations used in this document	18
4 Classification	18
5 Characteristics	19
5.1 Summary of characteristics	19
5.2 Type and characteristics of equipment	19
5.3 Rated and limiting values for the main circuit	20
5.3.1 General	20
5.3.2 Rated voltages	20
5.3.3 Rated operational current (I_e)	20
5.3.4 Rated frequency	20
5.3.5 Rated making and breaking capacities	21
5.3.6 Short-circuit characteristics	21
5.4 Utilization category	22
5.5 Control circuits	22
5.5.1 General	22
5.5.2 Electromechanical devices operating the main circuit	22
5.5.3 ATS controller	23
5.6 Auxiliary circuits	23
6 Product information	23
6.1 Nature of information	23
6.2 Marking	23
6.3 Instructions for installation, operation and maintenance, decommissioning and dismantling	25
6.4 Environmental information	26
7 Normal service, mounting and transport conditions	27
8 Constructional and performance requirements	27
8.1 Constructional requirements	27
8.1.1 General	27
8.1.2 Materials	27
8.1.3 Indication	28
8.1.4 Equipment suitable for isolation	28
8.1.5 Opening and closing of main contacts	28
8.1.6 Clearances and creepage distances	29
8.1.7 Provision for protective earthing	29
8.1.8 Stored charge energy circuit	29
8.1.9 Stored energy closing	29

IEC 60947-6-1:2026 © IEC 2026

8.1.10	Dedicated enclosures for TSE	29
8.1.11	Communication.....	29
8.2	Performance requirements.....	30
8.2.1	Operating conditions.....	30
8.2.2	Temperature-rise	31
8.2.3	Dielectric properties.....	31
8.2.4	Ability to make, carry, and break under no-load, normal load and overload conditions.....	31
8.2.5	Ability to make and break under short-circuit conditions.....	34
8.2.6	Critical load current performance of TSE with DC rating	35
8.3	Electromagnetic compatibility (EMC).....	35
8.3.1	General	35
8.3.2	Immunity.....	35
8.3.3	Emission.....	36
9	Tests	36
9.1	Kinds of tests	36
9.2	Type tests	36
9.2.1	General test conditions	36
9.2.2	Test sequences	37
9.2.3	Test sequence I – General performance characteristics	39
9.2.4	Test sequence II – Operational performance capability	46
9.2.5	Test sequence III – Short-circuit performance capability	51
9.2.6	Test sequence IV – Conditional short-circuit current	54
9.2.7	Test sequence V – Critical load current performance of equipment with a DC rating	55
9.2.8	Test sequence VI – EMC tests.....	58
9.3	Routine tests	60
9.4	Environmental tests	62
Annex A (normative)	Assignment of utilization categories based on results of tests	64
Annex B (informative)	Items subject to agreement between manufacturer and user	65
Annex C (normative)	Bypass/isolation transfer switch equipment	66
C.1	General.....	66
C.2	(void)	66
C.3	(void)	66
C.4	Classification	66
C.5	Characteristics.....	66
C.6	Product information.....	66
C.7	Normal service, mounting and transport conditions	66
C.8	Constructional and performance requirements	67
C.8.1	General	67
C.8.2	Construction requirements.....	67
C.8.3	Performance requirements.....	68
C.9	Tests	70
C.9.1	General	70
C.9.2	Interlocking function verification.....	70
C.9.3	Full assembly tests	70
C.9.4	Routine tests	70
C.10	BTSE typical circuits and main components	71

IEC 60947-6-1:2026 © IEC 2026

C.10.1	Example of operating sequence of a single line fixed type BTSE	71
C.10.2	Example of operating sequence of a double line fixed type BTSE	72
C.10.3	Example of operating sequence of a double line withdrawable type BTSE	73
C.10.4	Example of operating sequence of a double line load-break withdrawable type BTSE	74
C.10.5	Example of operating sequence of a single line withdrawable type BTSE	75
Annex D (normative)	ATSE having closed transition capability	76
D.1	General	76
D.2	(void)	76
D.3	(void)	76
D.4	Classification	76
D.5	Characteristics	76
D.6	Product information	76
D.6.1	General	76
D.6.2	Product instructions for operation	77
D.7	Normal service, mounting and transport conditions	77
D.8	Constructional and performance requirements	77
D.8.1	General	77
D.8.2	Operating mechanism	78
D.8.3	Controls, sequence, and limits of operation	78
D.8.4	Performance requirements	79
D.9	Tests	80
D.9.1	General	80
D.9.2	Test procedure	80
D.9.3	Figures to clarify closed transition transfer	81
Annex E (normative)	Stand-alone ATS controller	85
E.1	General	85
E.2	(void)	85
E.3	(void)	85
E.4	Classification	85
E.5	Characteristics	85
E.6	Product information	85
E.6.1	General	85
E.6.2	Product instructions for operation	87
E.7	Normal service, mounting and transport conditions	88
E.8	Constructional and performance requirements	88
E.8.1	Constructional requirements	88
E.8.2	Performance requirements	90
E.8.3	Electromagnetic compatibility (EMC)	90
E.9	Tests	90
E.9.1	General	90
E.9.2	List of type tests	90
E.9.3	Wire flexing test	91
E.9.4	EMC tests	91
E.9.5	Stand-alone ATS controller routine test	92
E.9.6	Environmental tests	92
E.9.7	Example to clarify stand-alone ATS controller operating transfer time	92

IEC 60947-6-1:2026 © IEC 2026

Annex F (normative) TSE used with electric driven fire pump control equipment	93
F.1 General.....	93
F.2 Normative references.....	93
F.3 Terms and definitions.....	93
F.4 Classification	93
F.5 Characteristics.....	93
F.6 Product information.....	93
F.7 Normal service, mounting and transport conditions	94
F.8 Constructional, functional, and performance requirements	94
F.8.1 General	94
F.8.2 General	94
F.8.3 Manual operating means for maintenance and servicing	94
F.8.4 ATSE Voltage sensing	95
F.8.5 ATSE Initiation of transfer to secondary supply source	95
F.8.6 ATSE Frequency monitoring of generator source	95
F.8.7 Indicators of transfer.....	95
F.8.8 Integral protective devices	95
F.8.9 ATSE Generator starting contacts.....	95
F.8.10 Power circuit components.....	96
F.8.11 Operating mechanism	96
F.9 Tests	96
F.9.1 General	96
F.9.2 Type tests.....	96
Bibliography.....	97
Figure 1 – Example of operating sequences for TSE with three positions.....	26
Figure 2 – Test circuit for connection to source I and source II supplies	61
Figure 3 – Test circuit for the verification of making and breaking capacities	62
Figure C.1 – Single line fixed type BTSE	71
Figure C.2 – Double line fixed type BTSE	72
Figure C.3 – Double line withdrawable type BTSE	73
Figure C.4 – Double line load-break withdrawable type BTSE	74
Figure C.5 – Single line withdrawable type BTSE.....	75
Figure D.1 – Additional control circuit and external disconnecting devices	79
Figure D.2 – Open transition	81
Figure D.3 – Closed transition.....	81
Figure D.4 – Example to describe a typical open and closed transition operating sequence	82
Figure D.5 – Example of an operating sequence with a fail to open position II contacts within 100 ms during a return transfer in closed transition.....	83
Figure D.6 – Example of an operating sequence with a fail to open both position I and position II contacts during a return transfer in closed transition and showing the removal of the condition by signalling an external device to open (source II)	84
Figure E.1 – Example to show the stand-alone ATS controller operating transfer time	92
Table 1 – Utilization categories	22
Table 2 – Product information	23

IEC 60947-6-1:2026 © IEC 2026

Table 3 – Verification of making and breaking capacity – Conditions for making and breaking corresponding to the utilization categories	32
Table 4 – Verification of operational performance – Conditions for making and breaking corresponding to the utilization categories	33
Table 5 – Value of the test current for the verification of the ability to operate under short-circuit conditions	34
Table 6 – Value of the test current for the verification of the ability to operate under short-circuit conditions (harmonized table)	35
Table 7 – Acceptance criteria of immunity test	36
Table 8 – List of type tests (overall scheme of test sequences)	37
Table 9 – List of type tests to which a derived TSE shall be submitted	38
Table 10 – Number and duration of operating cycles for the making and breaking capacity test	47
Table 11 – Number and rate of operating cycles for the electrical and mechanical operational performance tests for type A utilization categories	48
Table 12 – Number and rate of operating cycles for the electrical and mechanical operational performance tests for type B utilization categories	49
Table 13 – Temperature-rise limits for terminals and accessible parts	50
Table 14 – Number of operating cycles corresponding to the critical load current	57
Table 15 – Test circuit parameters for Table 14	57
Table 16 – Test sequence V: Critical load current performance of equipment with a DC rating	57
Table D.1 – Product information	77
Table E.1 – Product information	86
Table E.2 – List of type tests for the stand-alone ATS controller	91
Table F.1 – Product information	94

IEC 60947-6-1:2026 © IEC 2026

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Low-voltage switchgear and controlgear -
Part 6-1: Multiple function equipment -
Transfer switching equipment****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60947-6-1 has been prepared by sub-committee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2021. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- clarification of scope;
- clarification of terms and definitions;
- Annex C for Bypass/Isolation Transfer Switch Equipment;
- Annex D for ATSE having closed transition capability;

IEC 60947-6-1:2026 © IEC 2026

- Annex E for Stand-alone ATS controller;
- Annex F for TSE used with electric driven fire pump control equipment.

The text of this International Standard is based on the following documents:

Draft	Report on voting
121A/711/FDIS	121A/719/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all the parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This document is to be read in conjunction with IEC 60947-1:2020, *Low voltage switchgear and controlgear - Part 1: General rules*.

The provisions of the general rules are applicable to IEC 60947-6-1 where specifically called for. General rules clauses and subclauses thus applicable as well as tables, figures and appendices are identified by reference to IEC 60947-1:2020, for example, 1.2.3, Table 4, or Annex A of IEC 60947-1:2020.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IEC 60947-6-1:2026 © IEC 2026

INTRODUCTION

The availability of power in low voltage electrical installations is playing an ever increasing role in modern society. In fact, this requirement is a fundamental characteristic for the creation of economically and functionally efficient installations. A system able to switch a load from one source to another safely and with minimum disturbance to the load reduces problems caused by faulty conditions in the normal supply to the minimum.

All these operations, commonly known as "transfer switching", control the installations and can be done automatically, remotely or manually.

Therefore, an installation with installed "transfer switching" capability:

- ensures the continuity of production processes;
- provides a backup source of power if the main network is out of service;
- reduces the effect caused by network faults on parts of the installation;
- achieves a good compromise between reliability, simplicity and cost-effectiveness;
- provides the facility manager and managing system with a power source able to supply all or part of the installation.

Key factors motivating customers to use Transfer Switch Equipment (TSE) include:

- the continuous world growth population, the increasing number of electronic devices and the new demands of electric vehicles;
- the mediated pressure on climate change with a resulting increase in the cost of energy;
- the evolution of the electricity market with a greater number of alternate energy sources;
- the user's expectations of better grid reliability, better economic performance, and a desire to manage their energy.

Stakeholders involved in the management of electricity also have new expectations:

- customers want to reduce the cost of their energy and to have a quality energy supply;
- suppliers want to reinforce confidence to their customers;
- producers expect to optimize their investments;
- governments and regulators are willing to create a competitive and sustainable energy market.

Today, the performance of transfer switching equipment is defined by TSE manufacturers and also by this document. Consultants, integrators, facility managers and end users rely on this document for their power availability needs.

Transfer switching is often realised by implementing a transfer function within the electrical installation, and this critical function needs to be appropriately designed. Using a TSE following the requirements of this document ensure the safety and the performance of the transfer function which are necessary for reaching the objectives listed above.

IEC 60947-6-1:2026 © IEC 2026

1 Scope

This document applies to transfer switching equipment (TSE), to be used in power systems for ensuring the continuity of the supply and allowing the energy management of the installation, by transferring a load between power supply sources, the rated voltage of which does not exceed 1 000 V AC or 1 500 V DC.

Specific requirements for bypass/isolation transfer switch equipment are given in Annex C, ATSE having closed transition capability are given in Annex D, stand-alone ATS controllers are given in Annex E, and TSE for electric driven fire pump controllers are given in Annex F.

It covers:

- manually operated transfer switching equipment (MTSE);
- remotely operated transfer switching equipment (RTSE);
- automatic transfer switching equipment (ATSE), including the controller;
- stand-alone ATS controllers;
- bypass/isolation transfer switch equipment (BTSE);
- ATSE having closed transition capability;
- fire pump TSE.

It does not cover:

- TSE configurations that are not fully manufacturer type tested or marked according to this document as a complete transfer switch;
- auxiliary contacts (for guidance, see IEC 60947-5-1);
- transfer switches used in explosive atmospheres (for guidance, see IEC 60079 (all parts));
- embedded software design (for guidance, see IEC TR 63201);
- cybersecurity aspects (for guidance, see IEC 63208);
- TSE rated for direct-on-line starting asynchronous motor of design NE and HE, according to IEC 60034-12. (for guidance, see AC-3e utilisation category according to IEC 60947-4-1);
- other types of TSE under consideration including overlapping neutral TSE, multi-source TSE (i.e. TSE with more than two sources of supply), TSE with load-shedding functions, bus-tie TSE, and hybrid TSE;
- static transfer switches covered by IEC 62310 series.

NOTE TSE used for safety services and for emergency escape lighting systems as described in IEC 60364-5-56 are subject to specific rules and legal requirements.

The object of this document is to state:

- a) the required characteristics of the equipment;
- b) the conditions with which the equipment is to comply with respect to:
 - 1) operation for which the equipment is intended;
 - 2) operation and behaviour in case of specified abnormal conditions, for example, short-circuit;
 - 3) dielectric properties;
 - 4) electromagnetic compatibility;
- c) the tests intended to confirm that these conditions have been met and the methods for performing these tests;
- d) the product information to be provided by the manufacturer.

IEC 60947-6-1:2026 © IEC 2026

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, *Environmental testing - Part 2-2: Tests - Test B: Dry heat*

IEC 60417:2025, *Graphical symbols for use on equipment - 12-month subscription to regularly updated online database comprising all graphical symbols published in IEC 60417*

IEC 60715:2017, *Dimensions of low-voltage switchgear and controlgear - Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories*

IEC 60812:2018, *Failure modes and effects analysis (FMEA and FMECA)*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear - Part 1: General rules*

IEC 60947-2:2024, *Low-voltage switchgear and controlgear - Part 2: Circuit-breakers*

IEC 60947-4-1:2023, *Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters*

IEC 60947-5-1:2024, *Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signaling at a.c. power port, low frequency immunity tests*

IEC 61000-4-13:2002/AMD1:2009

IEC 61000-4-13:2002/AMD2:2015

IEC 61439-1:2020, *Low-voltage switchgear and controlgear assemblies - Part 1: General rules*

IEC 61439-2:2020, *Low-voltage switchgear and controlgear assemblies - Part 2: Power switchgear and controlgear assemblies*

IEC 61557-12:2018, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC - Equipment for testing, measuring or monitoring of protective measures - Part 12: Power metering and monitoring devices (PMD)*

IEC 61557-12:2018/AMD1:2021

IEC 61812-1:2023, *Time relays and coupling relays for industrial and residential use - Part 1: Requirements and tests*

IEC 63208:2025, *Low-voltage switchgear and controlgear - Security aspects*

CISPR 11:2024, *Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement*

koniec náhľadu – text ďalej pokračuje v platenej verzii STN